



COMMONWEALTH OF MASSACHUSETTS
 EXECUTIVE OFFICE OF ENERGY & ENVIRONMENTAL AFFAIRS
 DEPARTMENT OF ENVIRONMENTAL PROTECTION
 NORTHEAST REGIONAL OFFICE
 205B Lowell Street, Wilmington, MA 01887 • (978) 694-3200

DEVAL L. PATRICK
 Governor

IAN A. BOWLES
 Secretary

TIMOTHY P. MURRAY
 Lieutenant Governor

LAURIE BURT
 Commissioner

FINAL AIR QUALITY OPERATING PERMIT

Issued by the Massachusetts Department of Environmental Protection ("MassDEP") pursuant to its authority under M.G.L. c. 111, §142B and §142D, 310 CMR 7.00 et seq., and in accordance with the provisions of 310 CMR 7.00: Appendix C.

ISSUED TO ["the Permittee"]:

Exelon New Boston LLC
 9 Summer Street, P.O. Box 720
 Medway, Massachusetts 02053

INFORMATION RELIED UPON:

Application No. MBR-95-OPP-037R
 Transmittal No. W220507

FACILITY LOCATION:

Exelon New Boston Station
 776 Summer Street
 Boston, Massachusetts 02127

FACILITY IDENTIFYING NUMBERS:

AQ ID: 1190012
 FMF FAC NO.: 306548
 FMF RO NO.: 306549

NATURE OF BUSINESS:

Electrical Power Generation

STANDARD INDUSTRIAL CODE:

(SIC): 4911

NORTH AMERICAN INDUSTRY CLASSIFICATION SYSTEM:

(NAICS): 221112

RESPONSIBLE OFFICIAL:

Name: Paul Weeks
 Title: General Manager

FACILITY CONTACT PERSON:

Name: Jack Hughes
 Title: Plant Manager
 Phone: (508) 533-3919
 Fax: (508) 533-5364
 E-mail: jack.hughes@exeloncorp.com

This Operating Permit shall expire on March 30, 2015.

For MassDEP, Bureau of Waste Prevention

This final document copy is being provided to you electronically by the Department of Environmental Protection. A signed copy of this document is on file at the DEP office listed on the letterhead.

James E. Belsky
 Regional Permit Chief

March 30, 2010
 Date

TABLE OF CONTENTS

Section	Special Conditions for Operating Permit	Page No.
1	Permitted Activities and Description of Facility and Operations	3
2	Emission Unit Identification - Table 1	3
3	Identification of Exempt Activities - Table 2	4
4	Applicable Requirements	
	A. Emission Limits and Restrictions - Table 3	4
	B. Compliance Demonstration	
	- Monitoring/Testing Requirements - Table 4	6
	- Record Keeping Requirements - Table 5	7
	- Reporting Requirements - Table 6	8
	C. General Applicable Requirements	9
	D. Requirements Not Currently Applicable -Table 7	9
5	Special Terms and Conditions	10
6	Alternative Operating Scenarios	12
7	Emissions Trading	13
8	Compliance Schedule	13
Section	General Conditions for Operating Permit	Page No.
9	Fees	14
10	Compliance Certification	14
11	Noncompliance	15
12	Permit Shield	15
13	Enforcement	15
14	Permit Term	16
15	Permit Renewal	16
16	Reopening for Cause	16
17	Duty to Provide Information	16
18	Duty to Supplement	16
19	Transfer of Ownership or Operation	17
20	Property Rights	17
21	Inspection and Entry	17
22	Permit Availability	17
23	Severability Clause	17
24	Emergency Conditions	18
25	Permit Deviation	18
26	Operational Flexibility	19
27	Modifications	19
Section	Appeal Conditions for Operating Permit	20

SPECIAL CONDITIONS FOR OPERATING PERMIT

1. PERMITTED ACTIVITIES

In accordance with the provisions of 310 CMR 7.00: Appendix C and applicable rules and regulations, the Permittee is authorized to operate air emission units as shown in Table 1 and exempt and insignificant activities as described in 310 CMR 7.00: Appendix C(5)(h) and (i). The units described in Table 1 are subject to the terms and conditions shown in Sections 4, 5, and 6 and to other terms and conditions as specified in this Permit. Emissions from the exempt activities shall be included in the total facility emissions for the emission-based portion of the fee calculation described in 310 CMR 4.00 and this Permit.

DESCRIPTION OF FACILITY AND OPERATIONS

Exelon New Boston, LLC is an electrical power generation facility located at 776 Summer Street in Boston, Massachusetts. The facility operates one (1) simple cycle Combustion Turbine, noted as Emission Unit 5, used for generating power during periods of peak demand. The Combustion Turbine is rated at approximately 18.6 Megawatts output or 263 million British Thermal Units of energy input capacity per hour. Distillate fuel oil having sulfur content of 0.3 percent by weight or less is the only fuel of use. The Combustion Turbine is a Clean Air Interstate Rule Nitrogen Oxides Ozone Season Unit under the Massachusetts Clean Air Interstate Rule (310 CMR 7.32). The Combustion Turbine is also included in multi-facility NO_x emissions averaging with three (3) Combustion Turbines at the Permittee's Framingham Station and six (6) Combustion Turbines at the Permittee's West Medway Station for compliance with Reasonably Available Control Technology for Sources of NO_x (310 CMR 7.19). The Permittee has stated in the Operating Permit Application that the Exelon New Boston, LLC facility is not a major source of Hazardous Air Pollutants (HAP).

2. EMISSION UNIT IDENTIFICATION

The following emission unit (Table 1) is subject to and regulated by this Operating Permit:

Table 1			
EU#	DESCRIPTION OF EMISSION UNITS	EU DESIGN CAPACITY	POLLUTION CONTROL DEVICE (PCD)
EU5	Pratt & Whitney Model No. FT4-8 Combustion Turbine (Simple Cycle)	263 MMBTU per hour	None

Table 1 Key:

EU# = Emission Unit Number
 MMBTU = million British thermal units

3. IDENTIFICATION OF EXEMPT ACTIVITIES

The following are considered exempt activities in accordance with the criteria contained in 310 CMR 7.00: Appendix C(5)(h):

Table 2	
DESCRIPTION OF CURRENT EXEMPT ACTIVITIES	REASON
The list of current exempt activities is contained in the Operating Permit Application and shall be updated by the Permittee to reflect changes at the facility over the Permit term. An up-to-date copy of exempt activities list shall be kept on-site at the facility and a copy shall be submitted to MassDEP's Regional Office. Emissions from these activities shall be reported to MassDEP on the annual Source Registration/Emission Statement Form, pursuant to 310 CMR 7.12.	310 CMR 7.00: Appendix C(5)(h)

4. APPLICABLE REQUIREMENTS

A. EMISSION LIMITS AND RESTRICTIONS

The Permittee is subject to the emission limits/restrictions as contained in Table 3 below:

Table 3					
EU#	RESTRICTION	FUEL/RAW MATERIAL	POLLUTANT	EMISSION LIMIT/STANDARD	APPLICABLE REGULATION AND/OR APPROVAL NUMBER
EU5	NA	No. 2 Fuel Oil ≤ 0.3% S by weight	NO _x	≤ ALE _{NO_x} (1)	MBR-05-ECP-001 310 CMR 7.19(14) 310 CMR 7.00: Appendix B(4)
			CO	Not Applicable (2)	MBR-05-ECP-001 310 CMR 7.19(7)(a)4.
			S in Fuel	< 0.17 lb/MMBTU (3)	310 CMR 7.05(1)(a)2.
			NO _x	See "Special Terms and Conditions", Section 5(d)	310 CMR 7.32
			SO ₂	< 1.2 lb/MMBTU (3)	310 CMR 7.22(1)
Facility-Wide	NA	NA	Smoke	< No. 1 of Chart (4), except No. 1 to < No. 2 of Chart for ≤ 6 minutes during any one hour	310 CMR 7.06(1)(a)
			Opacity	< 20 percent, except > 20 to ≤ 40 percent for ≤ 2 minutes during any one hour	310 CMR 7.06(1)(b)

Table 3 Notes:

- See "Special Terms and Conditions", Section 5(c). In accordance with 310 CMR 7.19(7)(a)3., for stationary combustion turbines not using a continuous emissions monitoring system that satisfies the requirements of 310 CMR 7.19(13)(b) to determine compliance, compliance with the unit specific allowable NO_x emission rate for EU5 of 100 ppmvd corrected to fifteen (15) percent O₂ when firing oil, as stated in 310 CMR 7.19(7)(a)2.b., shall be based on a one-hour averaging time. In accordance with Approval MBR-05-ECP-001, compliance with this NO_x emission standard under 310 CMR 7.19(7)(a)2.b. shall be demonstrated by emissions averaging per the requirements of 310 CMR 7.19(14) and 310 CMR 7.00: Appendix B(4) by employing a 24 hour average of NO_x emissions from ten (10) stationary combustion turbines owned by the Permittee: EU5 at Exelon New Boston, LLC, three (3) turbines at Exelon Framingham, LLC located at Leland Street in Framingham, and six (6) turbines at Exelon West Medway, LLC located at 9 Summer Street in West Medway.
- In accordance with 310 CMR 7.19(7)(a)3., for stationary combustion turbines not using a continuous emissions monitoring system that satisfies the requirements of 310 CMR 7.19(13)(b) to determine compliance, compliance

with the unit specific allowable CO emission rate for EU5 of 100 ppmvd corrected to fifteen (15) percent O₂ when firing oil, as stated in 310 CMR 7.19(7)(a)2.c., shall be based on a one-hour averaging time. Notwithstanding this CO emission standard, as stated in 310 CMR 7.19(7)(a)2.c., of 100 ppmvd corrected to fifteen (15) percent O₂ when firing No. 2 Fuel Oil, MassDEP will allow the Permittee to operate EU5 at a higher CO emission standard, pursuant to Regulation 310 CMR 7.19(7)(a)4., provided that combustion conditions do not deteriorate as demonstrated by a decrease in the generator speed to exhaust temperature ratio when corrected to standard conditions, or by other means acceptable to MassDEP and the United States Environmental Protection Agency (EPA).

- 3 Compliance with 310 CMR 7.05 for the sulfur limit of fuel oil shall be deemed compliance with the SO₂ limit under the Massachusetts Acid Rain Law 310 CMR 7.22. Compliance is based on a calendar year averaging time. The provisions of 310 CMR 7.22 are State-Only Requirements.
- 4 Chart means the Ringelmann Scale for grading the density of smoke, as published by the United States Bureau of Mines and as referred to in the Bureau of Mines Information Circular No. 8333, or any smoke inspection guide approved by MassDEP.

Table 3 Key:

EU# = Emission Unit Number

No. = Number

lb/MMBTU = pounds per million British Thermal Units

ppmvd = parts per million by volume, dry basis

NO_x = Nitrogen Oxides

CO = Carbon Monoxide

S = Sulfur

SO₂ = Sulfur Dioxide

O₂ = Oxygen

% = percent

> = greater than

< = less than

< = less than or equal to

NA = Not Applicable

B. COMPLIANCE DEMONSTRATION

The Permittee is subject to the monitoring/testing, record keeping, and reporting requirements as contained in Tables 4, 5, and 6 below and 310 CMR 7.00: Appendix C (9) and (10), as well as the applicable requirements contained in Table 3:

Table 4	
EU#	MONITORING/TESTING REQUIREMENTS
EU5	<p>1. Conduct Emissions Compliance Testing (stack testing) annually prior to October 1, in accordance with Approval MBR-05-ECP-001, 310 CMR 7.13, 310 CMR 7.19(13)(c), and 40 CFR Part 60, Appendix A for NO_x and CO on the following Combustion Turbine Units involved in the Permittee's NO_x emission averaging bubble:</p> <ul style="list-style-type: none"> - one of the three (3) Rolls Royce Avon 1533-75L units located at Exelon Framingham, LLC not tested in the previous five (5) calendar years, and - the Exelon New Boston, LLC Pratt & Whitney FT4-8 unit, and - one of the six (6) Rolls Royce Avon 1533-77C units located at Exelon West Medway, LLC not tested in the previous five (5) calendar years and while burning No. 2 Fuel Oil, and - any Exelon West Medway, LLC Rolls Royce Avon 1533-77C unit burning Natural Gas, if the Permittee plans to burn Natural Gas in this unit during the time period leading up to the next scheduled stack testing of this unit and this unit has not been stack tested while burning Natural Gas in the previous five (5) calendar years, and - any other unit different from those tested above which has received major overhaul work since the last testing. <p>2. In accordance with 310 CMR 7.19(13)(d)3. and Approval MBR-05-ECP-001, monitor for each Combustion Turbine Unit, when in operation, on a daily basis: type(s) fuel burned, heat content of each fuel, total consumption of each fuel, total heating value of each fuel consumed, and actual hours of operation for each fuel burned. In accordance with Approval MBR-05-ECP-001, utilize this information to calculate the allowable NO_x emission bubble limitation (A_{E_{NO_x}}), the actual bubble NO_x emissions (A_{C_{E_{NO_x}}}), the difference between actual and allowable bubble NO_x emissions, and the quantity of Emission Reduction Credits (ERC_{NO_x}), both ozone (May 1 through September 30) and non-ozone season (October 1 through April 30), required to comply with 310 CMR 7.19. In accordance with Approval MBR-05-ECP-001, monitor that the amount of Emission Reduction Credits (ERCs) actually obtained includes five (5) percent more than the amount needed for compliance (See "Special Terms and Conditions", Section 5(c)). Fuel heat content information may be provided by fuel suppliers.</p> <p>3. In accordance with Approval MBR-05-ECP-001, monitor for each Combustion Turbine Unit, when in operation, on an hourly basis the generator speed, exhaust temperature, and generator speed to exhaust temperature ratio, corrected to standard conditions, to ensure that combustion conditions do not deteriorate as indicated by a decrease in the generator speed to exhaust temperature ratio when corrected to standard conditions, or by other means acceptable to MassDEP and EPA.</p> <p>4. Compliance with the Massachusetts Acid Rain Law 310 CMR 7.22 shall be demonstrated through monitoring for and compliance with 310 CMR 7.05, and monitoring as required by 310 CMR 7.19(13)(d)3. and Approval MBR-05-ECP-001.</p>

Table 4

EU#	MONITORING/TESTING REQUIREMENTS
EU5	<p>5. In accordance with 310 CMR 7.04(2)(a), no person shall cause, suffer, allow, or permit the burning of any grade oil or solid fuel in any fuel utilization facility having an energy input capacity rated by MassDEP equal to or greater than 40 MMBTU per hour, unless such facility is equipped with a smoke density sensing instrument and recorder which are properly maintained in an accurate operating condition, operates continuously and is equipped with an audible alarm to signal the need for combustion equipment adjustment or repair when the smoke density is equal to or greater than No. 1 of the Chart. Pursuant to MassDEP's authority through 310 CMR 7.00: Appendix C(9)(b)2., the monitoring of Opacity as determined in accordance with 40 CFR Part 60, Appendix A, Method 9 shall constitute compliance with this requirement. This method shall also apply to any detached plumes.</p> <p>6. Pursuant to MassDEP's authority through 310 CMR 7.00: Appendix C(9)(b)2., monitor sulfur content of each new shipment of fuel received. Compliance with the sulfur content of the fuel can be demonstrated through fuel analysis. The analysis of sulfur content of the fuel shall be in accordance with the applicable American Society for Testing Materials (ASTM) test methods or any other method approved by MassDEP and EPA. Fuel sulfur information may be provided by fuel suppliers.</p>
Facility-Wide	<p>7. In accordance with 310 CMR 7.13(1), any person owning, leasing, operating or controlling a facility for which MassDEP has determined that stack testing is necessary to ascertain compliance with MassDEP's regulations or design approval provisos shall cause such stack testing:</p> <p>(a) to be conducted by a person knowledgeable in stack testing,</p> <p>(b) to be conducted in accordance with procedures contained in a test protocol which has been approved by MassDEP, and</p> <p>(c) to be conducted in the presence of a representative of MassDEP when such is deemed necessary.</p> <p>In accordance with Approval MBR-05-ECP-001, conduct any other testing or testing methodology if and when requested by MassDEP or EPA.</p> <p>8. Monitor operations such that information may be compiled for the annual preparation of a Source Registration/Emission Statement Form as required by 310 CMR 7.12.</p>

Table 5

EU#	RECORD KEEPING REQUIREMENTS
EU5	<p>1. Maintain the test results of any Emissions Compliance Testing (stack testing) performed in accordance with Approval MBR-05-ECP-001, 310 CMR 7.13, 310 CMR 7.19(13)(c), and 40 CFR Part 60, Appendix A for NO_x and CO.</p> <p>2. In accordance with 310 CMR 7.19(13)(d)3. and Approval MBR-05-ECP-001, maintain records for each Combustion Turbine Unit, when in operation, on a daily basis: type(s) fuel burned, heat content of each fuel, total consumption of each fuel, total heating value of each fuel consumed, and actual hours of operation for each fuel burned. In accordance with Approval MBR-05-ECP-001, utilize this information to calculate and record the allowable NO_x emission bubble limitation (A_{E_{NO_x}}), the actual bubble NO_x emissions (A_{C_{E_{NO_x}}}), the difference between actual and allowable bubble NO_x emissions, and the quantity of Emission Reduction Credits (ERC_{NO_x}), both ozone and non-ozone season, required to comply with 310 CMR 7.19. In accordance with Approval MBR-05-ECP-001, record the amount of ERCs, both ozone (May 1 through September 30) and non-ozone season (October 1 through April 30), actually obtained. Said records shall also identify the source of ERCs obtained, including company name, emission unit and method of generation, date of generation, and the Transmittal Number of the application for certification of ERCs.</p>

Table 5	
EU#	RECORD KEEPING REQUIREMENTS
EU5	<p>3. In accordance with Approval MBR-05-ECP-001, maintain records for each Combustion Turbine Unit, when in operation, on an hourly basis of the generator speed, exhaust temperature, and generator speed to exhaust temperature ratio, corrected to standard conditions.</p> <p>4. Compliance with the Massachusetts Acid Rain Law 310 CMR 7.22 shall be demonstrated through record keeping for and compliance with fuel sulfur requirements, and record keeping as required by 310 CMR 7.19(13)(d)3. and Approval MBR-05-ECP-001.</p> <p>5. Consistent with the requirements of 310 CMR 7.04(2)(a) and pursuant to MassDEP's authority through 310 CMR 7.00: Appendix C(9)(b)2., maintain records of opacity determined in accordance with 40 CFR Part 60, Appendix A, Method 9. This method shall also apply to any detached plumes.</p> <p>6. In accordance with Approval MBR-05-ECP-001, maintain on-site, at all times, a copy of the Standard Operating and Maintenance Procedure (SOMP) for the subject emission unit.</p> <p>7. Pursuant to MassDEP's authority through 310 CMR 7.00: Appendix C(9)(b)2., maintain fuel analysis results used to demonstrate compliance with fuel sulfur content requirements.</p>
Facility-Wide	<p>8. Consistent with the requirements of Approval MBR-05-ECP-001, maintain the test results of any other testing or testing methodology required by MassDEP or EPA.</p> <p>9. Maintain records for the annual preparation of a Source Registration/Emission Statement Form as required by 310 CMR 7.12.</p> <p>10. Keep copies of Source Registration/Emission Statement Forms submitted annually to MassDEP as required per 310 CMR 7.12(3)(b).</p> <p>11. In accordance with 310 CMR 7.00: Appendix C(10)(b), maintain records of all monitoring data and supporting information required by this Operating Permit on site for five (5) years from the date of the monitoring sample, measurement, report or initial Operating Permit Application.</p>

Table 6	
EU#	REPORTING REQUIREMENTS
EU5	<p>1. In accordance with 310 CMR 7.19(13)(c) and Approval MBR-05-ECP-001, on an annual basis:</p> <p>(a) submit a pretest protocol for the required Emissions Compliance Test (stack test) for review and written MassDEP approval at least 60 days prior to the anticipated date of testing,</p> <p>(b) include in the pretest protocol a description of sampling point locations, sampling equipment, sampling and analytical procedures, and the operating conditions for the required Emissions Compliance Testing, and</p> <p>(c) submit the Emissions Compliance Testing report for review and written MassDEP approval within 60 days of the completion of the Emissions Compliance Testing.</p>

Table 6	
EU#	REPORTING REQUIREMENTS
EU5	<p>2. In accordance with Approval MBR-05-ECP-001, submit to this Regional Office, on a quarterly basis, a report that shows, for each Combustion Turbine Unit: 1) monthly heat input, in MMBTU, from each type of fuel burned; 2) monthly quantity of AcE_{NOx}, in pounds; and, 3) specific NO_x emission rate(s) used to calculate the monthly quantity of AcE_{NOx}. In addition, the report must contain the total quantities of 1) AcE_{NOx}, in pounds, 2) AlE_{NOx}, in pounds, and, 3) ERC_{NOx}, in pounds, for the Permittee's NO_x emission averaging bubble. The Permittee shall also report whether or not the NO_x emission averaging bubble was in compliance with 310 CMR 7.19. This submittal must be made for each calendar quarter by the thirtieth (30th) day of April, July, October, and January covering the previous calendar periods of January through March, April through June, July through September, and October through December, respectively. Each report submitted on January 30 of each calendar year, shall also contain: 1) the total amounts of ozone season (May 1 through September 30) and non-ozone season (October 1 through April 30) ERCs that were necessary for compliance with 310 CMR 7.19 in the previous calendar year, and 2) the identity of the source from which ERCs were obtained, including company name, emission unit and method of generation, date of generation, and the Transmittal Number of the application for certification of ERCs.</p> <p>3. In accordance with Approval MBR-05-ECP-001, updated versions of the Standard Operating and Maintenance Procedures (SOMP) shall be submitted to MassDEP. MassDEP must approve of significant changes to the SOMP prior to the change becoming effective. The updated SOMP shall supersede prior versions of the SOMP.</p> <p>4. In accordance with 310 CMR 7.19(13)(d)9., submit compliance records within ten (10) days of written request by MassDEP or EPA.</p>
Facility-Wide	<p>5. Report in accordance with the requirements of 310 CMR 7.71. (State Only)</p> <p>6. In accordance with 310 CMR 7.00: Appendix C(10)(d) and consistent with Approval MBR-05-ECP-001, submit, upon request, the test results of any other testing or testing methodology required by MassDEP or EPA.</p> <p>7. Submit a Source Registration/Emission Statement Form to MassDEP on an annual basis as required by 310 CMR 7.12.</p> <p>8. Submit by January 30 and July 30 for the previous six months respectively, a summary of all monitoring data and related supporting information to MassDEP as required by 310 CMR 7.00: Appendix C(10)(c).</p> <p>9. Submit Annual Compliance report to MassDEP and EPA by January 30 of each year and as required by General Condition 10 of this Permit.</p> <p>10. Promptly report to MassDEP all instances of deviations from Permit requirements by telephone or fax, within three days of discovery of such deviation, as provided in 310 CMR 7.00: Appendix C(10)(f) and General Condition 25.</p> <p>11. All required reports must be certified by a responsible official as provided in 310 CMR 7.00: Appendix C(10)(h).</p>

C. GENERAL APPLICABLE REQUIREMENTS

The Permittee shall comply with all generally applicable requirements contained in 310 CMR 7.00 et. seq. and 310 CMR 8.00 et. seq., when subject.

D. REQUIREMENTS NOT CURRENTLY APPLICABLE

The Permittee is currently not subject to the following requirements:

Table 7	
REGULATION & TITLE	REASON
310 CMR 7.16: Reduction of Single Occupant Commuter Vehicle Use	Not more than 250 commuters
310 CMR 7.27: NO_x Allowance	Superseded by 310 CMR 7.28 and 7.32

Table 7	
REGULATION & TITLE	REASON
Program	
310 CMR 7.28: NO _x Allowance Trading Program	As of January 1, 2009, this regulation is no longer applicable; it was superseded by 310 CMR 7.32
40 CFR Part 64: Compliance Assurance Monitoring	No Air Pollution Control Device on subject unit
42 U.S.C. 7401, §112(r): Prevention of Accidental Releases	Not more than a threshold quantity of a regulated substance

5. SPECIAL TERMS AND CONDITIONS

The Permittee is subject to the following special provisions that are not contained in Table 3, 4, 5, and 6:

- a) Per data as supplied through the Permittee's Operating Permit Application (MBR-95-OPP-037, Transmittal No. 108002), EU5 shall continue to emit products of combustion through a stack with the following parameters:

EMISSION UNIT	STACK HEIGHT (Feet)	STACK EXIT DIAMETER (Feet)	STACK MATERIAL
EU5	120	10	Metal

- b) As stated within Approval MBR-03-COM-009, Approval MBR-05-ECP-001, Approval MBR-92-COM-024, Approval MBR-89-COM-013, Approval MBR-84-COM-052, and Approval MBR-83-COM-029, that should any nuisance condition(s) occur as a result of the operation of the facility, then appropriate steps shall immediately be taken to abate said nuisance condition(s). (State Only, 310 CMR 7.01(1))
- c) In accordance with Approval MBR-05-ECP-001, EU5 is included in the Permittee's multi-facility NO_x emission averaging "bubble" involving ten (10) Combustion Turbine Units located at the following three facilities owned by the Permittee:

Exelon New Boston LLC, 776 Summer Street, South Boston - one Combustion Turbine

Exelon Framingham LLC, Leland Street, Framingham - three Combustion Turbines

Exelon West Medway LLC, 9 Summer Street, West Medway - six Combustion Turbines

The Permittee's multi-facility NO_x emission averaging bubble shall maintain continuous compliance with an allowable NO_x emission limitation (ALE_{NOx}), in pounds, based on the weighted average equation given below:

$$ALE_{NOx} = [(0.389) \times (B_2)] + [(0.23985) \times (B_{NG})] + ERC_{NOx}$$

where:

B_2 = heat input in MMBTU of Combustion Turbine Units 1 through 10, inclusive, when burning No. 2 Fuel Oil

B_{NG} = heat input in MMBTU of Combustion Turbine Units 1 through 6, inclusive, when burning Natural Gas

ERC_{NOx} = federally enforceable NO_x Emission Reduction Credits in pounds certified by MassDEP under 310 CMR 7.00 Appendix B(3)

The Permittee's Combustion Turbine Units 1 through 10 involved in the NO_x emission averaging bubble are described below:

UNIT	UNIT DESCRIPTION	MANUFACTURER & MODEL NO.	MAXIMUM HEAT INPUT RATING (MMBTU/hr)+	FUEL(S) COMBUSTED & MAXIMUM SULFUR(S) CONTENT BY WEIGHT
1 (J1T1) W. Medway	Combustion Turbine	Rolls Royce Avon 1533-77C	392	No. 2 Fuel Oil 0.3% S Natural Gas
2 (J1T2) W. Medway	Combustion Turbine	Rolls Royce Avon 1533-77C	392	No. 2 Fuel Oil 0.3% S Natural Gas
3 (J2T1) W. Medway	Combustion Turbine	Rolls Royce Avon 1533-77C	392	No. 2 Fuel Oil 0.3% S Natural Gas
4 (J2T2) W. Medway	Combustion Turbine	Rolls Royce Avon 1533-77C	392	No. 2 Fuel Oil 0.3% S Natural Gas
5 (J3T1) W. Medway	Combustion Turbine	Rolls Royce Avon 1533-77C	392	No. 2 Fuel Oil 0.3% S Natural Gas
6 (J3T2) W. Medway	Combustion Turbine	Rolls Royce Avon 1533-77C	392	No. 2 Fuel Oil 0.3% S Natural Gas
7 (FJ-1) Framingham	Combustion Turbine	Rolls Royce Avon 1533-75L	186	No. 2 Fuel Oil 0.3% S
8 (FJ-2) Framingham	Combustion Turbine	Rolls Royce Avon 1533-75L	186	No. 2 Fuel Oil 0.3% S
9 (FJ-3) Framingham	Combustion Turbine	Rolls Royce Avon 1533-75L	186	No. 2 Fuel Oil 0.3% S
10 (NBJ-1) Boston	Combustion Turbine	Pratt & Whitney FT4-8	263	No. 2 Fuel Oil 0.3% S

+ MMBTU/hr = million British Thermal Units per hour
 No. = Number
 S = Sulfur
 % = Percent

The actual NO_x emissions (AcE_{NOx}), in pounds, for the bubble shall be calculated according to the following equation:

$$AcE_{NOx} = [(Ac1_{\#2 OIL} \times B1_{\#2 OIL}) + (Ac2_{\#2 OIL} \times B2_{\#2 OIL}) + \dots + (Ac10_{\#2 OIL} \times B10_{\#2 OIL})] + [(Ac1_{NG} \times B1_{NG}) + (Ac2_{NG} \times B2_{NG}) + (\dots) + (Ac6_{NG} \times B6_{NG})]$$

where:

Ac1_{#2 OIL}, ..., Ac10_{#2 OIL} = unit specific NO_x emission rates of Combustion Turbine Units 1 through 10 in pounds/MMBTU as determined from the most recent stack testing performed while burning No. 2 Fuel Oil

B1_{#2 OIL}, ..., B10_{#2 OIL} = heat inputs in MMBTU of Combustion Turbine Units 1 through 10 when burning No. 2 Fuel Oil

Ac1_{NG}, ..., Ac6_{NG} = unit specific NO_x emission rates of Combustion Turbine Units 1 through 6 in pounds/MMBTU as determined from the most recent stack testing performed while burning Natural Gas

B1_{NG}, ..., B6_{NG} = heat inputs in MMBTU of Combustion

Turbine Units 1 through 6 when burning
Natural Gas

Final determination of the amount of ERCs necessary for the subject ten Combustion Turbine Units to comply with NO_x RACT shall be calculated utilizing a compliance assurance multiplier of 1.10 consistent with 310 CMR 7.19(13)(a)3.b. and according to the following formula:

$$ERC_{NOx} = (AcE_{NOx} - AlE_{NOx}) \times 1.10$$

The amount of ERCs calculated by the above formula shall be rounded to the nearest whole number. In accordance with 310 CMR 7.00: Appendix B(4)(a)2., the NO_x emissions from the ten Combustion Turbine Units in the emission averaging bubble shall be averaged over a 24 hour period or daily.

The Permittee shall comply with 310 CMR 7.00: Appendix B(3)(e) regarding the withdrawal, transfer, and use of ERCs. In accordance with 310 CMR 7.00: Appendix B(3)(e)2., the Permittee shall obtain an amount of credit equal to five (5) percent more than the amount needed for compliance calculation. Therefore, the amount of ERCs obtained shall be calculated according to the following formula and rounded to the nearest whole number:

$$ERC_{NOx} = (AcE_{NOx} - AlE_{NOx})(1.10)(1.05)$$

The Permittee shall calculate the total amounts of ozone season (May 1 through September 30) and non-ozone season (October 1 through April 30) ERCs that are necessary for compliance with 310 CMR 7.19, and obtain and use (or retire) ERCs in accordance with the provisions of 310 CMR 7.00: Appendix B(3)(e)8. In accordance with 310 CMR 7.00: Appendix B(3)(e)8., NO_x ERCs generated during the ozone control period of May 1 through September 30 can be used for compliance at any time during the year. However, NO_x ERCs generated during the non-ozone control period of October 1 through April 30 shall only be used for compliance in the same season as generated (October 1 through April 30).

In accordance with 310 CMR 7.00: Appendix B(4)(f)2., this NO_x emission bubble shall be in effect until the expiration date of this Operating Permit. At least nine months prior to the expiration of the bubble, Exelon shall reapply for permission to bubble.

- d) Massachusetts Clean Air Interstate Rule, 310 CMR 7.32

The owner/operator of Exelon New Boston Station is subject to and shall comply with the Massachusetts Clean Air Interstate Rule (CAIR), 310 CMR 7.32, and has submitted a CAIR Emission Control Plan Application pursuant to 310 CMR 7.32(3).

- e) In accordance with Approval MBR-92-COM-024 and Approval MBR-89-COM-013 the Permittee shall comply with all noise regulations and guidelines of the City of Boston's Air Pollution Control Commission. (State Only)
- f) In accordance with Approval MBR-92-COM-024 and Approval MBR-89-COM-013, the Permittee shall comply with all applicable requirements of the Consent Order and Notice of Noncompliance with an effective date of September 24, 1991, as amended by the Administrative Consent Order effective September 1, 1992. (State Only)
- g) The Permittee is subject to, and has stated in their Operating Permit Application (MBR-95-OPP-037, Transmittal No. 108002), that they are in compliance with the requirements of 40 CFR Part 82: Protection of Stratospheric Ozone. These requirements are applicable to this facility and EPA enforces these requirements.

6. ALTERNATIVE OPERATING SCENARIOS

The Permittee did not request alternative operating scenarios in its Operating Permit Application.

7. EMISSIONS TRADING

a) Intra-facility emissions trading

The Permittee is currently authorized to engage in emissions trading under the following federal and state regulatory programs:

310 CMR 7.22 - SO₂ Emissions Reductions for the Purpose of Reducing Acid Rain;

310 CMR 7.32 - Massachusetts Clean Air Interstate Rule;

310 CMR 7.00, Appendix A - Emission Offsets; and

310 CMR 7.00, Appendix B - Emission Reduction Credits.

Pursuant to 310 CMR 7.00: Appendix C(7)(b), emissions trades, provided for in this Permit, may be implemented provided the Permittee notifies EPA and MassDEP at least fifteen (15) days in advance of the FINAL changes and the Permittee provides the information required in 310 CMR 7.00: Appendix C(7)(b)3.

Any intra-facility change that does not qualify pursuant to 310 CMR 7.00: Appendix C(7)(b)2. is required to be submitted to MassDEP pursuant to 310 CMR 7.00: Appendix B.

b) Inter-facility emissions trading

The Permittee is currently authorized to engage in emissions trading under the following federal and state regulatory programs:

310 CMR 7.22 - SO₂ Emissions Reductions for the Purpose of Reducing Acid Rain;

310 CMR 7.32 - Massachusetts Clean Air Interstate Rule;

310 CMR 7.00, Appendix A - Emission Offsets; and

310 CMR 7.00, Appendix B - Emission Reduction Credits.

The Permittee has requested inter-facility emissions trading as provided for in Approval MBR-05-ECP-001 and Section 4 and Section 5 of this Operating Permit.

All increases in emissions due to emissions trading, must be authorized under the applicable requirements of 310 CMR 7.00: Appendix B (the "Emissions Trading Program") and 42 U.S.C. §7401 et seq. (the "Act"), and as provided for in this Permit.

8. COMPLIANCE SCHEDULE

The Permittee has indicated that the facility is in compliance and shall remain in compliance with the applicable requirements contained in Sections 4 and 5. In addition, the Permittee shall comply with any applicable requirements that become effective during the Permit term.

GENERAL CONDITIONS FOR OPERATING PERMIT

9. FEES

The Permittee has paid the Permit Application processing fee and shall pay the annual compliance fee in accordance with the fee schedule pursuant to 310 CMR 4.00.

10. COMPLIANCE CERTIFICATION

All documents submitted to MassDEP shall contain certification by the responsible official of truth, accuracy, and completeness. Such certification shall be in compliance with 310 CMR 7.01(2) and contain the following language:

"I certify that I have personally examined the foregoing and am familiar with the information contained in this document and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including possible fines and imprisonment."

MassDEP has made available to the Permittee via MassDEP's web site, <http://www.mass.gov/dep/air/approvals/aqannrp.doc> an "Operating Permit Reporting Kit". The "Operating Permit Reporting Kit" contains instructions, and the Annual Compliance Report and Certification and the Semi-Annual Monitoring Summary Report and Certification.

a. Annual Compliance Report and Certification

The Responsible Official shall certify, annually for the calendar year, that the facility is in compliance with the requirements of this Permit. The report shall be postmarked or delivered by January 30 to MassDEP and to the Regional Administrator, United States Environmental Protection Agency - New England Region. The report shall be submitted in compliance with the submission requirements below.

The compliance certification and report shall describe:

- i. the terms and conditions of the Permit that are the basis of the certification;
- ii. the current compliance status and whether compliance was continuous or intermittent during the reporting period;
- iii. the methods used for determining compliance, including a description of the monitoring, record keeping, and reporting requirements and test methods; and
- iv. any additional information required by MassDEP to determine the compliance status of the source.

b. Semi-Annual Monitoring Summary Report and Certification

The Responsible Official shall certify, semi-annually on the calendar year, that the facility is in compliance with the requirements of this Permit. The report shall be postmarked or delivered by January 30 and July 30 to MassDEP. The report shall be submitted in compliance with the submission requirements below.

The compliance certification and report shall describe:

- i. the terms and conditions of the Permit that are the basis of the certification;
- ii. the current compliance status during the reporting period;
- iii. the methods used for determining compliance, including a description

- of the monitoring, record keeping, and reporting requirements and test methods;
- iv. whether there were any deviations during the reporting period;
 - v. if there are any outstanding deviations at the time of reporting, and the Corrective Action Plan to remedy said deviation;
 - vi. whether deviations in the reporting period were previously reported;
 - vii. if there are any outstanding deviations at the time of reporting, the FINAL date of return to compliance;
 - viii. if the deviations in the reporting period have returned to compliance and date of such return to compliance; and
 - ix. any additional information required by MassDEP to determine the compliance status of the source.

11. NONCOMPLIANCE

Any noncompliance with a Permit condition constitutes a violation of 310 CMR 7.00: Appendix C and the Act, and is grounds for enforcement action, for Permit termination or revocation, or for denial of an Operating Permit Renewal Application by MassDEP and/or EPA. Noncompliance may also be grounds for assessment of administrative or civil penalties under M.G.L. c.21A, §16 and 310 CMR 5.00; and civil penalties under M.G.L. c.111, §142A and 142B. This Permit does not relieve the Permittee from the obligation to comply with any other provisions of 310 CMR 7.00 or the Act, or to obtain any other necessary authorizations from other governmental agencies, or to comply with all other applicable Federal, State, or Local rules and regulations, not addressed in this Permit.

12. PERMIT SHIELD

(a) This facility has a Permit shield provided that it operates in compliance with the terms and conditions of this Permit. Compliance with the terms and conditions of this Permit shall be deemed compliance with all applicable requirements specifically identified in Sections 4, 5, 6, and 7 for the emission units as described in the Permittee's Application and as identified in this Permit.

Where there is a conflict between the terms and conditions of this Permit and any earlier Approval or Permit, the terms and conditions of this Permit control.

(b) MassDEP has determined that the Permittee is not currently subject to the requirements listed in Section 4, Part D, Table 7.

(c) Nothing in this Permit shall alter or affect the following:

- i. the liability of the source for any violation of applicable requirements prior to or at the time of Permit issuance.
- ii. the applicable requirements of the Acid Rain Program, consistent with 42 U.S.C. §7401, §408(a); or
- iii. the ability of EPA to obtain information under 42 U.S.C. §7401, §114 or §303 of the Act.

13. ENFORCEMENT

The following regulations found at 310 CMR 7.02(8)(h) Table 6 for wood fuel, 7.04(9), 7.05(8), 7.09 (odor), 7.10 (noise), 7.18(1)(b), 7.21, 7.22, 7.70 and any condition(s) designated as "state only" are not federally enforceable because they are not required under the Act or under any of its applicable requirements. These regulations and conditions are not enforceable by the EPA. Citizens may seek equitable or declaratory relief to enforce these regulations and conditions pursuant to Massachusetts General Law Chapter 214, Section 7A.

All other terms and conditions contained in this Permit, including any provisions designed to limit a facility's potential to emit, are enforceable by MassDEP, EPA, and citizens as defined under the Act.

A Permittee shall not claim as a defense in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Permit.

14. PERMIT TERM

This Permit shall expire on the date specified on the cover page of this Permit, which shall not be later than the date five (5) years after issuance of this Permit.

Permit expiration terminates the Permittee's right to operate the facility's emission units, control equipment or associated equipment covered by this Permit, unless a timely and complete Renewal Application is submitted at least 6 months before the expiration date.

15. PERMIT RENEWAL

Upon MassDEP's receipt of a complete and timely Application for renewal, this facility may continue to operate subject to final action by MassDEP on the Renewal Application.

In the event MassDEP has not taken final action on the Operating Permit Renewal Application prior to this Permit's expiration date, this Permit shall remain in effect until MassDEP takes final action on the Renewal Application, provided that a timely and complete Renewal Application has been submitted in accordance with 310 CMR 7.00: Appendix C(13).

16. REOPENING FOR CAUSE

This Permit may be modified, revoked, reopened, and reissued, or terminated for cause by MassDEP and/or EPA. The responsible official of the facility may request that MassDEP terminate the facility's Operating Permit for cause. MassDEP will reopen and amend this Permit in accordance with the conditions and procedures under 310 CMR 7.00: Appendix C(14).

The filing of a request by the Permittee for an Operating Permit revision, revocation and reissuance, or termination, or a notification of a planned change or anticipated noncompliance does not stay any Operating Permit condition.

17. DUTY TO PROVIDE INFORMATION

Upon MassDEP's written request, the Permittee shall furnish, within a reasonable time, any information necessary for determining whether cause exists for modifying, revoking and reissuing, or terminating the Permit, or to determine compliance with the Permit. Upon request, the Permittee shall furnish to MassDEP copies of records that the Permittee is required to retain by this Permit.

18. DUTY TO SUPPLEMENT

The Permittee, upon becoming aware that any relevant facts were omitted or that incorrect information was submitted in the Permit Application, shall promptly submit such supplementary facts or corrected information. The Permittee shall also provide additional information as necessary to address

any requirements that become applicable to the facility after the date a complete Renewal Application was submitted but prior to release of a draft Permit.

The Permittee shall promptly, on discovery, report to MassDEP a material error or omission in any records, reports, plans, or other documents previously provided to MassDEP.

19. TRANSFER OF OWNERSHIP OR OPERATION

This Permit is not transferable by the Permittee unless done in accordance with 310 CMR 7.00: Appendix C(8)(a). A change in ownership or operation control is considered an administrative Permit amendment if no other change in the Permit is necessary and provided that a written agreement containing a specific date for transfer of Permit responsibility, coverage and liability between current and new Permittee, has been submitted to MassDEP.

20. PROPERTY RIGHTS

This Permit does not convey any property rights of any sort, or any exclusive privilege.

21. INSPECTION AND ENTRY

Upon presentation of credentials and other documents as may be required by law, the Permittee shall allow authorized representatives of MassDEP and EPA to perform the following, as per 310 CMR 7.00: Appendix C(3)(g)12.:

(a) enter upon the Permittee's premises where an Operating Permit source activity is located or emissions-related activity is conducted, or where records must be kept under the conditions of this Permit;

(b) have access to and copy, at reasonable times, any records that must be kept under the conditions of this Permit;

(c) inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Permit; and

(d) sample or monitor at reasonable times any substances or parameters for the purpose of assuring compliance with the Operating Permit or applicable requirements.

22. PERMIT AVAILABILITY

The Permittee shall have available at the facility, at all times, a copy of the materials listed under 310 CMR 7.00: Appendix C(10)(e) and shall provide a copy of the Permit, including any amendments or attachments thereto, upon request by MassDEP or EPA.

23. SEVERABILITY CLAUSE

The provisions of this Permit are severable, and if any provision of this Permit, or the application of any provision of this Permit to any circumstances is held invalid, the application of such provision to other circumstances, and the remainder of this Permit, shall not be affected thereby.

24. EMERGENCY CONDITIONS

The Permittee shall be shielded from enforcement action brought for noncompliance with technology based¹ emission limitations specified in this Permit as a result of an emergency². In order to use emergency as an affirmative defense to an action brought for noncompliance, the Permittee shall demonstrate the affirmative defense through properly signed, contemporaneous operating logs, or other relevant evidence that:

- (a) an emergency occurred and that the Permittee can identify the cause(s) of the emergency;
- (b) the permitted facility was at the time being properly operated;
- (c) during the period of the emergency, the Permittee took all reasonable steps as expeditiously as possible, to minimize levels of emissions that exceeded the emissions standards, or other requirements in this Permit; and
- (d) the Permittee submitted notice of the emergency to MassDEP within two (2) business days of the time when emission limitations were exceeded due to the emergency. This notice must contain a description of the emergency, any steps taken to mitigate emission, and corrective actions taken.

If an emergency episode requires immediate notification to the Bureau of Waste Site Cleanup/Emergency Response, immediate notification to the appropriate parties should be made as required by law.

25. PERMIT DEVIATION

Deviations are instances where any Permit condition is violated and not reported as an emergency pursuant to Section 24 of this Permit. Reporting a Permit deviation is not an affirmative defense for action brought for noncompliance. Any reporting requirements listed in Table 6 of this Operating Permit shall supercede the following deviation reporting requirements, if applicable.

The Permittee shall report to MassDEP's Regional Bureau of Waste Prevention the following deviations from Permit requirements, by telephone or fax, within three (3) days of discovery of such deviation:

- Unpermitted pollutant releases, excess emissions or opacity exceedances measured directly by CEMS/COMS, by EPA reference methods or by other credible evidence, which are ten percent (10%) or more above the emission limit.
- Exceedances of parameter limits established by your Operating Permit or other Approvals, where the parameter limit is identified by the Permit or Approval as surrogate for an emission limit.

¹ Technology based emission limits are those established on the basis of emission reductions achievable with various control measures or process changes (e.g., a new source performance standard) rather than those established to attain health based air quality standards.

² An "emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the source, including acts of God, which situation would require immediate corrective action to restore normal operation, and that causes the source to exceed a technology based limitation under the Permit, due to unavoidable increases in emissions attributable to the emergency. An emergency shall not include noncompliance to the extent caused by improperly designed equipment, lack of preventative maintenance, careless or improper operations, operator error or decision to keep operating despite knowledge of any of these things.

- Exceedances of Permit operational limitations directly correlated to excess emissions.
- Failure to capture valid emissions or opacity monitoring data or to maintain monitoring equipment as required by statutes, regulations, your Operating Permit, or other Approvals.
- Failure to perform QA/QC measures as required by your Operating Permit or other Approvals for instruments that directly monitor compliance.

For all other deviations, three (3) day notification is waived and is satisfied by the documentation required in the subsequent Semi-Annual Monitoring Summary and Certification. Instructions and forms for reporting deviations are found in MassDEP's Bureau of Waste Prevention Air Operating Permit Reporting Kit, which is available via MassDEP's web site, <http://www.mass.gov/dep/air/approvals/aqannrp.doc> This report shall include the deviation, including those attributable to upset conditions as defined in the Permit, the probable cause of such deviations, and the corrective actions or preventative measures taken.

Deviations that were reported by telephone or fax within 3 days of discovery, said deviations shall also be submitted in writing via the Operating Permit Deviation Report to the regional Bureau of Waste Prevention within ten (10) days of discovery. For deviations that do not require 3 day verbal notification, follow-up reporting requirements are satisfied by the documentation required in the aforementioned Semi-Annual Monitoring Summary and Certification.

26. OPERATIONAL FLEXIBILITY

The Permittee is allowed to make changes at the facility consistent with 42 U.S.C. §7401, §502(b)(10) not specifically prohibited by the Permit and in compliance with all applicable requirements provided the Permittee gives the EPA and MassDEP written notice fifteen days prior to said change; notification is not required for exempt activities listed at 310 CMR 7.00: Appendix C(5)(h) and (i). The notice shall comply with the requirements stated at 310 CMR 7.00: Appendix C(7)(a) and will be appended to the facility's Permit. The Permit shield allowed for at 310 CMR 7.00: Appendix C(12) shall not apply to these changes.

27. MODIFICATIONS

(a) Administrative Amendments - The Permittee may make changes at the facility which are considered administrative amendments pursuant to 310 CMR 7.00: Appendix C(8)(a)1., provided they comply with the requirements established at 310 CMR 7.00: Appendix C(8)(b).

(b) Minor Modifications - The Permittee may make changes at the facility which are considered minor modifications pursuant to 310 CMR 7.00: Appendix C(8)(a)2., provided they comply with the requirements established at 310 CMR 7.00: Appendix C(8)(d).

(c) Significant Modifications - The Permittee may make changes at the facility which are considered significant modifications pursuant to 310 CMR 7.00: Appendix C(8)(a)3., provided they comply with the requirements established at 310 CMR 7.00: Appendix C(8)(c).

(d) No Permit revision shall be required, under any approved economic incentives program, marketable Permits program, emission trading program and other similar programs or processes, for changes that are provided in this Operating Permit. A revision to the Permit is not required for increases in emissions that are authorized by allowances acquired pursuant to the Acid Rain Program under Title IV of the Act, provided that such increases do not require an Operating Permit revision under any other applicable requirement.

APPEAL CONDITIONS FOR OPERATING PERMIT

This Permit is an action of MassDEP. If you are aggrieved by this action, you may request an adjudicatory hearing within 21 days of issuance of this Permit. In addition, any person who participates in any public participation process required by the Federal Clean Air Act, 42 U.S.C. §7401, §502(b)(6) or under 310 CMR 7.00: Appendix C(6), with respect to MassDEP's final action on Operating Permits governing air emissions, and who has standing to sue with respect to the matter pursuant to federal constitutional law, may initiate an adjudicatory hearing pursuant to Chapter 30A, and may obtain judicial review, pursuant to Chapter 30A, of a final decision therein.

If an adjudicatory hearing is requested, the facility must continue to comply with all existing federal and state applicable requirements to which the facility is currently subject, until a final decision is issued in the case or the appeal is withdrawn. During this period, the Application shield shall remain in effect, and the facility shall not be in violation of the Act for operating without a Permit.

Under 310 CMR 1.01(6)(b), the request must state clearly and concisely the facts which are the grounds for the request, and the relief sought. Additionally, the request must state why the Permit is not consistent with applicable laws and regulations.

The hearing request along with a valid check payable to The Commonwealth of Massachusetts in the amount of one hundred dollars (\$100.00) must be mailed to:

The Commonwealth of Massachusetts
Department of Environmental Protection (MassDEP)
P.O. Box 4062
Boston, MA 02211

The request will be dismissed if the filing fee is not paid unless the appellant is exempt or granted a waiver as described below.

The filing fee is not required if the appellant is a city or town (or municipal agency) county, or district of the Commonwealth of Massachusetts, or a municipal housing authority.

MassDEP may waive the adjudicatory hearing-filing fee for a person who shows that paying the fee will create an undue financial hardship. A person seeking a waiver must file, together with the hearing request as provided above, an affidavit setting forth the facts believed to support the claim of undue financial hardship.