

# Guidelines for the Design, Construction, Operation, and Maintenance of Small Wastewater Treatment Facilities with Land Disposal



Commonwealth of Massachusetts  
Department of Environmental Protection  
Division of Watershed Permitting  
Revised November 2014



## TABLE OF CONTENTS

	<u>PAGE</u>
LIST OF TABLES & FIGURES	3
INTRODUCTION	4
ACKNOWLEDGEMENTS	6
I LAWS AND REGULATIONS	7
II FILING FOR A GROUNDWATER PERMIT	15
III REQUIRED SUBMITTALS	20
IV CALCULATION OF WASTEWATER FLOWS	34
V INFILTRATION/INFLOW & SEWER SYSTEM MAINTENANCE	37
VI SITE EVALUATION & SITING CRITERIA	38
VII EFFLUENT DISPOSAL	42
VIII GENERAL REQUIREMENTS FOR TREATMENT PLANTS	52
<i>A. TREATMENT REQUIREMENTS</i>	52
<i>B. GENERAL WWTF REQUIREMENTS</i>	54
IX DESIGN CRITERIA	62
<i>A. COLLECTION SYSTEM</i>	62
<i>B. PUMPING STATIONS</i>	69
<i>C. FLOW EQUALIZATION</i>	72
<i>D. PRELIMINARY AND PRIMARY TREATMENT</i>	73
<i>E. SECONDARY TREATMENT</i>	77
<i>F. SECONDARY CLARIFICATION</i>	86
<i>G. NITROGEN &amp; PHOSPHORUS REMOVAL</i>	88
<i>H. FILTRATION</i>	95
<i>I. OTHER ADVANCED TREATMENT PROCESSES</i>	97
<i>J. DISINFECTION</i>	100
<i>K. RESIDUALS MANAGEMENT/FOG REQUIREMENTS/     GREASE TRAPS</i>	104
<i>L. INSTRUMENTATION</i>	107
<i>M. PROPRIETARY TECHNOLOGIES</i>	112
<i>N. SCHOOLS &amp; OTHER SEASONAL FACILITIES</i>	113
X OPERATION & MAINTENANCE PLAN	115
XI GROUNDWATER PERMIT REQUIREMENTS	124
XII CERTIFICATION & PERFORMANCE GUARANTEES	126

## **APPENDIX**

A – CERTIFICATION STATEMENT

B – INFILTRATION RATE AND INFILTRATION RATE TEST

C – DIVISION OF WATER SUPPLY POLICY BRP/DWM/WS/P03-1: REVIEW OF SEWER LINE/WATER SUPPLY PROTECTION

D – SUGGESTED MAINTENANCE REQUIREMENTS

### **LIST OF TABLES**

<b><u>TABLE TITLE</u></b>	<b><u>PAGE</u></b>
1 REGULATION SUMMARY	12
2 MINIMUM ACCEPTABLE SEPARATION DISTANCES	41
3 DESIGN LOADING RATE –GALLONS PER DAY PER SQUARE FOOT (GPD/SF)	45
4 SUMMARY OF PRIMARY CLARIFIER DESIGN CONSIDERATIONS	76
5 SUMMARY OF ROTATING BIOLOGICAL CONTACTOR CONSIDERATIONS	80
6 AERATION TANK CAPACITIES AND PERMISSIBLE LOADINGS	81
7 ALLOWABLE LOADING RATES FOR SECONDARY CLARIFIERS AT DESIGN FLOW	88
8 SECONDARY CLARIFIER DESIGN CONSIDERATIONS	75
B-1 BASIC INFILTRATION RATES FOR VARIOUS SOIL TYPES	112

### **LIST OF FIGURES**

<b><u>FIGURE</u></b>	<b><u>TITLE</u></b>	<b><u>PAGE</u></b>
1	MERRIMACK CURVE	36
2	TYPICAL UTILITY PIPE SEPARATIONS	65

## **INTRODUCTION**

The field of environmental engineering and regulatory framework has advanced significantly since MassDEP developed the “Guidelines for the Design, Construction, Operation and Maintenance of Small Sewage Treatment Facilities with Land Disposal – Second Draft: January 1988” and the subsequent revisions in April 2004. The 2012 document includes a substantial updating to reflect improvements in wastewater treatment technology and new regulatory changes which establish proper design, construction and operational practices for small wastewater treatment works with discharge to groundwater.

Our understanding of groundwater flow dynamics and the potential for impacts on downstream resources has grown. There are also a number of new MassDEP policies and initiatives which directly impact the groundwater program. Lastly, our experience in reviewing the design and operation of wastewater treatment facilities over the years has given us a keen insight into what is necessary to construct, operate, and maintain a modern facility.

This document is intended to serve as a technical guide for individuals involved in the design, construction, and use of small wastewater treatment facilities in the Commonwealth of Massachusetts. It outlines the current regulations, policies, and standards of MassDEP as they relate to facilities that discharge to the ground. For the purposes of this document, small treatment facilities are defined as those with a sewage flow of between 10,000 and 150,000 gallons per day (gpd). This document only applies to these small treatment facilities.

It is the MassDEP’s intent that this guidance be used as a supplement to the standards and design criteria found in the document published by the New England Interstate Water Pollution Control Commission titled “TR-16: Guides for the Design of Wastewater Treatment Works – 2011 Edition”. TR-16 is and will continue to remain as the primary design reference for MassDEP use. This additional guidance is not intended to replace TR-16, but rather to provide further information and standards, where necessary, given the particular problems that we face in Massachusetts in the design and construction of land-based systems. It should be emphasized that while this guidance is intended primarily for small systems, many of the principles and design criteria are also applicable to larger systems. The larger systems (> 150,000 gpd) present a different set of issues that have to be evaluated in a separate manner. As an example, such topics include flow derivation, size of effluent disposal reserve area and/or redundancy, and level of hydrogeologic evaluation. Whenever possible, differences in approach will be noted in the text.

In addition to TR-16, other documents used in the development of this guidance and to be read in conjunction with include:

- ❖ Wastewater Engineering: Treatment, Disposal, and Reuse – 3<sup>rd</sup> Edition  
Metcalf & Eddy

- ❖ Water Reuse: issues, Technologies, and Applications – Metcalf & Eddy/AECOM
- ❖ Biological Wastewater Treatment – 2<sup>nd</sup> Edition – Grady, Daigger, & Lim
- ❖ Wastewater Treatment Plant Design: Manual of Practice (MOP 8) – Water Environment Federation
- ❖ Process Design Manual: Land Treatment of Municipal Wastewater– United States Environmental Protection Agency (EPA 625/1-81-013)
- ❖ Process Design Manual: Land Treatment of Municipal Wastewater – Supplement on Rapid Infiltration and Overland Flow – United States Environmental Protection Agency (EPA 625/1-81-013a)
- ❖ The Northeast Guide for Estimating Staffing at Publicly and Privately Owned Wastewater Treatment Plants – New England Interstate Water Pollution Control Commission (November 2008)

## **ACKNOWLEDGEMENT**

This document represents the collective thought and expertise of many individuals both within and outside MassDEP of Environmental Protection. Without the active involvement of these individuals and the organizations and agencies they represent, this publication would not be possible. Specifically, MassDEP would like to thank the following individuals and organizations for their time in reviewing and commenting on these documents:

Mark Beaudry	Meridian Associates
Charles Button	STANTECH
Michael Giggey	Wright-Pierce Engineers
Thomas Parece	AECOM
George Preble	Beals & Thomas, Inc.
David Young	CDM Smith

### **Department of Environmental Protection Staff**

Kevin Brander	June Mahala
David Boyer	Paul Nietupski
Marybeth Chubb	John Ostrosky
Andrew Cohen	Brett Rowe
Lisa Dallaire	Alan Slater
Deirdre Desmond	Harold Stephens
Brian Dudley	Greg Tomaszewski
David Ferris	Margaret Webber
Claire Golden	Ronald White
Stephen Hallem	Dana Hill
Robert Kimball	

Alan Slater of the Massachusetts Department of Environmental Protection was the technical editor and project manager for this effort.

## **I. LAWS AND REGULATIONS**

There are several laws and regulations implemented by federal, state and local governmental agencies that apply to the planning, installation, operation and maintenance of small sewage treatment facilities. This section presents a brief explanation of the major regulatory programs with jurisdiction over small sewage treatment facilities. It also contains a table listing possible regulatory requirements applicable to any particular project. Copies of other laws and regulations can be obtained from these links:

- (1) Massachusetts General Laws are available online at <https://malegislature.gov/Laws/GeneralLaws>
- (2) Most MassDEP regulations are available at the MassDEP website at <http://www.mass.gov/dep/> or the State House Bookstore, Room 116, State House, Boston, MA 02133, telephone (617) 727-2834;
- (3) for local bylaws, ordinances and regulations the Town Clerk at the Town Hall for the municipality in which the facility is to be located; and
- (4) for federal laws and regulations, visit the Federal Bookstore website at <http://bookstore.gpo.gov> or telephone (866) 512-1800.

### **A. STATE**

The primary statutory authority for regulation of small sewage treatment facilities is contained in the Massachusetts Clean Waters Act, M.G.L. c. 21, §§ 26-53. This state law established a Division of Water Pollution Control within MassDEP. The responsibilities of the Division of Water Pollution Control have since been transferred to MassDEP's Division of Wastewater Management (Division). The Division's duties and responsibilities include enhancing the quality and value of water resources and establishing a program for the prevention, control, and abatement of water pollution. The Division is specifically authorized by the Act to establish programs and adopt regulations that include:

1. standards of minimum water quality applicable to the various waters of the Commonwealth;
2. a permit program establishing effluent limits and procedures applicable to the management and disposal of pollutants including, where appropriate, prohibition of discharges;
3. requirements for dischargers to establish monitoring, sampling, record keeping and reporting procedures and facilities, and to submit data gathered to the Division;
4. regulations requiring proper operation and maintenance of wastewater treatment facilities;
5. rules and regulations needed to properly administer laws regarding water pollution control and protect the quality and value of water resources; and

6. requirements for the Division to approve reports and plans of wastewater treatment facilities, or any part thereof, and to inspect the construction of such facilities to determine compliance with the approved plans.

Additionally, M.G.L. c. 111, §17 requires towns, districts and other persons to submit their proposed system for the disposal of drainage and sewage to MassDEP for its approval.

The Code of Massachusetts Regulations (CMR) is a compilation of state agency regulations. Agency regulations implement statutes passed by the state legislature. The state laws are referred to as the Massachusetts General Laws (M.G.L.).

MassDEP regulates discharges of pollutants below ground surface through the Ground Water Discharge Permit Program (“the Program”) regulations at 314 CMR 5.00 requiring potential dischargers to seek plan approval and obtain a discharge permit. Those regulations also impose limitations on the amount and type of pollutants allowed to be discharged to assure that the receiving waters meet minimum water quality standards established by those regulations as well as the Surface Water Quality Standards, 314 CMR 4.00.

Each ground water discharge permit also contains monitoring and reporting requirements to verify compliance with permit limitations and conditions, including a requirement for the installation of monitoring wells. Plans for a minimum of three ground water monitoring wells (one upgradient and two downgradient) for compliance monitoring must be submitted to the Program as part of a completed hydrogeological report. The plans must specify the type of wells, their locations, depth, screen selection and method of construction, development and sampling.

As part of the submittal for a groundwater permit, the applicant must also submit an engineering report and a certification statement that the engineering report and the plans and specifications have been prepared in accordance with all applicable standards. A copy of the certification form can be found at the MassDEP website. The formal submission of the plans and specifications is not required until ninety (90) days prior to the start up of the facility. In limited circumstances, particularly dealing with new technology, MassDEP may request a set of plans and specifications when the permit application is submitted.

Procedures for plan approval and permit issuance are specified in the Permit Procedure regulations at 314 CMR 2.00. Generally, the project proponent submits a completed discharge permit application, along with the certification form, to MassDEP. The project proponent must submit a copy of the application and accompanying documents to both the Boston office and the appropriate regional office of MassDEP

A project proponent must submit sufficient engineering and hydrogeological information to explain the public health and environmental impacts of the proposed project to MassDEP. After receiving sufficient information, MassDEP prepares a draft permit and

a fact sheet detailing the significant factual, legal, methodological and policy questions considered by MassDEP during its review of the project. The draft permit and fact sheet are sent to the applicant, the applicant's consultants and the local Board of Health for review and comment.

Following this informal review, MassDEP makes a tentative determination to either issue or deny the permit and begins the formal public comment process. Notice of the tentative determination will be published in accordance with the procedures outlined in 314 CMR 2.00. Publication of the notice begins a thirty-day public comment period on the tentative permit determination to MassDP. If the applicant or permittee requests a public hearing, or if MassDEP decides that a public hearing is in the public interest, MassDEP schedules and conducts the hearing in a community within the area affected by the facility or discharge. If a public hearing is deemed necessary, the permit issuance or denial is postponed until all issues raised during the hearing have been evaluated and MassDEP has prepared a final response summary and determination.

At the conclusion of the thirty-day public comment period, MassDEP issues the permit or a final determination to deny it. If no comments objecting to the permit's issuance or terms were received during the public comment period, the permit becomes effective on the date of issuance. If comments objecting to the permit's issuance or terms were received during the thirty-day comment period, the permit becomes effective thirty days after its issuance. Any person aggrieved by the permit's issuance, terms, or MassDEP's determination to deny the permit may file a request for an adjudicatory hearing with MassDEP's Office of Administrative Appeals within the thirty-day period following permit issuance.

MassDEP's Operation And Maintenance and Pretreatment Standards For Wastewater Treatment Works and Indirect Dischargers regulations at 314 CMR 12.00 require permittees to submit an Operation and Maintenance manual and a Staffing Plan to MassDEP for review and approval ninety (90) days prior to the start up of the facility. In addition, the Certification of Operators of Wastewater Treatment Facilities regulations at 257 CMR 2.00 require that a certified wastewater treatment plant operator must be employed by the permittee to operate and maintain the treatment facilities.

The project may require a filing under 301 CMR 11.00, the Massachusetts Environmental Policy Act (MEPA). These regulations establish review thresholds at 310 CMR 11.03 that determine whether MEPA review is required.

## **B. LOCAL**

At the local level, primary regulatory authority over the design, construction and use of small sewage treatment facilities that discharge less than 10,000 gallons per day is vested in the Board of Health. Title 5 of the State Environmental Code at 310 CMR 15.003 requires the Board of Health to issue a disposal system construction permit prior to the construction of any subsurface sewage disposal system, in most instances. M.G.L.

c. 111, §31 authorizes Boards of Health to adopt reasonable health regulations. Many Boards have used this authority to promulgate bylaws, ordinances or regulations more stringent than MassDEP's Title 5 regulations.

The primary regulatory authority for facilities greater than 10,000 gallons per day is vested in MassDEP. Unlike Title 5, there is no formal local review process or local jurisdiction over 10,000 gallons per day, but the applicant should check with the Board of Health to determine if any additional requirements beyond those imposed by state laws and regulations apply to the proposed project, regardless of size.

Fats, Oils and Greases (FOG) are separated from the sewage collection system and stored for transport to approved facilities. The FOG material shall be handled, treated and disposed as a solid waste and subject to M.G.L. c. 111, s. 150A and 310 CMR 15.000 as appropriate.

### **C. FEDERAL**

MassDEP, not the federal government, has jurisdiction over the groundwater discharge permit program.

The Underground Water Source Protection Program also known as the Underground Injection Control Program (UIC) is a federal program designed to protect underground sources of drinking water from pollution. The United States Environmental Protection Agency (EPA) pursuant to the Federal Safe Drinking Water Act, 42 U.S.C.A §§300f to 300j-26, administers this program. The EPA divides injection practices into five classes. Class I includes deep disposal wells for industrial and municipal waste. Class II covers all injection wells related to oil and gas production including wells used to store hydrocarbons, which are liquid at standard temperature and pressure. Class III includes wells, which inject liquids for the in situ extraction of minerals or energy. Class IV includes the injection of hazardous and high level radioactive wastes into and above usable ground water. Class V covers all other injection wells including those used to discharge treated sewage.

In Massachusetts, the EPA has delegated the UIC Program to MassDEP of Environmental Protection. MassDEP has promulgated regulations at 310 CMR 27.00 to implement the State's UIC Program in accordance with the federal requirements. For purposes of the UIC Program, a well is defined as a "bored, drilled, or driven shaft, a dug hole, or seepage pit whose depth is greater than the largest surface dimension; or, an improved sinkhole; or, a soil absorption system. Please contact MassDEP for further information on UIC applicability.

## **LIST OF ACRONYMS USED ON SUMMARY TABLES**

BOH – Board of Health

CFR- Code of Federal Regulations

CMR- Code of Massachusetts Regulations

DPS- Massachusetts Department of Public Safety

EOEA- Massachusetts Executive Office of Energy & Environmental Affairs

EPA- Federal Environmental Protection Agency

FWPCA- Federal Water Pollution Control Act

MassDEP- Massachusetts Department of Environmental Protection

MEPA- Massachusetts Environmental Policy Act

M.G.L.- Massachusetts General Laws

NPDES- National Pollution Discharge Elimination System

O&M- Operation and Maintenance

U.S.C.- United States Code

WWTF- Wastewater Treatment Facilities

TABLE 1

**REGULATORY SUMMARY**

<i>Program Name</i>	<i>Component or Activity Regulated</i>	<i>Application or Filing Required</i>	<i>Statutory Authority</i>	<i>Regulatory Reference</i>	<i>Implementing Agency</i>
Permit Procedures			M.G.L. c. 21, §27	314 CMR 2.00	MassDEP
Surface Water Discharge Permit	Treatment Plant	Application/Plans	M.G.L. c. 21, §27	314 CMR 3.00	MassDEP
Surface Water Quality Standards			M.G.L. c. 21, §27	314 CMR 4.00	MassDEP
Hydrogeological Report	Treatment Plant Discharge	Application/Report	M.G.L. c. 21, §27	314 CMR 5.00	MassDEP
Ground Water Discharge Permit	Treatment Plant and Discharge	Application Certification Form	M.G.L. c. 21, §27	314 CMR 5.00	MassDEP
Sewer System Extensions and Connections	Collection System	Application/Plans	M.G.L. c. 21, §27	314 CMR 7.00	MassDEP
Operation & Maintenance of Treatment Facilities	Treatment Plants/Sewers	O&M Manual and Staffing Plan	M.G.L. c.21, §27	314 CMR 12.00	MassDEP
Administrative Penalty Regulations	Violations of State Laws and Regulations		M.G.L. c. 21A, §16	310 CMR 5.00	MassDEP
Wetland Protection	Construction within 100 ft. of Wetland or 200 ft. of a Riverfront Area	Notice of Intent	M.G.L. c. 131, §40	310 CMR 10.00	Local Conservation Commission/MassDEP
Water Quality Certification	Activity Requiring Federal Permit	Plans	33 U.S.C. §1341; M.G.L. c. 21, §27	314 CMR 9.00	MassDEP
Cross Connections	Water Supply	Plans for Backflow Preventor	M.G.L. c. III, §160A	310 CMR 22.00	MassDEP

TABLE 1 CONTINUED

<i>Program Name</i>	<i>Component or Activity Regulated</i>	<i>Application or Filing Required</i>	<i>Statutory Authority</i>	<i>Regulatory Reference</i>	<i>Implementing Agency</i>
Underground Injection Control	Discharge into Wells	Registration Form	M.G.L. c. 21, §27	310 CMR 27.00	MassDEP
Wastewater Treatment Plant Operation Certification	Operator	Application/ Exam	M.G.L. c. 21, §34A & 34B	257 CMR 2.00	State Board of Certification of Operators of WWTF's
Environmental Code General Application & Administration	Environmental		M.G.L. c. 21A, §13	310 CMR 11.00	MassDEP
Massachusetts Environmental Policy Act	Issuance of State Permit	Environmental Notification Form	M.G.L. c.30, §§61-62H	301 CMR 11.00	State MEPA Office/EOEEA
Waterways License	Waterways		M.G.L. c. 91, §1-63	310 CMR 9.00	MassDEP
Engineer Registration	Design Engineer	Application/ Exam	M.G.L. c. 112, §81 D-T	250 CMR 1:00-6.00	State Board of Registration of Professional Engineers and Land Surveyors
Air Pollution Regulations	Diesel Generator	Plans	M.G.L. c. III, §142 A-E	310 CMR 7.00	MassDEP

TABLE 1 CONTINUED

<i>Program Name</i>	<i>Component or Activity Regulated</i>	<i>Application or Filing Required</i>	<i>Statutory Authority</i>	<i>Regulatory Reference</i>	<i>Implementing Agency</i>
Ambient Air Quality			M.G.L. c. III, §142 A-E	310 CMR 6.00	MassDEP
Disposal Works Construction Permit	Subsurface Disposal System	Application/ Plans	M.G.L. c. 21A, §13	310 CMR 15.000	Local Board Health/MassDEP
Building Permit	Building	Application/ Plans	M.G.L. c. 143	780 CMR	Local Building Inspector/MassDEP
Plumbing Permit	Plumbing	Application	M.G.L. c. 143, §13	248 CMR 2.00	Local Plumbing Inspector/DPS
Electric Permit	Wiring	Application	M.G.L. c. 143, §3L	527 CMR 12.00	Local Wiring Inspector/DPS
Flammable Liquid Storage	Storage tanks	Application/ Plans	M.G.L. c. 148, §1-59	527 CMR 14.00	Local Fire Chief/DPS
Zoning By-Laws	Subdivision Plan	Plans	M.G.L. c. 40A	310 CMR 15.000	Local Planning Board/Zoning Board
Hauler's Permit	Transportation & Disposal of Sludge/Septage/Grease	Application	M.G.L. c.21A, §13	310 CMR 15.000	Local Board of Health
FWPCA §404 Dredge and Fill Permit	Construction in Navigable Water	Application	33 U.S.C. §1344	40 CFR Parts 220-232	Federal Army Corps of Engineers
NPDES Permit	Discharge to Surface Waters	Application	33 U.S.C. §1342	40 CFR Parts 122-125	Federal EPA
Solid Waste	Fats,Oils & Grease	Application	M.G.L. c.111, s150 M.G.L. C.111. s150A 310CMR19.00	310CMR16.00	Local BOH/MassDEP

## **II. FILING FOR A GROUNDWATER DISCHARGE PERMIT**

The MassDEP Groundwater Discharge Permit Program regulates the location, construction, operation and monitoring of all wastewater treatment plants designed for flows exceeding 10,000 gallons per day. It should be noted that there may be instances where a prospective permittee may wish to pursue a MassDEP groundwater discharge permit for a discharge of less than 10,000 gallons per day of treated sanitary wastewater to the ground where the applicant seeks to obtain a higher effluent loading to the ground than available under a Title 5 system. New systems, unpermitted systems and some systems to be modified will undergo a review process that will assure compliance with 314 CMR 5.00 and will result in the issuance of an individual groundwater discharge permit or coverage under a general permit. For both types of permit, a Hydrogeologic Evaluation is required.

The applicant should begin the permitting process with a pre-permit scoping meeting with MassDEP. Following this meeting, the applicant will develop and submit to MassDEP a scope of work for a hydrogeological investigation that is specific to the proposed site in accordance with 314 CMR 5.09, including consideration of downgradient receptors. Upon MassDEP approval of the scope of work, the applicant will then prepare a hydrogeological evaluation report consistent with that scope.

The completed hydrogeological evaluation report will be submitted to the MassDEP with the BRP WP 83 application form, the fee and other required materials. The MassDEP approval of the hydrogeological evaluation report will direct the applicant to apply for a groundwater discharge permit through the submittal of either a Notice of Intent for Coverage under a General Permit or the appropriate individual groundwater discharge permit application.

### **GENERAL PERMIT COVERAGE:**

314 CMR 5.13 gives MassDEP the authority to issue general permits to one or more categories of dischargers whose discharges warrant similar control measures. Currently there are four categories of General Permit:

- 1) <50,000 gpd sewage treatment plants for Publicly Owned Treatment Works (POTW);
- 2) <50,000 gpd sewage treatment plants for Private Sewage Treatment Facilities (PSTF) (BRPWP81); and
- 3) Carwashes (BRPWP80)
- 4) Commercial Coin-operated Laundromats (BRPWP 80)

The permits and fact sheets can be viewed online at: <http://www.mass.gov/eea/agencies/massdep/water/approvals/general-permits-associated-with->

brp-80-and-brp-81.html If your project is eligible for a general permit, the applicant submits a Notice of Intent (NOI) for coverage under the appropriate category. The NOI submittal will include:

- Project Description
- Design Criteria (Flow rate, loadings, treatment units)
- Engineering Report Certification
- Plans and Specification Certification
- Hydrogeologic Evaluation Certification

It is important to note that by submitting an NOI for coverage under a general permit the applicant waives any right to request an adjudicatory hearing relative to the MassDEP's issuance or denial of the general permit coverage.

The Mass DEP will review the NOI for administrative and technical components. This review will determine whether coverage can be granted or not. If coverage is approved, the applicant will receive the public notice form to be published in accordance with 314 CMR 2.06. At a minimum, the public notice is sent to be published in the Environmental Monitor with MEPA. Forms and directions for these publications are provided to the applicant. The comment period is 30 days and comments are limited to the applicant's eligibility for coverage.

Coverage under the general permit is effective 45 days from the date the notice was published, unless the applicant is otherwise notified. Upon approval, the applicant will be sent copies of the general permit and general permit fact sheet and an approval letter describing the facility, approved design flow, assigned permit number, specific monitoring wells to be sampled, and, for new facilities, inspection and clear water test requirements. The letter will also state the submittals required to be made prior to the start up of the plant.

If coverage cannot be approved, the applicant may receive a deficiency letter stating what information the application is missing, a denial letter stating why coverage cannot be approved or will be directed to apply for an individual permit.

#### INDIVIDUAL PERMIT:

There are three different types of applications for individual permits:

***BRPWP79 – Individual Sewage Treatment Plant***

***BRPWP84 – Reclaimed Water System***

***BRPWP85 – Individual Discharge Permit not in WP79 or WP80***

After completion and approval of the hydrogeological evaluation the applicant submits the appropriate application which includes:

- Engineering Report with Certification
- Hydrogeologic Certification

- Plans and Specification Certification

If the site is located in a Zone II or interim wellhead protection area (IWPA) then the applicant must notify the Public Water Supply of the submittal.

If the application is for a reclaimed water system (WP84), then the application will need to include the information specified in 314 CMR 20.11 and 20.12, a reuse management plan and a service and use agreement if the reclaimed water is to be used by persons other than the permittee.

The Mass DEP will review the application for administrative and technical components based on the timelines for review established for each permit category under 310 CMR 4.00. If the application is complete a draft permit and fact sheet are sent to the applicant. The applicant will receive the public notice form to be published in accordance with 314 CMR 2.06 At a minimum, the public notice is sent to be published in the Environmental Monitor with MEPA. Forms and directions for these publications are provided to the applicant. The comment period is 30 days.

Upon approval, the applicant will be sent copies of the individual permit and plan approval letter. The letter will state the submittals required to be made prior to the start up of the plant and will specify any inspection and clear water test requirements. The permit will be issued and will be effective on issuance or, if comments were received, 30 days from the date of issuance.

If the application is incomplete or cannot be approved, the applicant will receive a deficiency letter stating what information the application is missing. The letter will include timeframes for the applicant to address any deficiencies.

Please note that the permit application for an individual permit for a new or modified WWTFs no longer requires that engineering plans and specifications be submitted with the application. Instead, an expanded engineering report accompanied by a certification statement from a Massachusetts Registered Professional Engineer stating that the plans and specifications have been prepared in accordance with applicable standards are required. The formal submission of engineering plans & specifications for the proposed wastewater treatment facility to the MassDEP is required 90 days prior to the startup of the facility. These plans must be stamped, signed and dated by a **Massachusetts Registered Professional Engineer**. The plans and specifications must describe in detail the collection, treatment and disposal components of the WWTF. It should be noted that , in accordance with 314 CMR 5.09A (4) and (5), the MassDEP may request that plans and specifications be submitted with the application or at any time during the application's review process.

Some facilities will be required to provide Financial Assurance Mechanisms (FAMs) per 314 CMR 5.15. Standard form documents are used for the FAMs and are provided to the

permittee during the review of the application. These documents must be approved, signed and submitted to the MassDEP 90 days prior to facility startup.

Permit applications must also include a ground water monitoring plan and a certification statement that the hydrogeological evaluation of the WWTF disposal site and its surroundings has been done and approved by MassDEP. Specifics regarding these submittals are contained in each of the permit application packages and a Certification Statement form is also provided. Application packages are available from the DEP Internet web site at:

<http://www.mass.gov/eea/agencies/massdep/water/wastewater/groundwater-discharge-permitting.html>

#### RENEWAL OF PERMITS:

Groundwater Discharge Permits are issued for up to 5 years. Persons who want to continue the permitted activity either under an Individual permit or through coverage under a General permit, must submit a renewal application six months prior to the expiration date of the permit.

The permit renewal application categories are:

***BRPWP80 and 81 for renewal of coverage under a General Permit***

***BRPWP11 and 12 for renewal with or without modification for an Individual Permit***

***BRPWP82 Administrative Renewal for an Individual Permit***

Renewal of coverage under a General Permit and renewal of an Individual permit follow the same process of review and issuance (administrative review, technical review and public notice) as the original application.

The BRPWP82, Administrative Renewal application, is a new category of renewal for Individual permits issued under 314 CMR 5.00. This application has shorter timelines and lower fees than the other renewal categories. In order to qualify for an Administrative renewal the permittee must meet **all** the criteria listed in 314 CMR 5.12(9):

- Application submitted 180 days prior to the expiration date
- No modifications required or requested
- Facility is operating in compliance with 314 CMR 5.00, CMR 12.00, the operation and maintenance plan and any applicable Best Management Practices (BMPs)
- A Massachusetts Registered Engineer inspects and certifies that the facility is in compliance
- MassDEP determines that current limits are protective and stricter limits are not required
- Facility is in compliance with the Financial Assurance Mechanisms (if applicable)
- Facility is not required to submit an engineering report for treatment plant evaluation, typically conducted in operational year 14 through 19 or beyond per 314 CMR 5.12 (7) & (8)
- Facility does not treat industrial wastewater
- BRPWP82 application is signed and certified as required by 314 CMR 5.14



### **III. REQUIRED SUBMITTALS**

All permit applications, notices of intent, and supporting documents shall be submitted to the local Board of Health, the appropriate MassDEP Regional Office and the Boston Office of MassDEP's Wastewater Management Program at least 180 days prior to the date upon which an action by MassDEP is desired. The documents submitted for formal approval shall include an engineering report, a hydrogeologic report, a completed discharge permit application, , certification statement on final plans and specifications, an operation and maintenance plan, a staffing plan, documentation of ownership and financial resources and contracts for operational services.

The engineering report and any plans and specifications required shall be stamped, dated and signed by a qualified professional engineer registered to practice in the Commonwealth of Massachusetts. If the engineer's discipline is not noted on the stamp, then the discipline shall be printed below the imprint.

No construction of wastewater treatment works shall take place until the application or notice of intent has been approved by MassDEP and the discharge permit has been issued.

#### **A. HYDROGEOLOGIC REPORT**

The first step in the process is the preparation and approval of the hydrogeological report assessing the site characteristics and the fate and effects of the treatment plant discharge. A qualified geologist or engineer must prepare this report. The completed hydrogeological evaluation report will be submitted to the MassDEP with the BRP WP 83 application form, the fee and other required materials. The MassDEP approval of the hydrogeologic evaluation report will direct the applicant to apply for a groundwater discharge permit through the submittal of either a Notice of Intent for Coverage under a General Permit or the appropriate individual groundwater discharge permit application.

At the time of submittal for a groundwater discharge permit, the proponent will also submit the certification statement (Appendix A) signed by a Massachusetts Registered Professional Engineer that the present day site conditions and the design parameters for this facility are consistent with what was found at the time the hydrogeological report was initially performed.

The hydrogeological report shall include the following information:

The Long-Term Acceptance Rate (LTAR) shall be determined through percolation testing and/or infiltration rate testing in accordance with the scope of work approved by MassDEP. In all cases the soil must be tested under saturated conditions (soaked) as described in Title 5 or in documentation relative to the infiltrometer testing.

The appropriateness of the methods is determined by the size of the facility and the accepting soil characteristics. If the design discharge is less than 20,000 gpd, a

percolation test is the preferred method. The exception to this would be for a small system, which may be in tight (Class III) soils where an infiltration rate would yield the most reliable data.

For systems greater than 20,000 gpd an infiltration test shall be performed according to acceptable engineering practice or the technical reliability demonstrated to the satisfaction of MassDEP. However, if the soils are Class I, MassDEP may accept a percolation test. MassDEP should be contacted on this instance to determine the appropriate testing method.

For systems utilizing drip dispersal, percolation tests would be the preferred method.

The report shall minimally include (for primary and reserve area(s)):

- An analysis of the ability of site to accept and disperse flow at the proposed discharge rate. (Maximum Monthly Flow)
- Evaluation of the mounding potential, presence of confining layers, thickness and estimated aerial extent of unsaturated receiving formation. Mounding calculations or modeling to be evaluated for maximum monthly flow (defined as 80% of the design flow based on Title 5 calculations. However, it should be noted that the disposal field design is based on 100% of the design flow) for a duration of 90 days. Maximum daily flow may be higher, but the sum of the daily flows for the months over the 90 days shall not exceed the maximum monthly flow for the 90-day period evaluation of the site.
- Evaluation must include (if applicable) the effect of impermeable or semi-permeable barriers within the potential groundwater mound. These would include but not limited to foundations and retaining walls.
- Proposed appropriate monitoring well locations based upon known or inferred groundwater flow direction under various seasonal conditions and geology. (Minimum of one upgradient and two down gradient locations. MassDEP may require more based upon site complexity, proximity to sensitive areas or design of the system.)
- Evaluation of likely impacts on current and potential down gradient and cross gradient receptors. The list includes wells within 1 mile (public and private), wastewater discharges (such as septic systems), subsurface construction and infrastructure (basements and pipelines), water supply protection areas (Zone I, Zone II, Zone A), and Outstanding Resource Water.
- Hydraulic conductivity and infiltration rate.
- Groundwater flow direction.
- Determine ambient water quality (groundwater and if present nearby surface water).
- A summary of all soil borings and geotechnical evaluations.
- Test pits and Infiltration test data performed by a Certified Soil Evaluator, (or engineer or geologist with Department approval). Data forms to be included in the report.
- If within Zone II or well head protection area evaluate time of travel from

discharge to water supply. Also do time of travel evaluation to any sensitive receptor.

- Location of other wastewater disposal systems, which are near the proposed site. Indicate whether or not the mounds will interfere.
- Location (Lat, Long to nearest second), surveys to use the most recent standard datum. Currently it is a geographic coordinate reference system based on the NAD83 horizontal datum and NAVD88 vertical datum. The datum utilized shall be clearly stated.
- Proximity to the nearest wetlands and surface water bodies.
- Show proposed disposal areas on the site plan.
- Stormwater management concepts and their interaction with the proposed collection and dispersal systems.

## **B. ENGINEERING REPORT**

An engineering report shall be required for all projects involving sewage collection, treatment and disposal systems. It is required at the time of submittal for the following permits: BRP WP 11, BRP WP 68, BRP WP 79, BRP WP 84 and BRP WP 85. The purpose of this report is to present in clear, concise form a description of the project, the results of site evaluations, solutions examined, the basis of design for the recommended systems, and the associated environmental and public health impacts. The report shall be written for easy public understanding and serve as a permanent summary of the principle information needed by MassDEP for conceptual approval of the project. Data on structural, mechanical, electrical and HVAC designs may be excluded at this point of project development except that reference to such elements shall be made as necessary to understand the functional operation of the proposed systems.

The engineering report shall be stamped, dated and signed by a qualified professional engineer registered to practice in the Commonwealth of Massachusetts as either a civil or sanitary engineer. If the engineer's discipline is not noted on the stamp, then the discipline shall be printed below the imprint. At the time of submittal for a groundwater discharge permit, the proponent will submit a certification statement (Appendix A) from a Massachusetts Registered Professional Engineer stating that the engineering report has been prepared in accordance with applicable standards

The engineering report shall include, at a minimum, the following items:

- a detailed description of the project including all phasing of development which is expected over a 20 year planning period;
- all pertinent data concerning relevant local, state and federal permits, approvals, orders of conditions and variances;
- a description of the geographic location and setting of the project including a locus map and preliminary site plan at an appropriate scale;
- a description of the geology, hydrology and topography with an appropriate plan showing key features, surface drainage and contours of the project site;
- a listing of the current and projected population both resident and nonresident involved in the proposed project;

- the location of all public and private water supply wells, springs, surface reservoirs including tributaries, and other features of public health significance within a half mile of the project site;
- the amount and source of water supply for the proposed project;
- a delineation of all wetlands resource areas (as defined in 310 CMR 10.00) within the project boundaries and/or within 100 feet of any proposed construction activity;
- a description of the proposed sewage collection system for the project with a reference to the overall site plan;
- a description of the probable future expansion of the collection system together with information on how these areas will be served;
- an explanation of the relationship between the point of generation of sewage to the proposed treatment facility, including rough elevations and locations where pump stations may be necessary;
- a description of the various locations within the project site available for wastewater treatment and disposal and the reasons for choosing the one recommended;
- an identification of the proximity of residences or developed areas to the treatment and disposal areas;
- a discussion of the type of treatment and disposal processes studied, including water reclamation alternatives, and the reasons for choosing the recommended alternative;
- a description of how the proposed plan fits into the municipal wastewater management plan, including, where appropriate the potential for future transfer of ownership to the city, town, or district, and the possibility of including capacity for sewage flows from neighboring properties;
- identification of any local standards for wastewater treatment plant design and operation and how those local standards will be met;
- a complete description of the basis of design of the collection, treatment and disposal systems including design population (resident and nonresident), as well as flow contributing common facilities (recreational hall, laundries, health clubs, restaurants, etc.) strength of sewage, total daily sewage flow (including infiltration allowances where appropriate), and daily peak, monthly average and maximum hour (peak) flow;
- a description of all pumps, including type, number, and operating range;
- a description of all major unit processes giving capacity, equipment type, and operation factors under varying conditions (i.e. seasonal flow variations or project phasing), redundancy requirements and method of operation. Include design calculations for each unit process;
- a discussion of the degree and type of treatment and adequacy for present and future needs;
- a hydraulic profile showing water surface elevations at average, maximum, and minimum flow (peak) conditions;
- a general layout and flow diagram, including return lines, chemical feed lines, and sampling points shall be provided;

- a description of process control;
- a staffing analysis
- the results of all site testing and evaluations including the location and log for all soil borings, deep observation holes, and percolation tests;
- a list of chemicals used in each process and chemical metering; and
- a description of other ancillary items, such as, but not limited to; HVAC, lighting, safety, MSDS sheets, fire suppression, and compliance sampling.

### C. PLANS AND SPECIFICATIONS<sup>1, 2</sup>

Plans and specifications are required to be submitted ninety (90) days prior to facility start up. A certification statement (Appendix A) from a Massachusetts Registered Professional Engineer stating that the plans and specifications have been prepared in accordance with applicable standards is now required to be submitted with the permit application. It should be noted that, in accordance with 314 CMR 5.09A (4) and (5), the MassDEP may request that plans and specifications be submitted with the application or at anytime during the applications' review process. Regardless of when the documents are submitted to MassDEP, all plans and specifications must satisfy the requirements outlined below.

All plans shall bear a suitable title showing the name and location of the project and shall show the scale in feet, a directional arrow indicating north, date, the name, address and telephone number of the engineer and the imprint of his registration seal with signature and date.

The plans shall be clear and legible. They shall be drawn to a scale that will permit all necessary information to be plainly shown. The size of the plans shall be 24" x 36". The datum used and its relation to mean sea level datum (USC&GS) should be indicated. Locations and logs of all test borings, percolation tests and deep observation holes shall be shown on the plans.

Detailed plans shall consist of plan views, elevations, sections and supplementary views that, together with the specifications and general layouts, provide the working information for the contract and construction of the various processes. The plans shall include dimensions and relative elevations of all structures, the location and outline form of equipment location and size of piping, ground water levels, ground elevations (existing and finish grades) and hydraulic profiles. Plans shall include a profile (to scale) of the soil absorption system (SAS), which depicts the mounded, and high groundwater elevation below the SAS.

Complete technical specifications for the construction of sewers, pumping stations, and treatment and disposal systems including all appurtenances shall accompany the plans. The specifications accompanying the construction drawings shall include, but not be limited to, all construction information not shown on the drawings which is necessary to inform the

---

<sup>1</sup> The permittee should also check with the BWP air permitting section in the appropriate regional office to determine whether the project would trigger any of the air regulation thresholds.

<sup>2</sup> When the Division of Municipal Services finances a project, they may require early submission of plans and specifications.

contractor in detail of the design requirements as to the quality of materials, workmanship and fabrication of the project. They shall include: the type, size, strength, operating characteristics and rating of equipment, allowable infiltration including allowable methods of measuring infiltration; the complete requirements for all mechanical and electrical apparatus; wiring and meters; laboratory fixtures and equipment; operating tools; construction materials, special materials such as stone, sand or gravel; installation specifications; miscellaneous appurtenances; chemicals when used; instructions for testing materials and equipment as necessary to meet design standards; and operating tests for the completed works and component units.

The plans and specifications shall include architectural, civil, sanitary, structural, electrical, mechanical, HVAC, plumbing, process control and land surveying components of the sewage collection, treatment and disposal systems in sufficient detail for approval by MassDEP.

When required, a set of final design plans and specifications shall be submitted to the appropriate DEP regional office to be kept on file, along with an electronic copy. One set of final design plans and specifications must be kept on site at all times during construction.

All construction shall be in strict accordance with the approved plans and no changes to the plans shall be made without the prior written approval of MassDEP. The design engineer shall be present at the site at all important phases of construction to verify and certify that all construction of the treatment plant processes conform to the approvals. For all projects, at the completion of construction the design engineer shall submit one set of "as-built" record drawings to the DEP Regional Office showing final elevations and dimensions and which include any modifications that have been approved by MassDEP, along with a digital PDF copy.

#### **D. OPERATION AND MAINTENANCE PLAN**

An individual operation and maintenance (O&M) manual shall be prepared and kept current for all small sewage treatment facilities by a qualified civil or sanitary engineer licensed to practice in the state of Massachusetts. The O&M manual shall contain all information necessary for the plant operator to properly operate and maintain the collection, treatment and disposal systems in accordance with all applicable laws and regulations. The regulations at 314 CMR 12.04 include a listing of requirements. A copy of the approved O&M manual shall be maintained at the treatment plant at all times. See Section X for further details. The WWTF cannot begin operation until the O&M Manual has been reviewed and approved by MassDEP. The O&M Manual should be re-evaluated at the time of permit renewal or with any modification of the wastewater treatment/collection system.

#### **E. DOCUMENTATION OF OWNERSHIP AND FINANCES**

##### **Ownership Requirements**

For the specific ownership requirements relating to privately owned wastewater treatment facilities, please refer to 314 CMR 5.15.

## **Financial Security Requirements**

**Immediate Repair and Replacement Account:** The following applies to any PWTF that treats at least some sewage from residential uses, hospitals, nursing or personal care facilities, residential care facilities and/or assisted living facilities. In addition, Section 5.15(6) provides that the following may also apply to other PWTFs, if MassDEP so determines based on, for example, compliance history and/or consideration of risks to public health, safety, welfare or the environment (e.g., relating to actual and potential drinking water sources and/or to certain surface waters).

The permittee responsible for operating any such PWTF must establish and fund an immediate repair and replacement account with funds adequate to correct any unanticipated problem right away, in order to minimize any disruption of operation and avoid a violation of the terms and conditions of the PWTF permit. The permittee must use a form escrow agreement developed by MassDEP for establishing this account. This form is available from MassDEP online at: <http://www.mass.gov/dep/water/approvals/surffms.htm#groundwater>

The permittee must establish the immediate repair and replacement account a minimum of thirty (30) days before either starting operation of a new PWTF or renewing or transferring a permit for an existing PWTF.

The permittee must fund the immediate repair and replacement fund in an amount equal to at least fifteen per cent (15%) of the estimated construction cost of the PWTF. Cost estimates must include the cost of constructing the wastewater treatment plant (including building costs), the collection system and all mechanical equipment associated with the wastewater treatment plant and the collection system, but not the cost of the land, grounds or the disposal area. The permittee must maintain at least this amount in the fund by replenishing the fund within ninety (90) days of any disbursement.

The owner of a PWTF should maintain records of deposits to and disbursements from this account for at least seven years from the date of the transaction.

**Capital Reserve Account:** The following also applies to any PWTF that treats at least some sewage from residential uses, hospitals, nursing or personal care facilities, residential care facilities and/or assisted living facilities. In addition, Section 5.15(6) provides that the following may also apply to other PWTFs, if MassDEP so determines based on the criteria listed in that section, as described above.

The permittee responsible for operating any such PWTF must also establish a Capital Reserve Account with sufficient funds to replace the PWTF or portions of it, and all other mechanical equipment associated with the wastewater treatment and collection, except for land, grounds or disposal area. The permittee must use

a form trust agreement developed by MassDEP for establishing this account. This form is available from MassDEP online at: <http://www.mass.gov/dep/water/approvals/surffms.htm#groundwater>

Prior to MassDEP authorization to operate or a permittee commencing to operate, Section 5.15(4) of 314 CMR requires that all financial assurance mechanisms be approved, in full force and effect, and the permittee to have made all financial contributions required by the financial assurance mechanisms.

To fund a capital reserve account in full requires an amount equal to at least twenty-five per cent (25%) of the estimated construction cost of the PWTF in question. Cost estimates must include the cost of constructing the wastewater treatment plant (including building costs), the collection system and all mechanical equipment associated with the wastewater treatment plant and the collection system, but not the cost of the land, grounds or the disposal area.

The capital reserve account must be funded in accordance with the schedule set forth in the form trust agreement referenced above. For a PWTF that's been in operation for over fifteen (15) years, depending on its age and condition, MassDEP may determine that additional funds are required in the capital reserve account, in excess of the amount described above, to ensure the continued operation of the PWTF in a manner that adequately protects the public health, safety, welfare or the environment. In such cases, MassDEP would establish a schedule for accumulation of the additional capital, which the Permittee would need to incorporate into MassDEP's form trust agreement.

The owner of a PWTF should maintain records of deposits to and disbursements from this account for at least seven years from the date of the transaction.

**Annual Financial Report:** In addition to the above requirements, Section 5.10(8)(1)(1)(a) of 314 CMR, requires the owner of a PWTF that treats at least some sewage from residential uses, hospitals, nursing or personal care facilities, residential care facilities and/or assisted living facilities to submit to MassDEP an annual financial report. The report shall be due by January 31 of each year and should contain all financial transactions relating to the PWTF for the previous calendar year. The report must be prepared in accordance with generally accepted accounting principles. The report must include, at a minimum, the information required, below, and shall confirm the continued availability of funds for the purposes required by each account.

- (1) The report must include the initial and current balance of the security funds maintained in the "Immediate Repair and Replacement Account" and in the "Capital Reserve Account;"
- (2) the report should include a listing of all disbursements from each account;
- (3) the report must include a description of the means by which each account will be replenished;

- (4) the report should include a summary of expenses for operation, maintenance and repair of the sewage treatment facilities; and
- (5) the report should include a determination of assessments to the individual users for the current year.

**Rules & Regulations:** The owners of small sewage treatment facilities which service multiple users shall establish and submit to MassDEP for approval prior to the commencement of the facilities operation (including clear water hydraulic testing) a copy of the “Rules And Regulations Regarding The Use Of Common Sanitary Sewers”. Said rules and regulations shall be contained within tenantry use, in the lease or rental agreements. The rules and regulations shall contain, at a minimum, the following restrictions:

- (1) no person shall discharge or cause to be discharged any stormwater, surface water, groundwater, roof runoff or subsurface drainage, to any sanitary sewer;
- (2) no person shall discharge or cause to be discharged any of the following described waters or wastes to any sewers:
  - (a) any gasoline, kerosene, benzene, naphtha, fuel oil, or other flammable or explosive liquid, solid, or gas; Pollutants which create a fire or explosive hazard in the treatment works, including ,but not limited to, wastestreams with a closed-cup flashpoint of less than 140 Degrees F (60 Degrees C) using the test methods specified in 40 CFR 261.21.
  - (b) any non-latex paints, paint thinners, paint removers, or strippers;
  - (c) any organic solvent or any liquid containing any organic solvent including the following:

Acetone  
Benzene  
Bromodichloromethane  
Bromoform  
Bromomethane  
Carbon tetrachloride  
Chlorobenzene  
Chloroethane  
2-Chloroethylvinyl ether  
Chloroform  
Chloromethane  
1,2-Dichlorobenzene  
1,3-Dichlorobenzene  
1,4-Dichlorobenzene  
1,1-Dichloroethane  
1,2-Dichloroethane  
1,1-Dichloroethane  
trans-1,2-Dichloroethene  
cis-1,3-Diclorpropene  
trans-1,3-Diclorpropene  
Ethyl benzene

Methylene chloride  
1,1,2,2-Tetrachloroethane  
**Tetrachloroethene**  
Toluene  
1,1,1-Trichloroethane  
1,1,2-Trichloroethane  
Trichloroethane  
Trichloroflouromethane  
Vinyl chloride

- (d) any lubricating or hydraulic fluids including waste crankcase oil, brake fluid, transmission fluid, and lithium grease;
  - (e) any photographic fluids including waste developer, fixer and rinsewater;
  - (f) any pesticide including insecticides, fungicides, rodenticides and herbicides of any sort;
  - (g) any waters or wastes containing toxic or poisonous solids, liquids, or gases in sufficient quantity, either singly or by interaction with other wastes, to injure or interfere with any sewage treatment process, constitute a hazard to humans or animals, create a public nuisance, or create any hazard in the receiving waters of the sewage treatment plant;
  - (h) any waters or wastes having a pH higher than 9.5 or lower than 5.5, or having any other corrosive property capable of causing damage or hazard to structures, equipment, and personnel of the sewage works; and
  - (i) solid or viscous substances in quantities or of such size capable of causing obstruction to the flow in sewers, or other interference with the proper operation of the sewage works such as, but not limited to, ash, ashes, cinders, sand, mud, straw, shavings, metal, glass, rags, feathers, tar, plastics, wood, unground garbage, whole blood, paunch manure, hair and fleshings, entrails and paper dishes, cups, milk containers, etc. either whole or in parts.
- (3) No person shall discharge or cause to be discharged the following described substances, materials, waters, or wastes if it appears likely in the opinion of the owners or their agent that such wastes can harm either the sewers, sewage treatment process, or equipment, have an adverse effect on the receiving waters, or can otherwise endanger life, limb, public property, or constitute a nuisance. In forming the opinion as to the acceptability of these wastes, the owners or their agent will give consideration to such factors as the quantities of subject wastes in relation to flows and velocities in the sewers, materials of construction of the sewers, nature of the sewage treatment process, capacity of the sewage treatment plant, degree of treatability of wastes in the sewage treatment plant, and other pertinent factors. The substances prohibited are:
- (a) any liquid or vapor having a temperature higher than 150 °F (65 °C);
  - (b) any water or waste containing fats, wax, grease, or oils, whether emulsified or not, in excess of 100 mg/l or containing substances which may solidify or become viscous at temperatures between 32 and 150°F (0 and 65°C);
  - (c) any garbage that has not been properly shredded. The installation and operation of any garbage grinder equipped with a motor of three-fourth's (3/4) horsepower (0.76 hp metric) or greater shall be subject to the review and approval of the owners or their designated agent; and
  - (d) waters or wastes containing substances which are not amenable to treatment or reduction by the sewage treatment process employed, or are amenable to treatment only to such degree that the sewage treatment plant effluent cannot meet the requirements of other agencies having jurisdiction over discharge to the receiving waters.

(4) No unauthorized person shall maliciously, willfully, or negligently break, damage, destroy, uncover, deface, or tamper with any structure, appurtenance, or equipment which is a part of the sewage works. Any person violating this provision shall be subject to immediate arrest under charge of disorderly conduct.

**Effluent Discharge Limits:** The following table lists typical effluent limits for a standard groundwater discharge permit. These are maximum day values not to be exceeded. These limits can be more stringent on a case-by-case basis if site-specific conditions warrant a greater degree of protection.

<b><u>Parameter</u></b>	<b><u>Limit</u></b>
Flow	Approved design flow in gpd
pH	6.5-8.5 Standard Units (not more than 0.2 S.U. outside naturally occurring range)
Fecal Coliform <sup>2</sup>	200/100 ml
Chlorine Residual or UV Dose	1.0 mg/l Case-by-case
BOD	30 mg/l
Total Suspended Solids (TSS)	30 mg/l
Total Nitrogen	10 mg/l
Nitrate Nitrogen	10 mg/l
Total Phosphorus	Case-by-case
Orthophosphate	Case-by-case
Oil & Grease	15 mg/l
Volatile Organic Compounds <sup>3</sup> (US EPA Method #624)	Monitor and report

If the effluent discharge is located within the Zone II or IWPA of a public water supply well, the effluent standards are more stringent. First, no discharge is allowed within either the Zone I (400 foot radius of the well) or the six-month groundwater travel time to the source, whichever is greater. Second, the effluent limits will be more stringent if the discharge is within the two-year groundwater travel time to the source. Again, these are maximum day values not to be exceeded.

<b><u>Parameter</u></b>	<b><u>&lt;2-Year Travel Time</u></b>	<b><u>&gt;2-Year travel Time</u></b>
Flow	Approved design flow in gpd	Approved design flow in gpd
Fecal Coliform	Median of no detectable	200/100 ml

<sup>2</sup> Fecal requirement only applicable when open sand beds are proposed or as otherwise determined by MassDEP

<sup>3</sup> Should not exceed Maximum Contaminant Levels (MCL) as contained in 310CMR22.00, Drinking Water

	colonies/100 ml during a 7day sample period with no sample greater than 14colonies/100ml	
Turbidity	Not to exceed an average of 2 NTU in a 24-hr period, 5 NTU more than 5% of the time in a 24-hr period of 10 NTU at any time	5NTU
pH	6.5-8.5 Standard Units (not more than 0.2 S.U. outside naturally occurring range)	6.5-8.5 Standard Units (not more than 0.2 S.U. outside naturally occurring range)
Chlorine Residual or UV Dose	1.0 mg/l Case-by-case	1.0 mg/l Case-by-case
BOD	10 mg/l	30 mg/l
TSS	5 mg/l	10 mg/l
Total Organic Carbon (TOC)	1 mg/l	3 mg/l or as determined by DEP
Total Nitrogen	5 mg/l	10 mg/l
Nitrate Nitrogen	10 mg/l	10 mg/l
Oil & Grease	15 mg/l	15 mg/l
Volatile Organic Compounds <sup>4</sup> (US EPA Method #624)	Monitor and report	Monitor and report
Other constituents as specified by MassDEP	Case-by-case	Case-by-case

## F. CONTRACT SERVICES

Contracts for the following services shall be submitted to MassDEP at least 14 days prior to scheduling a clear water hydraulic test.

- Certified Wastewater Treatment Plant Operator;
- Professional Engineer Operational Consultant;
- Licensed Septage Hauler;
- Approved Sludge Treatment and Disposal Facility; and
- Approved Laboratory

Proof of employment and resume of qualified members of the owner's staff may be submitted as partial fulfillment of the above obligations.

### Certified Wastewater Treatment Plant Operator

**General:** A certified operator shall be retained by the owner of all small sewage treatment facilities in accordance with the requirements of the Board of Certification of

<sup>4</sup> Should not exceed Maximum Contaminant Levels (MCL) as contained in 310CMR22.00, Drinking Water

Operators of Wastewater Treatment Facilities. The operator shall be responsible for daily operation and routine maintenance of the collection, treatment and disposal systems.

**Plant Coverage:** The certified operator shall spend a minimum of two hours per day, five days each week at the facilities or as otherwise stated in the approved O&M Manual and staffing plan. Additional time shall be allotted when conditions warrant. Treatment Plants rated by the Board of Certification of Operators of Wastewater Treatment Facilities as Grade 4 and above shall have a certified operator present at least 3 hours a day during the working week and at least one hour a day on weekends and holidays. Note that as facilities increase in size and complexity that the required plant coverage will increase. See Section X for further details.

**On Call Requirements:** The operator or an assistant, each of whom must be certified at least to the grade level of the plant, shall be on call 24 hours a day, 7 days a week to respond to plant malfunctions. On-call personnel shall be equipped with an appropriate paging device and shall be capable of responding to emergencies within one hour of alarm activation.

**Reporting:** The certified operator shall report any plant malfunction that has the potential to endanger public health or the environment to MassDEP and the local Board of Health. Initial notification shall be provided orally within 24 hours from the time the operator becomes aware of the circumstances. A written report shall also be provided within 5 days of the time the operator becomes aware of the circumstances. The written submission shall contain a description of the event, including exact dates and time, steps taken or planned to eliminate the problem and to prevent its reoccurrence. The operator shall perform all sampling and reporting requirements in accordance with the discharge permit.

**Operational Training:** The certified operator shall be responsible for all process control testing including free chlorine residual; influent, effluent and intermediate BOD, suspended solids, settleable solids, nitrogen series, pH and dissolved oxygen. The operator shall also be responsible for maintaining flow charts and recording the daily flow.

**Record Keeping:** The certified operator shall maintain all testing records and flow records at the plant for inspection and shall submit copies of the results to MassDEP and the local Board of Health as required by the discharge permit.

### **Professional Engineer Operational Consultant**

**General:** At a minimum, the owner of all small sewage treatment facilities shall engage the services of a Massachusetts Registered Professional Civil or Sanitary Engineer experienced in sewage treatment plant operation during the start-up of the facility and to evaluate the condition of the facility at specified periods.

**Start-Up Services:** The consultant engineer shall be present at the initial clear water hydraulic test of the treatment facilities. Inspection of the operation of the treatment facilities shall continue on a once per week basis for the first two months to explain

procedures to the operator and assist in the actual operation of the plant. A complete sampling shall be conducted every two weeks during the first two months of operation. Inspection of the operation of the treatment facilities shall continue once every two weeks for the next four months to check the operation and discuss operating procedures with the operator. A complete sampling shall be conducted at least once each month during this four-month period.

**Facility Evaluation:** Simultaneously with the permit renewal application at year fifteen following either the initiation of plant operations or any subsequent permit renewal, the permittee shall submit an engineering report to MassDEP for its review and approval. The report, prepared by a registered professional civil or sanitary engineer and with input from the facility operator, shall outline in sufficient detail what modifications (if any) to the facility or other changes are required to insure that the facility can remain in compliance with its groundwater discharge permit and other applicable requirements through the next 5 year permit term and beyond.

### **Licensed Septage Hauler**

**General:** The owner of all small sewage treatment facilities, not equipped with sludge processing equipment, shall engage the services of a qualified individual or firm for the removal and transport of waste sludge to an appropriate off-site sludge treatment and disposal facility.

**License:** The person so engaged shall be properly licensed by the Board of Health of the municipality in which the small sewage treatment facility is located in accordance with 310 CMR 15.000 and M.G.L. c. 111, §31A.

**Disposal Location:** Waste sludge shall only be disposed of at an approved treatment and disposal facility. The location and method of disposal and appropriate restrictions shall be included in the contract.

**Pump-Out Records:** Copies of all receipts for sludge pump outs along with a certification that volume of sludge has been received at the approved disposal facility shall be submitted to MassDEP and the local Board of Health. Such receipts shall indicate the date of pump-out, volumes pumped and the date and location of disposal.

### **Approved Sludge Treatment and Disposal Facility**

**General:** The owners of all small sewage treatment facilities, not approved for on-site sludge disposal, shall obtain the written approval of a fully approved and permitted facility for the disposal of waste sludge.

**Approval Required:** As part of the O&M Plan, a primary and secondary plan for sludge disposal must be outlined.

### **Approved Laboratory**

**General:** a MassDEP certified laboratory shall perform all analyses for compliance monitoring at small sewage treatment facilities. All monitoring and sampling shall be conducted in accordance with the procedures contained in the latest edition of “Standard Methods for the Examination of Water and Wastewater”.

**Certification:** Any laboratory used for water or wastewater analysis shall be certified by MassDEP pursuant to the Safe Drinking Water Act.

**QA/QC:** The laboratory shall have a Quality Control - Quality Assurance Program approved by MassDEP.

## **IV. CALCULATION OF WASTEWATER FLOW**

The wastewater design flow is used to determine whether the project is subject to the requirements of the State Environmental Code (Title 5) – 310 CMR 15.000 or the Groundwater Discharge Permit Program – 314 CMR 5.00. The design criteria outlined in 310 CMR 15.203 are used. The estimated maximum contributory population for the entire development should be used. In the case of phased projects, the existing as well as all planned future phases shall be included. If the calculated flows are less than 10,000 gallons per day (gpd), the system can be designed in accordance with Title 5. If the flows are greater than 10,000 gpd, then the requirements of the groundwater discharge permit program govern.<sup>1</sup>

If the project is subject to the requirements of the groundwater discharge permit program, there are several different methods that may be used to evaluate wastewater flows for designing treatment unit processes, as follows:

1. **Actual Flows:** In some cases, actual water use/wastewater flow data is available for the facilities to be served by the proposed wastewater treatment plant and groundwater discharge. Where there is an adequate historical record of actual flows (minimum of 1 year) at existing facilities at full occupancy, data on average flows, maximum monthly flows, and peak flows may be used for the design of wastewater treatment works.
2. **State Environmental Code (Title 5):** Where no actual flow data exists for facilities to be served from the proposed treatment works, this is the standard method for calculating the design flow. The plant design and the disposal area are based upon the estimated flows as contained in 310 CMR 15.203. This value is equivalent to the estimated flow for the proposed use plus a factor

---


<sup>1</sup> WWTFs may be allowed for flows less than 10,000 gpd provided it is demonstrated, to the satisfaction of the Department that the financial burden associated with the operation, maintenance and replacement of such a facility can be borne by the users of the system without posing an undue hardship on any individual within the user group.

representing flow variation. It represents the maximum volume of wastewater that the treatment plant and disposal area will receive on any given day.

3. **Metered Flows:** The actual metered flows from known similar establishments may be used as the basis for determining wastewater treatment plant design and disposal area. This method would be most applicable for, but not necessarily limited to, commercial facilities and office parks. In this manner, a flow value, such as X gallons per 1000 square feet for an office park or Y gallons per seat for a restaurant would be established. All proposed flow values must be fully documented by the project proponent. When this method is utilized, the design of the wastewater treatment plant and disposal area shall be based on 200 percent of the average daily meter readings (during periods of peak use) to simulate maximum daily flows.
  
4. **Per Capita Flows:** This method may be utilized when dealing with municipal facilities that tend to be larger, have more diverse flow sources, and have variable flow rates. For residences, per capita rates will be based on water use records, assuming 80% of water consumption is discharged as wastewater. If such records are not available, a reasonable assumption for wastewater flow is 70 gallons per capita per day (gpcd). For commercial, industrial, recreational and institutional sources, flow rates will be based either on actual use or similar facilities. An allowance for infiltration will be added, typically 500 gallons per day per inch-diameter mile (gpd/in-mi) for new systems. The summation of these flows will yield the average daily flow. Maximum daily flows will be calculated in accordance with Figure 1. (Note: This is the Merrimack Curve contained in TR-16). The wastewater treatment plant will be designed to handle both the average and maximum day hydraulic flow and maximum organic loading/wastewater strength, since in this instance certain unit operations/processes may be more sensitive either to the average or maximum day flow or high strength wastes. The disposal area will be evaluated and sized for both the average daily and maximum month flows, since the concern is whether the site can adequately accept variable flows.

When developing the groundwater discharge permit, the manner in which the flow limits are described will vary with the method used to develop flows. Most permits are written with a “not to exceed” flow limit. That language is generally appropriate when the flows are derived using either the Title 5 or metered flows method since we have only a single value that accounts for all flow variations. When the per capita method is used, the permit will contain two flow limits, one for the average and one for the maximum day flow. Depending on the particular situation, the average limit could represent an annual average value, or, such as the case where the system experiences significant infiltration during high groundwater periods, it could be the average flow during the maximum month.

Final



**FIGURE 1**

AVERAGE DAILY DISCHARGE OF DOMESTIC SEWAGE MGD  
RELATION OF EXTREME DISCHARGES ON MAXIMUM AND MINIMUM DAYS  
TO THE AVERAGE DAILY DISCHARGE OF DOMESTIC SEWAGE  
( FROM MOP9 - SEWER DESIGN & CONSTRUCTION )  
ASCE & WPCF

## MERRIMACK CURVE

### V. INFILTRATION/INFLOW & SEWER SYSTEM MANAGEMENT

Infiltration/Inflow (I/I) is extraneous water entering the wastewater collection system through a variety of sources. Infiltration is groundwater that enters the collection system through physical defects such as cracked pipe/manholes and deteriorated joints. Typically, many sewer pipes are below the surrounding groundwater table, therefore leakage into the sewer (infiltration) is a broad problem that is difficult and expensive to identify and remove. The rate of infiltration is generally higher in the spring when groundwater levels are at the maximum. Inflow is extraneous flow entering the collection system through point sources. It may be directly related to stormwater runoff from sources such as roof leaders, yard and area drains, sump pumps, manhole covers, and cross connections from storm drains or catch basins. Other potential sources include non-storm related point sources such as leaking tide gates, cooling-water discharges, or drains from springs or swampy areas. Because inflow enters a collection system through point sources, it is generally easier and more cost-effective to identify and remove than infiltration.

High levels of I/I reduce treatment and pipeline capacity that would otherwise be available for sanitary flow. The result, during extreme storm events, could be sewer surcharging, back-up of sewage into homes and businesses; local overflows of untreated sewage, treatment plant bypasses, and inadequate treatment of sewage. I/I also results in the transport of groundwater and surface water out of the natural watershed, which may adversely impact groundwater and surface water resource areas.

MassDEP has wide authority over sewage collection and treatment facilities, including regulatory responsibility for sewer surcharging and overflows caused by I/I. These powers include the ability to issue enforcement orders to reduce I/I, including specific schedules and corrective measures to reduce I/I quantities. Additionally, many groundwater discharge permits will contain a special permit condition relating to the management of Infiltration/Inflow. For communities, the standards for performing I/I reduction projects are incorporated into Department guidance most recently issued in 1993. The Division of Municipal Services can be contacted for copies of the latest guidance.

In order to minimize the impacts of I/I, there are 7 overall goals that should be followed:

1. Eliminate all sewer system backups
2. Minimize, with a long-term goal of eliminating, health and environmental impacts of sewer system overflows related to I/I
3. Remove all (and prevent new) inflow sources from separate sanitary systems
4. Minimize system-wide infiltration
5. Educate and involve the public
6. Develop an Operation & Maintenance (O&M) program

For the purposes of this document, special attention should be paid to the development of a proper O&M program. The need for a preventative maintenance program cannot be overemphasized. Such steps include, but are not limited to: record keeping, frequent inspection at chronic problem sites, periodic sewer system inspection, system cleaning, maintenance of pump stations and ancillary facilities, and establishing a sufficient spare parts inventory. In this manner, many problems can be resolved before they occur.

The O&M Program should include documentation of location and ownership of all grease interceptors on the collection system. Animal and vegetable based FOG entering the sewer system is a primary cause of maintenance and capacity problems. The owner/operator of the WWTF should have adequate control over sewer connections that may contribute FOG to the collection system. See Section IX-K for more guidance on FOG control.

## **VI. SITE EVALUATION & SITING CRITERIA**

The site investigation shall minimally include:

- Installation and development of monitoring wells (according to Standard Methods for Monitoring Wells, WSC 310-91); submit well completion form to DEP. Provide soil boring information, Standard Penetration Test and other relevant data. Wells are recommended to be installed with 15-foot screens with approximately 5' above and 10' below the adjusted high groundwater level. This construction may be modified based upon specific site conditions such as suspected seasonal high water level fluctuations. Wells must be able to be secured and constructed so as not to allow infiltration of surface water or runoff. The ability of the proponent to install or demonstrate that wells can be installed in the future to monitor the reserve area shall be required should the need to expand into that area be needed. The monitoring well should locations must be accessible to operations staff year round to perform the required sampling and maintenance.
- Test pits to at least 5 feet below the bottom of the proposed disposal system, including the reserve area. All soil evaluations shall be performed in accordance with the methodology stated in Title 5 – 310 CMR 15.000 and performed by a MassDEP approved soil evaluator or a geologist or other person approved by MassDEP. If bedrock rock is encountered, characterize the bedrock surface. The extent of the characterization shall be based upon observations of the field personnel such as but not limited to the degree of weathering, fracturing, and type of rock. Note if redoxymorphic features or water appear to be at or near this surface at the time of observation. Provide Certified Soil Evaluator (CSE) logs. The number of test pits to be performed shall be in accordance with the approved scope of services but the number could be modified based on the initial site work, subject to MassDEP approval.
- Percolation, infiltration and other testing for the purpose of determining the infiltration rate of the proposed disposal system shall be in the most restrictive layer encountered during the exploration of the test pit by the Certified Soil

Evaluator. If the final design of the system will result in the removal of the restrictive material, the testing mentioned may be conducted in the most restrictive material to remain as the receiving soil. All percolation tests shall be performed in accordance with the methodology stated in Title 5, 310 CMR 15.000.

- Mapping of all surface water, vernal pools (certified or potential) and wetlands.
- Locate seeps, springs or other areas of groundwater reaching the surface.
- Locate public (if discharge is in a Zone II or IWPA or surface water protection zone or within 1 mile) and private water supplies (within ½ mile).
- Locate bedrock at or known to be near the surface. Include a description.
- Perform Infiltration testing by qualified professional (see Appendix B)
- Record initial water levels.
- Survey location and elevation of wells.
- Initial background water quality sampling.
- Hydraulic conductivity testing of wells
- Ground water mound calculations shall be performed based upon the starting groundwater elevation of the 80<sup>th</sup> percentile of the highest estimated groundwater level. A simple desktop calculation or analytical model should utilize data collected from the site investigations.

Based upon site complexity, sensitive receptors or design, MassDEP may require the following items for the site evaluation:

- Additional wells,
- Surface water sample collection and analysis,
- Split spoon logs from borings. At a minimum, the deepest boring shall have a continuous split spoon log,
- Assessment of potential impacts of nutrients (i.e. Nitrogen, Phosphorus),
- Sieve analysis of split spoon samples and/or test pit samples. The results shall include an estimate of the infiltration rate,
- Geophysical investigation methods,
- Scale loading tests,
- Predictive model implementation to determine mounding of system to provide adequate separation between estimated high water and the bottom of the distribution system or bed. Characterization of difference between the mounding material and the native material must be done to account for difference in infiltration rate and preferential flow direction,
- A more sophisticated model may be required based upon sensitive receptor or mound height issues. This would usually require additional fieldwork to provide the additional input data. Usually a greater coverage of data is also necessary then is required for desktop or analytic mounding analysis,
- Evaluation of travel time or other issues of wastewater to water supplies,
- Other information as deemed appropriate and necessary by MassDEP.

## **Plans & Specifications**

Submit with locus map (Topographic Map) and site map (such as plot plan). Show neighboring properties. If not on plan provide notes or figure that shows new structures or important changes.

## **Sampling and Analysis**

A list of all monitoring points (operational and compliance) and the analysis required along with the regulatory limits and methodology shall be submitted. QA/QC plan must be presented in the plan. The complete plan shall be submitted to MassDEP for approval.

Adjustments to observed ground water levels:

The presence of soil mottles (redoxymorphic features) may be utilized if observed in test pit by a qualified individual (CSE, Soil Scientist, P.E., C.E., geologist or Hydrogeologist). The general use of these features shall be based upon commonly acceptable practice. This includes the declaration of high water by frequency of occurrence of these features at specific depth. The absence of these features in certain soil types (such as sand) may not indicate the absence of a seasonally high water table as some soils do not have the capability of producing observable redoxymorphic features. Town and/or U.S. Geological Survey published observation well data may be used according to the methodology set forth in the following publications:

- Frimpter, M.H. 1981, Probable High Ground-Water Levels in Massachusetts: U.S. Geological Survey Water Resources Investigations Open File Report 80-1205.
- Frimpter, M.H. and Fisher, M.N, 1983, Estimating Highest Ground-Water Levels for Construction and Land Use Planning – A Cape Cod Massachusetts Example: U.S. Geological Survey Water Resources Investigation Report 83-4112.

## **Repairs and replacement systems:**

The data requirements shall be the same as the above with the opportunity for the proponent to demonstrate with existing data the requirements above. If infiltration testing data does not exist or utilizes an unacceptable or superceded method or was not witnessed by MassDEP or designee the testing must be performed as for a new system. If loading rates and monitoring data is available, mounding calculations may utilize this data. Reasons for the repair shall be stated and considered should additional data be needed to mitigate the reason for the failure.

**Preferred testing method:**

Soil Description (To be most restrictive encountered and left in place at proposed site)	Classification	Hydraulic Conductivity (Gal/Ft <sup>2</sup> /Day)	Testing Method
Clean Gravel	Gravel	10 <sup>5</sup> to 10 <sup>4</sup>	Percolation Test (Likely to be less than 2 Min./In. See Table 3)
Clean Sand and Sand & Gravel	Sand	10 <sup>3</sup> to 10 <sup>2</sup>	Percolation Test (Probably less than 2 Min./In.) (See Table 3)
Fine Sand	Fine Sand	10 <sup>1</sup> to 10 <sup>-1</sup>	Percolation test or Infiltration test method
Sand with Silt & or Clay	Sandy Loam	10 <sup>-1</sup> to 10 <sup>-3</sup>	Infiltration test method (Possibly greater than 20 Min./In.) (See Table 3)
Sand with Significant Silt or Clay	Loamy Sand or Silt	10 <sup>-3</sup> to 10 <sup>-4</sup>	Infiltration test method (Greater than 20 Min./In.) (See Table 3)

**Distances** - No sewage collection, treatment or disposal system shall be closer than the distances stated to the components listed in Table 2. Please note that these are minimum setbacks and that site-specific conditions may warrant additional distance.

<b>TABLE 2</b>					
<b>MINIMUM ACCEPTABLE SEPARATION DISTANCES</b>					
(FEET)					
<u>Component</u>	<u>Treatment Plant Bldg.</u>	<u>Pump Station</u>	<u>Subsurface Tank</u>	<u>Leaching Facility</u>	<u>Sewer or Force Main</u>
Well					
Public	400	400	400	400 <sup>5</sup>	400
Private	50	50	50	100	50
Water Supply Line	-	10	10	25	10*
Dwelling Unit	50	25	10	25	10

<sup>5</sup> Distance either 400 feet or the 6-month groundwater travel time from the discharge to the public water source, whichever is greater.

Subsurface Drain	-	25	25	25	10
Property Boundary	50	25	10	25	10
Surface Waters	100	50	50	100	50
Downhill Slope greater than one vertical to three horizontal	10	10	10	50	--
Stormwater Infiltration Basins <sup>6</sup>	-	25	25	25	5

\* See design criteria for collection systems.

## VII. EFFLUENT DISPOSAL

**General** - Final effluent disposal shall be by means of properly designed open sand beds, leaching pits, leaching chambers, leaching trenches, drip dispersal or other approved subsurface methods. The use of reclaimed water consistent with Department policies is encouraged. Other methods of discharge may be allowed on a case-by-case basis provided adequate documentation is presented to MassDEP, which demonstrates the expected impact on the environment and hazard to public health resulting from such alternate system. This documentation shall include either the results of a properly monitored pilot test performed with Departmental approval at the proposed discharge site or the results of tests and/or actual experience at other similar locations.

**Reserve Area** - A reserve area tested and shown to be sufficient to replace the capacity of the original leaching area shall be provided. Although it is preferred that a 100% reserve area be provided whenever possible, particularly for smaller facilities ( $\leq 40,000$ gpd), there are instances where this requirement can be modified.

For open sand beds, the construction of a minimum of four (4) basins of approximate equal size can be provided. In this manner, the loading cycle can be adjusted so that one bed is being loaded as the others are drying, while at the same time one of the beds can be taken out of service for required maintenance.

For subsurface facilities, the combination of a proven treatment process providing a high level of treatment and permeable soils may reduce the need for a reserve area, but shall

---

<sup>6</sup> Where stormwater infiltration basins are proposed in proximity to an existing or proposed subsurface disposal system (SAS), the permittee shall provide documentation that no adverse impacts to the performance of the SAS shall result. The analysis should include assessment of stormwater infiltration of a one-year and ten-year design storm, or otherwise based on peak design flows to the basin if flow controls are incorporated into the design.

not result in provisions for a reserve area less than 50% of the size of the designed SAS. Another example is where effluent disposal is accomplished by means of a number of small subsurface leaching facilities that are not interconnected. In this instance, a reserve area equivalent to one field being off-line is possible.

When drip dispersal is used, the drip tubing shall be placed 4 foot on center if the area between the tubing is proposed for reserve.

### **Open Sand Beds**

**Leaching Area** - The leaching area required shall be determined in accordance with the provisions of Table 3. The effective leaching area shall include only the bottom area, not the sidewall.

**Groundwater** - The maximum ground water elevation including mounding shall be no less than 4 feet (1.22 m) below the bottom of the sand bed.

**Number** - The sand bed shall be divided into at least two sections or at least two separate beds of approximate equal size shall be provided. Sections shall be alternately dosed.

**Construction** - All top soils and subsoils shall be removed from the bed area. At least 2.0 feet (0.61 m) of clean sand shall be placed within the beds. Material for the sand beds shall be placed without compaction of the subgrade or the sand itself. Sand shall conform to the following grading limitations, as determined by AASHO -T11 and T27:

<b>Percent by Weight</b>		
<b><u>Size of Sieve</u></b> <b>(Square Openings)</b>	<b><u>Passing Through</u></b> <b>Minimum/Maximum</b>	
1/2 inch	100	---
3/8 inch	85	100
#4	60	100
#16	35	80
#50	10	55
#100	2	10

**Impervious Materials** - Excavations into or fill upon impervious material shall not be allowed. Excavation through impervious material may be allowed if at least 4 feet (1.22 m) of naturally occurring pervious material (as determined by performing a percolation test in the most restrictive pervious layer), remains beneath the lowest point of excavation. All construction after excavation through impervious material shall be in accordance with 310 CMR 15.02(17).

**Surface Drainage** - The grade adjacent to the sand bed shall slope away from the bed at least 2 percent to prevent the accumulation of surface water.

**Excavation** - Excavation may be made by machinery provided that the soil at the bottom of the disposal system is not compacted. The bottom of each bed shall be level.

**Frozen Conditions** - Sand beds shall not be constructed in frozen soil.

**Downhill Slope** - Sand beds shall not be located closer than 50 feet from downhill slopes steeper than one vertical to three horizontal.

**Berms** - A berm of at least 2 feet in height shall be provided around the perimeter of the sand beds.

**Splash Pads** - Suitable splash pads of washed stone, concrete or other appropriate material shall be installed in each bed beneath the outlet pipe to prevent scouring of the bed surface.

**Fencing** - Open sand beds shall be enclosed within a fence of at least 5 feet in height. The fence shall be provided with a locking gate.

**Piping** - All distribution pipe shall be SDR-35 PVC and shall be self-draining to prevent freezing.

**Disinfection** – Must be provided at all times for facility discharges utilizing open sand beds.

**Maintenance Plan** – All open sand beds must have a maintenance plan to ensure that the beds are free of weed and plant growth.

### **Leaching Pits, Chambers and Trenches**

**General** - The criteria listed in 310 CMR 15.251, 15.252, and 15.253 (Title 5) shall be used to design leaching pits, leaching chambers and leaching trenches respectively for use at small sewage treatment facilities, with the following revisions:

- leaching area requirements shall be determined in accordance with the provisions of Table 3;
- maximum ground water, including mounding, must be at least 4 feet (1.22 m) below the bottom of the excavation;
- at least 4 feet (1.22 m) of naturally occurring pervious material is required below the lowest point of excavation; and
- the area between the leaching facilities is allowed to be used as the reserve area.

**Percolation Test vs. Infiltration Test** – The rate of movement of water into the soil is called the infiltration rate. A dry soil may have a very high initial infiltration rate, but as the soil pores become filled with water (saturated) the infiltration rate decreases sharply. In a saturated soil, the infiltration rate is equal to the rate at which water moves through

the soil profile which is the percolation rate. The infiltration rate and percolation rate are critical physical properties of the soil that must be considered when designing and operating a subsurface disposal system. Both of these properties determine the rate at which water can be effectively applied to a soil. A percolation test involves a pre-soak which is intended to saturate the soils, while the infiltration test uses a confining ring which allows constant saturation of the soil being tested. The infiltration test provides a higher degree of control and is preferable in most situations. The results are relatively comparable, but will vary due to the accuracy of the method used. Since infiltration tests provide a more accurate analysis of the saturated acceptance ability than percolation tests, a higher loading rate (with the exception of less than 2 min/in) will be available in Table 3 for sites where infiltration testing has been performed. Examples of infiltration tests include: Double-ring infiltrometer; Guelph Permeameter; and loading tests. Note that a “loading test” may yield a more accurate result as it more closely mirrors actual conditions. Please refer to Appendix B for further discussion of infiltration testing methods.

**Ventilation** – Adequate ventilation is necessary for the proper operation of the facilities. If the facilities are constructed beneath a parking lot then ventilation is required.

**Cover** – Depth of cover over leaching facilities shall be no greater than 3 feet. The facilities can be located below parking lots, if properly vented, or athletic fields as long as there is nothing penetrating the field.

**Disinfection** – Must be provided at all times for new facility discharges utilizing subsurface disposal which are located within a Zone II area, Interim Wellhead Protection Area (IWPA) or an area where private drinking water wells may be impacted. MassDEP may require disinfection for other facilities on a case-by-case basis.

**Maintenance Plan** – A maintenance plan is required to ensure that the area over the leaching facilities is free of tree and shrub growth.

**TABLE 3**

**DESIGN LOADING RATE – GALLONS PER DAY PER SQ. FOOT (GPD/SF)**

**(Using Percolation Testing)**

<b>Percolation Rate</b>	<b>Less than 2 Min/In (mpi)</b>	<b>2 to 5 Min/In</b>	<b>5 to 10 Min/In</b>	<b>10 to 20 Min/In</b>	<b>Greater than 20 Min/In<sup>1</sup></b>
<b>Open Sand Bed</b>	5.0	5.0	4.0	2.0	0.3 (w/regular maintenance)
<b>Leaching Pit</b>	3.0	3.0	2.5	1.5	0.2
<b>Leaching Chamber</b>	3.0	3.0	2.5	1.5	0.2

<sup>1</sup> A maximum percolation test rate of 60 min/in shall be imposed. The Department based upon test data and system design may impose lower loading rates.

<b>Leaching Trench</b>	2.5	2.5	1.5	1.0	0.2 <sup>2</sup>
<b>Drip Dispersal</b>	1.5	1.5	1.2	0.9	20-30mpi: 0.75 30-40mpi: 0.65 40-50mpi: 0.45 50-60mpi: 0.30

**(Using Infiltration Testing)**

<b>Percolation Rate</b>	<b>Less than 2 Min/In</b>	<b>2 to 5 Min/In</b>	<b>5 to 10 Min/In</b>	<b>10 to 20 Min/In</b>	<b>Greater than 20 Min/In<sup>1</sup></b>
<b>Open Sand Bed</b>	5.0	5.0	4.5	3.0	0.3 (w/regular maintenance)
<b>Leaching Pit</b>	4.0	3.5	3.0	2.0	0.3
<b>Leaching Chamber</b>	4.0	3.5	3.0	2.0	0.3
<b>Leaching Trench</b>	3.0	2.75	2.0	1.5	0.25 <sup>2</sup>

**Drip Dispersal**

A drip dispersal effluent disposal system may be used in place of conventional disposal methods. Drip dispersal is a shallow slow rate pressure-dosed system used for land application of wastewater. This type of system uses small diameter piping with drip emitters, and must be preceded by filtering mechanisms, which conforms to the manufacturer’s specifications for the particular emitter used. Effluent must be adequately filtered before distribution through the drip tubing and emitter system. Subsurface drip dispersal networks have the capability of equally distributing effluent at relatively low application rates over the entire absorption area with the goal of preventing saturation of the soil. Wastewater is applied at a controlled rate in the plant root zone. Shallow placement of the drip emitter lines has an added benefit which is to allow for enhanced evapotranspiration and plant uptake of effluent as compared with conventional subsurface dispersal systems.

The unique feature of drip dispersal networks is the use if uniformity spaced drip emitters that are inserted within flexible tubing to control the rate of wastewater discharges out of the tubing through small orifices. This method of application of the wastewater to the

<sup>2</sup> Leaching trenches may require additional restrictions and a significantly lower rate. More stringent treatment standards may be required if this method is selected.

native soils maintains an unsaturated flow condition and enhances the retention time in the soil for optimal treatment. Drip line is installed directly into the soil without aggregate or other media. When used as a method of delivering treated wastewater to the final treatment medium it is referred to as drip dispersal rather than drip irrigation. Drip dispersal is seldom designed to meet the watering requirements of the covering vegetation but instead its primary focus is to maximize infiltration of water into the soil.

### **Pressure Dosing**

The pressure-dosing component of a drip dispersal system includes the dose chamber, pumps, control switches, filters and electrical panels. The function of the dosing component is to serve as a storage system to hold the effluent until it's dosed into the drip fields or zones. This component provides flow equalization, a method of delivering the wastewater to the final dispersal component and emergency storage during periods of pump failure or electrical outage. While no specific treatment process is associated with this device, it plays an important role by providing storage and a means of discharging effluent in uniform doses over the 24-hour design period. Small, evenly spaced doses throughout the day, contribute to enhanced performance and longevity in the final treatment and dispersal component by providing regular resting cycles between doses. Flow equalization is one of the main goals of the design and operation of a drip dispersal system.

### **Drip Dispersal**

The drip dispersal component consists of parts and devices such as zone control valves, common supply and return lines, drip tubing, drip emitters, supply and return manifolds, check valves, and air release valves/vacuum breakers. System configuration is dependent on site and soil characteristics. Alternative layouts such as looped systems, zone loading with equal and unequal configurations, split zones, and zones with sub headers on steeper slopes are readily adaptable to most sites. Consult with the manufacturer to assess what if any variations on the basic zone layout may be appropriate for your site.

### **Drip Tubing & Zones**

The drip tubing is normally a ½-inch diameter flexible polyethylene tube with emitters attached to the inside wall of the tubing. Emitters are typically evenly spaced at 2 feet on center but can be ordered with alternate spacing intervals. Drip tubing commonly comes in 500 and 1,000 foot rolls. Normal installation depth for drip tubing is 8" to 12" but may be installed deeper if desired for frost protection and if adequate suitable soils are available. Shallow installation is one of the advantages of drip tubing technology. Tubing installed in the active root zone provides water reuse for plant watering needs and during the warm season, takes advantage of evapotranspiration opportunities. The tubing is typically installed at 2 feet on center throughout the drip zone but other common practices have them placed 1-3 feet apart horizontally depending on soil texture and site conditions. In wooded sites the average on-center distance can be greater. A 3 feet

spacing is sometimes recommended on very steep (25% to 30%) slopes to allow adequate distance between tubing runs for the water to infiltrate before impacting the next downslope drip tube. Consult with the manufacturer to determine the most desirable spacing of the tubing based on soil texture, slope and soil conditions at a particular site. Spacing of emitters closer together should not change the footprint of the area required based on soil loading rates established by the soil evaluation. The tubing is installed along the contour with each run laid as level as possible. A run is defined as a single length of drip line installed along the contour. A lateral is defined as a run or series of runs extending from the supply manifold to the return manifold in a single dispersal zone. Typical installation of the tubing is with a vibratory plow or trencher, which creates very little disturbance to the surface area. Drip zones are a group or set of laterals, which operate independently of the other zones in the component. The number of drip zones required is dependent on the amount of tubing needed for the project, the equipment specified and the general desire to have smaller zones.. Zones may be equal or unequal in size. Equal zones will have the same number of emitters and therefore the same dosing rate to each zone while unequal zones will have varying numbers of emitters and have different dose rates for each zone. Unequal zones are used to “fit” a zone to the available space. Because each zone is completely independent of all the other zones they do not need to have the same number of emitters or length of tubing. The amount of wastewater applied per emitter will be the same no matter what size the zone is. The drip dispersal component is divided into enough zones to make the use of smaller horsepower pumps practical and economical. Multiple zones also adds some flexibility for operation of the system by providing the opportunity for complete resting of a zone if the soil becomes saturated or a malfunction occurs that requires some time to repair. The dose controller rotates the doses between the zones. Zones may be dosed individually or dual zone dosing can be employed. No treatment of the wastewater can be attributed to the drip tubing; effluent quality requirements must be addressed prior to final dispersal or in the soil after dispersal. Drip tubing’s function is to distribute the effluent as evenly as possible over the suitable soil area.

## **Emitters**

Drip emitters are designed to create a high head loss between the in-line pressure of the drip line and the outlet orifice in the drip tubing wall. The pressure loss created, controls the pressure at the emitter so that the discharge is maintained within a desired range. Each emitter acts as a point discharge, which releases water at a rate nearly equal to the discharge rate from other emitters in the same drip line. Drip tubing is available with two types emitters: pressure compensating, and turbulent flow non-pressure compensating.

### **Pressure Compensating Emitters**

This emitter style is designed to maintain a constant discharge rate over a range of pressures from 5 to 70 psi. Pressure compensating emitters are available for nominal flow rates ranging from 0.4 to 1.0 gallons per hour depending on the manufacturer. A usual design discharge rate for pressure compensating emitters is 0.60 gallons per hour. A pressure compensating emitter designed for use with wastewater uses an elastomeric diaphragm or disk placed over a turbulent-flow labyrinth to reduce variable inlet

pressures to a constant outlet pressure resulting in uniform flow rates on both sloping and level sites. The advantage of using drip tubing with pressure compensating emitters is that the laterals can be run longer distances (up to 300') and are more adaptable for installation sloping sites than tubing with non-pressure compensating emitters. The disadvantage is the tubing is more expensive than non-pressure compensating emitter tubing.

#### *Turbulent Flow, Non-Pressure Compensating Emitters*

With non-pressure compensating emitters the discharge rate will vary with the in line pressure. Angles in the emitter flow path are designed to cause turbulence in order to equalize flow between emitters and keep the emitters clean. The recommended operating pressure for this emitter is 10 to 45 psi. Emitters installed at different elevations will have variable discharge rates; lower emitters will have a higher discharge rate than emitters located at higher elevations. A typical flow rate in tubing with turbulent flow emitters is 1.30 gallons per hour at 20 psi. Because of the variable flow rates at different pressure the use of a pressure-regulating valve is recommended when there is a difference in elevation of 6 feet or more between the highest and lowest lateral in a zone. The maximum flow variation between any two emitters in a single zone should not exceed 10 percent. When determining flow variation consideration should be given to the effect of "drain down", an effect which occurs in the field laterals after the pump shuts off that results in unequal distribution and excess flows in the runs of pipe placed at the lowest elevation. Lateral lengths should also be kept under 200' to maintain the pressure differential across the drip lateral within a tolerable range. Non-pressure compensation emitters are generally less expensive than pressure compensating emitters.

#### **Zone Valves**

Zone valves recommended for use in small community flow applications are electrically actuated valves. The zone valve is used to control the flow to each zone. Solenoid zone valves are typically in a closed position until the dose controller activates the valve during a routine dosing event. When the controller starts a dose cycle the pump is activated and one or two zone valves are simultaneously opened to discharge the dose to the designated zones. The zone valve requires a structure for access and maintenance purposes. For smaller systems, the structure is typically buried and insulated to provide frost protection; removable lids at the surface are provided for access for maintenance purposes while for larger systems the components are often placed inside the treatment facility building. Typically the zone valve is positioned higher than the highest lateral in a zone and equipped with an air release valve to allow for the drainage of water away from the valve after each dose.

#### *Air Release/Vacuum Breaker Valves*

The air release/vacuum breaker valve is one of the most crucial parts of the drip dispersal component. Air/vacuum breakers are installed at high points in the zone to aid in pressurization of the zone and at pump shut off to keep soil from being sucked into the emitters due to back siphoning or back pressure and to allow the water to readily drain out of the supply and return manifolds and into the drip laterals after each dose. Each

zone requires two air/vacuum valves, one on the supply side and one on the return side. The air release/vacuum breaker valve is located in a small meter box or manufacturer supplied housing structure with sufficient space to provide airflow around the valve and an access point for periodic maintenance.

#### *Drainage During Depressurized Flow*

When the pump shuts off, the remaining effluent in the drip lateral and manifolds will drain out through the emitters. On sloping sites and to some extent on level sites, it will flow via the tube and manifolds to the lowest point where it will flow out the emitters. If the tubing is not laid out generally level, this may cause severe overloading and breakout on the ground surface especially in larger systems and on slowly permeable soils. Things that can be done to minimize this from happening are: Keep each zone as small as is reasonable and use a small compressed horizontal manifold with small diameter pipes extending to the drip laterals. This compressed manifold isolates drip laterals from one another as it is normally placed on the up slope side of the zone. The isolated lines supplying effluent from the manifold to the drip laterals prevents drainage of the manifold to the lower drip laterals. Isolate each lateral by having the PVC feeder tubing for each lateral pass over an elevated berm between the manifold and beginning of the tubing to reduce gravity flow out of the lateral. In looped systems, elevating the loop will keep the effluent in its respective run. Determine a sufficient dose volume so that the percentage of effluent which drains by gravity is small compared to the amount delivered while the laterals are fully pressurized. Use a bottom-loading supply manifold with check valves installed before each lateral to prevent residual water from flowing down the slope. The return manifold should also have check valves to prevent water flowing down the slope during drainage. In addition the supply and return manifolds can also be drained from the bottom of the field back to the pump tank. This prevents effluent from draining into the drip laterals and returns it back to the tank to be dosed again during the next event.

#### **Soil**

The soil is the ultimate receiver of the wastewater and the most important part of the drip dispersal component. It is also the most variable and must be carefully evaluated. The discharged wastewater moves through the soil vertically and/or horizontally. The area footprint of each drip dispersal field depends upon the horizontal and vertical acceptance rate of the soil. Determine the rate through perc test or such field test methods as a double ring infiltrometer. Because drip tubing is installed directly into the soil without any use of aggregate to help spread out the wastewater flow, the wetting pattern observed with drip tubing is different than in other soil absorption systems. In most soil types there will be a small zone of saturation immediately around each emitter. The wetted volume from one emitter should approach but not exceed the distance to the boundary of the wetted volume from adjacent emitters in the same drip line and to the emitter in adjacent drip lines. The wetted volume in clayey soils depends mainly on capillary forces while gravitational forces have a greater effect in sand soils. Soils with high clay content may not be suitable depending on the test results. Soil samples must be analyzed using a method suitable to determine the clay fraction if a high clay component is suspected. A larger lateral spread

of the wetting front typically occurs with increasing fines and or higher drip rates. After discharge from the drip tubing wastewater must flow through an unsaturated zone for final treatment prior to discharge to the groundwater. In a properly functioning system all wastewater applied over the footprint of the dispersal component must leave the system, therefore the flow rate of the applied wastewater must be equal to or less than the flow rate in the unsaturated zone. Water in the underlying saturated zone also must continue to move away from the system until it is dispersed into the environment or the soil will become saturated back to the point of application and ultimately result in system failure. At some point away from the system all the wastewater is assimilated into the environment such that it is not detectable or will not influence the system operation. This is called the system boundary. System boundaries are located both horizontally and vertically away from the drip dispersal zones. The boundary could be, but is not limited to, restrictive soil layers, a surface water discharge point, change in slope, and area of convergent flow in the landscape or the groundwater surface. The system boundary for each system is determined during the detailed site evaluation as described later in this manual.

## **Performance**

The factors that determine good performance from a drip dispersal system include:

- Consistent effluent water quality in accordance with the limitations in the groundwater discharge permit and the manufacturer's recommendations. A thorough and competent investigation of the site and soil conditions
- A design based on loading rates carefully matched to the soil and site conditions
- Use of a site specific engineered design
- Competent construction practices including on-site construction assistance by the manufacturer, no compaction of wet soils, and system start-up by the manufacturer.
- Adequate operation and maintenance procedures

One method of determining if the drip dispersal zones are performing as expected is to install soil moisture sensors. Soil moisture sensors placed in the drip zones can provide a signal to the operator when and if saturated soil conditions are present due to the application of greater flows than the soil is capable of transmitting away from the zone. This device provides a warning of soil wetness and allows the operator to remove a zone from the dosing rotation for a short period of time or reduce the volume per dose to that zone to a rate more compatible with soil acceptance rate. Other than moisture sensors, the performance of the drip dispersal component can be determined by visual observation of the ground surface. The surface over the drip laterals should be dry and no surfacing of the effluent should be visible if the application rates are matched correctly to the soil conditions at the site.

## **VIII. GENERAL REQUIREMENTS FOR TREATMENT PLANTS**

### **A. TREATMENT REQUIREMENTS**

All groundwater discharge permits will be issued a set of effluent limitations that are specific to the particular site. As a general rule, MassDEP shall apply the more stringent of: the water quality based effluent limitations under 314 CMR 5.10(3); the technology based effluent limitations under 314 CMR 5.10(4); or the additional and more stringent requirements related to specific discharges as outlined in 314 CMR 5.10(4A), (4B) and (4C).

Note that there are circumstances under which even more stringent limitations may be required. Knowledge of downgradient uses and impacts is critical to making the proper decision on treatment requirements. Such situations include, but are not limited to, discharges that will impact a Zone II or IWPA, projects incorporating wastewater reuse, and nutrient (nitrogen and/or phosphorus) sensitive areas.

Those facilities which seek coverage under a General Permit in accordance with 314 CMR 5.13 and which are granted said coverage shall be subject to the terms and conditions of the specific General Permit and any special conditions imposed by MassDEP within its approval letter granting coverage such as, but not limited to, the maximum daily flow.

1. **General Permit Limitations:** All General Permits issued by MassDEP in accordance with 314 CMR 5.13 are effective for a period of time not to exceed five (5) years. General Permits will include limitations and conditions necessary to insure the maintenance of groundwater quality and will be specific to the nature of the facility discharging. General Permits for those facilities discharging only sanitary sewage will typically limit BOD<sub>5</sub>, suspended solids, pH, oil and grease, total nitrogen and nitrate nitrogen. Such limitations shall apply to the end of the pipe or the outlet.
2. **Individual Groundwater Permit Limitations:** Unless otherwise stated, all groundwater discharge permits will include limitations and conditions necessary to insure the maintenance of groundwater standards as discussed in 314 CMR 5.11, and any such limitations shall apply to the end of the pipe or outlet. The effluent limitations contained in the permit typically will consist of the following: BOD<sub>5</sub>, suspended solids, pH, oil and grease, total nitrogen and nitrate nitrogen. Other pollutants may be included on a project specific basis.
3. **Disinfection:** Where required in an individual Permit and/or where there is reclaimed water, in accordance with 314 CMR 20.00 is , the permit limitation may vary based on the circumstances of the discharge. A permit limitation of 200 fecal coliform per 100 ml is required for Class C reclaimed water as defined by 310 CMR 20.17(3). Class B reclaimed water must meet a median of 14 detectable fecal coliform colonies per100 ml over 7 continuous 7-day sampling periods, not to exceed 100/100 ml in any one sample. The most stringent fecal coliform limit for Class A reclaimed water is a median of no

detectable colonies per 100 ml over continuous, running 7-day sampling periods, not to exceed 14 colonies per 100 ml.

4. **Enhanced Nitrogen Removal:** In order to maintain groundwater quality standards, the end-of-pipe effluent limitation for all non-reclaimed water discharges, with the exception for facilities covered under the General Permit for commercial carwashes, for both total and nitrate nitrogen is less than or equal to 10 mg/l as max day. In some cases, nitrate/total nitrogen limits will be reduced further where drinking water supplies are at increased risk, where nitrogen sensitive areas may be impacted, or where wastewater reuse is envisioned. Once the hydrogeologic study has determined the area impacted by the discharge, the sensitive receptors within that impact area will be identified and evaluated and the type of permit, individual or general, required will be identified.
5. **Phosphorus Removal:** The regulations do not contain a limit for phosphorus. As opposed to nitrogen, phosphorus is not as mobile and frequently adsorbs to soil particles due to chemical and electrostatic bonding. Consequently, phosphorus has not generally been regulated in groundwater discharge permits. However, it is the limiting nutrient for unwanted aquatic growth in inland waterways. There has been substantial recent evidence that, under certain conditions, the ability of the soil to adsorb phosphorus is finite and that it could migrate and reach sensitive receptors. The location of sensitive receptors within the plume area shall be identified and the potential impact of phosphorus will be evaluated on a case-by-case basis. If phosphorus removal is necessary, MassDEP in consultation with the permittee will determine the required effluent limit. Unless otherwise notified in writing by MassDEP, all permittees shall be required to report to MassDEP phosphorus concentrations in the effluent and in the monitoring wells on a quarterly basis.
6. **Wastewater Reuse:** MassDEP has developed regulations at 314 CMR 20.00 outlining how the use of reclaimed water is regulated in Massachusetts. At this time, the following uses are allowable: indirect recharge of aquifers through discharge to an Interim Wellhead Protection Area (IWPA) or a Zone II; toilet flushing; irrigation; any discharge within 100 feet of an irrigation well; landscaping; cooling water; car washes; industrial process water; snowmaking; fire protection; creation of wetlands and recreational impoundments; agricultural uses; dust control; soil compaction; concrete mixing and aggregate washing; street cleaning, industrial boiler feed; and silviculture. Additional approved uses may be added in the future. Please check with MassDEP whether a proposed use is allowable and for the associated effluent limits.
7. **Zone II or Interim Wellhead Protection Area (IWPA):** Discharges into a Zone II or IWPA are referenced in the Reclaimed Water Regulations at 314 CMR 20.00. The treatment plant reliability requirements are described in the regulations. The regulations require that MassDEP's NO<sub>3</sub> loading model, or

equivalent, must be run and submitted as part of the hydrogeologic report submittal.

8. **Nutrient Loading Approach:** MassDEP has developed regulatory conditions applicable to those facilities that were formerly covered under an interim policy entitled “Nutrient Loading Approach to Wastewater Permitting and Disposal” and for proposed facilities where extensive land area provides the opportunity to apply pollutant loadings over a large area. These regulatory conditions permit a mixture of treatment technologies to achieve a site-wide nutrient loading limit, rather than simply a single wastewater treatment plant with a nitrate and total nitrogen end-of pipe effluent limit  $\leq 10$  mg/l.

## **B. GENERAL WWTF REQUIREMENTS**

All facilities must be designed to treat the wastewater produced by its users. The characteristics of the wastewater may vary per site and the designer should be aware of activities that potentially could introduce high strength and or toxic components to the flow, but typical influent values for medium strength sanitary wastewater are as follows:

- BOD<sub>5</sub> – 200 mg/l
- Suspended Solids – 200 mg/l
- Total Nitrogen – 40 mg/l
- Total Phosphorus – 7 mg/l

The engineering report and the subsequent submittal of design plans must demonstrate that the proposed treatment works are capable of achieving the following general requirements:

- The means to adequately regulate hydraulic and pollutant loading to each process unit
- Sufficient treatment capability to fully oxidize BOD and remove TSS of wastewater of the concentration and strength proposed
- Sufficient treatment capability to fully nitrify and denitrify wastewater of the concentration and strength proposed
- Means for adequate solids handling and removal
- Means for ensuring effluent turbidity concentrations suitable for disinfection and possible future reuse, and
- Adequate access to all major process unit components to facilitate routine inspection and preventative maintenance

To achieve these general requirements, most technologies should incorporate the following process components:

1. **Building Requirements** – A building shall be constructed at the site of all wastewater treatment facilities. Some buildings will contain the entire treatment system, minus outside tankage such as pretreatment and flow equalization tanks. Other buildings will house only pumps, blowers, chemical feed equipment and electrical controls. Design plans shall allow for sufficient clearance (horizontal and vertical) around all process units to allow for routine inspection and servicing.
  
2. **Aerobic Treatment** – Most designs incorporate some form of fixed film or suspended growth treatment to reduce BOD and convert ammonia nitrogen to nitrate (nitrification). To accomplish this, these units must be sized to provide sufficient contact time for the following biological actions:
  - a. Initial reduction of BOD to 15 mg/l.
  - b. Subsequent reduction of ammonia levels to less than 1.0 mg/l.

The contact time required may vary seasonally, depending on metabolic rates. For this reason, the design must reflect the contact time needed when metabolic rates are lowest. Design calculations for fixed substrate processes must include the estimated total media surface requirements needed to achieve complete nitrification. All covered units must be equipped with adequate service hatches (preferably hinged) to facilitate routine inspection and servicing of the media and mechanical components, and shall have the ability to control temperature in the treatment units to provide conditions sufficient for effective reduction of BOD and nitrification. Provisions for alkalinity to the treatment system should also be provided to enhance the treatment process.

3. **Anaerobic Treatment** – Designs must provide adequate contact time and conditions to allow micro-organisms to reduce total nitrogen levels below 10 mg/l. Since these technologies generally employ anaerobic micro-organisms to denitrify wastewater, the design must ensure that the dissolved oxygen level of the wastewater entering the anaerobic unit is below 0.5 mg/l and that the range of pH is close to 7. Some designs must also provide for addition of a carbon source to promote denitrification. In other designs, denitrification is achieved in a pretreatment tank to take advantage of available carbon. When this approach is used, care must be taken in the design to ensure that the sidestreams entering this process unit do not disrupt anaerobic conditions needed to maintain this treatment. All covered units must be equipped adequate service hatches (preferably hinged) to facilitate routine inspection and servicing of the media and mechanical components, and shall have the ability to control temperature in the treatment units to provide conditions sufficient for effective denitrification.

4. **Filtration** – In many instances, filtration is needed to reduce suspended solids in final effluent prior to final disinfection, disposal and/or reuse. Commonly used filtration devices include sand filters, cloth filters, and membrane filters. Most employ a backwash cycle generating a waste sidestream that must be accounted for in sizing other treatment process units affected by the recirculation.
5. **Sludge Removal** – All technologies must demonstrate capability for adequate sludge removal and storage. Solids must routinely be removed from primary tanks, FETs, and clarifiers. All covered process units must be equipped with service hatches to allow for inspection and removal of sludge. Also, process unit floors should be sloped to a sump or collection area directly below a service hatch to aid sludge removal practices. Most technologies should provide a central sludge holding tank sized for temporary storage for up to six months. The size and/or treatment scheme will dictate the level of sludge processing. Smaller plants may only require the ability to periodically remove liquid sludge, while some larger plants or those with more complex treatment schemes could require thickening and/or dewatering.
6. **Interior Construction** – The structure shall provide heat, water and protection from the elements. The building shall be constructed of moisture-proof materials.
7. **Siting** – The treatment plant building shall be located as far as possible from built-up areas to prevent nuisance odors and noise. The site shall be located outside the 100-year flood level. The treatment plant should provide for uninterrupted operation of all units under flood conditions of a 25-year frequency and should be placed above or protected against structural and equipment damage from the 100-year flood level. All first floors, tank walls, motors, electrical panels and structural openings should be higher than the 100-year flood level. Flood proofing (e.g. stop logs at garage entrances, raised motor drives and pumps, and adequate structural strength to buildings) shall be provided to above the 100-year flood level. All facilities should be constructed outside of coastal velocity flood zones. A paved and accessible roadway shall be provided. The chemical storage area shall have a paved access way and accessible in the winter.
8. **Electrical** – All electrical controls shall be located in a separate room from the process treatment units to prevent malfunction due to contact with moisture or corrosive gases. In the event that electrical controls cannot be located in a separate room then dehumidification shall be required. Electrical fixtures shall be non-corrosive, moisture-proof and possibly explosion proof. The use of PVC electrical conduits is strongly suggested. Electrical equipment in enclosed places, where gas may accumulate, shall comply with the National Electrical Code requirements

for Class I, Group D, Division I locations and Section 820 of the National Fire Protection Association, Standard for Fire Protection in Wastewater Treatment and Collection Facilities (NFPA 820)..

9. **Ventilation** – Ventilation shall be provided for all treatment buildings. If the building contains process treatment units, ventilation in the process area shall be consistent with the requirements of OSHA and NFPA 820. An automatic timer with light switch override shall be provided. Ventilation for the office/laboratory, electrical control room, generator room and restroom shall be sized on the basis of at least five air changes per hour. Heating is required. Dehumidification is strongly suggested so as to provide protection to treatment units and ancillary controls and appurtenances. Air vents from underground sludge or holding tanks shall all be separate and located in an area to minimize dispersal of odors. Fresh air intakes should be located away from processes or equipment that may generate hazardous gases.
10. **Chemical Storage** – There shall be spill containment under or around the barrels or drums containing any chemical. The containment shall be designed to handle 110 percent of the chemical kept at the facility. A Material Data Safety Sheet (MSDS) shall be posted on the wall near the chemical and at a central location remote from all hazards. Hazardous chemicals (i.e. gaseous chlorine or methanol) shall be stored in enclosed rooms with access from the exterior of the building only. Doors for the chemical storage area shall open outward and shall be equipped with panic bar openers. All methanol drums shall be grounded. Fire protection (sprinklers) to be provided where the volume and type meet fire protection requirements (not all chemical areas). If chemicals are stored in the building, heat is recommended (may not be necessary for dry chemicals and certain acids – review with design engineer).
11. **Potable Water** – All buildings, whether they contain process treatment units or not, shall contain a potable water source. An approved backflow prevention device in accordance with 310 CMR 22.00 shall protect the potable water supply to the treatment plant. Hose bibs and floor drains are recommended for cleaning. At a minimum, a sink and eye wash station shall be present at all wastewater treatment facilities. An emergency shower is recommended, particularly if hazardous chemicals are present.
12. **Safety Equipment** – In addition to the eye wash and shower required with the potable water, all buildings shall also be provided with a first aid kit and fire extinguisher, emergency lighting, proper signage and smoke and fire detectors. All necessary personal protective equipment (safety harness, life rings, safety glasses, gas monitors, etc.) shall be provided and clearly labeled and accessible.

13. **Spacing** – Pumps, blowers, and other component parts of the treatment plant shall have adequate spacing around the units to provide the operator with ample room for maintenance and repair. A minimum of seven (7) feet, six (6) inches of headspace shall be provided above all units. A minimum aisle width of thirty-six (36) inches shall be provided. All drains, valves, cleanouts and sampling ports shall be readily accessible to the plant operator. UV disinfection bulbs that require a lateral removal shall have ample room to remove the bulbs.
14. **Equipment Removal** – Provisions should be made for removing all equipment from the building. Access openings, hatches, and/or skylights should be sized accordingly. Portable or permanent hoisting devices should be provided as necessary.
15. **Ladders and Guard Rails** – Any treatment plant unit that requires a ladder to access the top of a unit for repair or maintenance (i.e. the tops of clarifiers and sand filters) shall have an inclined ladder with handrails or flat catwalk from nearby units. If a vertical ladder is proposed, then it should be in accordance with OSHA standards. All open tanks with walls less than 42-inches above grade shall have a guard rail installed around the entire perimeter.
16. **Alarms** – Alarms shall be provided for all equipment to signify pump failures, power outages and other process malfunctions. There shall be a visual light alarm on the outside of the operations building. High-level alarms should be installed in areas subject to flooding. Please see the chapter on Instrumentation Guidance for additional detail.
17. **Flow Measurement** – The facility shall contain a flow meter that continuously (electronically) records the effluent discharging to the ground on a daily basis. The flow meter shall have a recording device so flow measurement can be taken on weekends when operators are typically not present
18. **Alternate Power Source** – All treatment units shall be equipped with an alternate electrical supply or a permanently installed standby generator sized to operate all electrical components including, where feasible, remote pumping stations. The secondary electrical source must be equipped with a transfer switch that will automatically activate upon a prolonged interruption of the primary electrical supply. Equipment start-up after power interruption shall be sequenced. Generators must be provided with fuel sufficient for at least two days of operation. Portable generators and gas-powered pumps are not acceptable substitutes, with the exception for small pumping stations.

19. **Spare Parts** – An inventory of high wear parts such as bearings, belts, gears, links, relays and starters shall be maintained at the treatment facility. A dated listing of those spare parts maintained on-site shall be placed in a prominent place in the wastewater treatment facility building and updated as applicable.
20. **Redundancy** – Multiple treatment units shall be provided whenever the average daily flow exceeds 40,000 gpd and shall include the biological processes and clarifiers. Each unit shall be designed for equal proportions of the design flow. The treatment plant shall be capable of operating at 100 percent of the design flow without violating its discharge limits with any one unit out of service. In no case shall the organic or hydraulic loading to remaining units exceed the peak rates specified in the following sections of this document. This could involve sizing tankage and mechanical equipment for the extreme flow variations over the course of the year. Redundancy may also be required on a case-by-case basis for facilities under 40,000 gpd if the discharge is subject to the reclaimed water regulations of 314 CMR 20.00.
21. **Flexibility and Recycling Provisions** – When treatment facilities are designed with parallel process trains or multiple alternating components, designs shall also include interconnected piping to provide flexibility between all units (as example, modifying flow from parallel mode to series). This allows for a process unit in one train to be temporarily taken off-line without disrupting treatment capability. Most treatment technologies also employ means to recirculate partially treated wastewater and solids to prior units in the process train. This enhances flexibility in treatment processes, and provides a means of solids removal. However, it is critical that all recirculated flows and loads are accounted for in the general process design, For example, filter backwash return can significantly increase the total flow entering the equalization tank. These units must be sized to accommodate return flows. Similarly, the additional flow from these sidestreams must also be directly accounted for in calculating the required hydraulic detention time in biological processes. Failure to do so could result in shortened contact time in the unit and incomplete treatment. Flexibility shall also be provided with the ability to recycle flows and add chemicals to different units.
22. **Duplicate Pumps** – Duplicate pumps shall be installed wherever pumping is required. Pumping systems shall be capable of handling the peak daily flow with the largest unit out of service. Particular care should be taken to insure that the pumps are capable of pumping the low flows during initial facility start-up. The use of variable speed pumps is preferred so as to provide maximum flexibility to the treatment process.

23. **Unit Drains** – Unit drains shall be provided for all processes to facilitate cleaning, repairing, or replacing treatment processes.
24. **Floor Drains** – All buildings shall contain floor drains. The floor shall be sloped approximately ¼ inch per foot to a floor drain. The drain shall discharge to the influent. Drains shall have U-traps to prevent the escape of odors from drainage system.
25. **Odor Control** – If the facility is located in close proximity to a residential development or high use or populated area, all necessary design standards shall be taken to minimize nuisance odor conditions. Please check with air quality staff at MassDEP for further guidance.
26. **Lighting** – Lighting shall be included in all treatment buildings. Emergency lights for power outages shall also be provided. Lights shall be located in an area that is easily accessible to replace bulbs. Exterior lighting may be required for facilities that readily access exterior treatment units.
27. **Security** – All treatment facility buildings shall have locks and outside units be protected from vandalism or fenced in.
28. **Sampling Locations** – The design shall include easily accessible sampling locations for influent and effluent samples. These locations shall allow for representative 24-hour composite samples. Every process unit shall be equipped with its own sampling ports and/or electronic monitoring equipment so as not to rely on measurements obtained from any other component. The plans shall denote the sampling locations.
29. **As-Built Plans** - All facilities shall maintain a copy of the as-built drawings, including the disposal area, pump stations, and transmission system, on-site. The as-built plans shall also include a surveyed plan of the monitoring wells with top of casing and top of pipe elevations. The As-built plans shall be updated as unit processes and the like may be modified or replaced.
30. **Operation & Maintenance (O&M) Manual** – All facilities shall maintain a copy of the O&M Manual on-site. The O&M Manual shall be prepared in accordance with the requirements of 314 CMR 12.04(1) and shall be updated as treatment processes may be modified and/or replaced. The O&M Manual shall also include a copy of the most recent staffing plan, prepared and updated in accordance with the requirements of 314 CMR 12.04(3).
31. **Flow Equalization Tanks** – The purpose of the Flow Equalization Tanks (“FET”) is to provide uniform hydraulic and organic loading to

downstream process components. Sizing of FET pumps must be capable of handling the maximum daily flows but at the same time not exceed hourly loading rates of downstream components served. Pumping rates may have to be adjusted seasonally as a function of variations in metabolic rates of the micro-organisms.

32. **Deep Tanks** – if flow equalization or final dosing tanks are deep in the ground, manhole covers shall be large enough and possibly have a shelf so that operators can access the pumps for maintenance and repair.
33. **Subsurface Tank Location** – Subsurface exterior tanks shall be located in a manner that allows for access at all times throughout the year. A means to prevent parking over access hatches is required.
34. **Buoyancy Calculations** – Buoyancy calculations must be done for all in-ground units that are located at or near the water table.
35. **Effluent Tank Covers** – Tanks used for the storage of effluent prior to disposal should be covered to prevent the growth of algae.
36. **Certified Operator Design Review** – It is strongly recommended that a Massachusetts Certified Wastewater Treatment Plant Operator, familiar with the unit operations proposed for a particular wastewater treatment plant, review the plans and specifications prior to submittal to MassDEP.

### C. CONSTRUCTION OVERSIGHT

Construction inspection is one of the most important phases in the conception, design, construction and maintenance of a WWTF. The quality of a project primarily depends on the effectiveness of construction management. It is critical that throughout the construction of the WWTF that the engineer of record performs sufficient inspection to ensure that the facility is being constructed in accordance with all local, state, and federal permits, approvals, and design requirements. These responsibilities typically fall upon a Resident Engineer (RE) to administer. Given the costs associated with the construction of the WWTF, MassDEP strongly recommends utilizing an RE to oversee construction throughout this phase of the project. Diligent construction oversight is necessary in order to deliver a quality product on schedule and within budget. The contractor is essentially responsible for constructing the project according to the contract documents through accepted industry standards and practices. The construction oversight and management personnel are responsible for overseeing the contractor's performance and progress, for reviewing and approving payments, and documenting the project on a contemporaneous basis. The contract between the design firm providing the consulting services and the owner should address construction oversight and clarify the amount of time needed to perform sufficient inspections. However, the owner may choose an altogether separate professional consultant to oversee these responsibilities.

Throughout the construction phase, the engineer or owner shall keep MassDEP informed of the progress of the construction. At various points, an inspection by MassDEP may be necessary. Typically, MassDEP will condition approval of a treatment works plan to provide for inspection of the following phases:

1. Bottom of the excavation for the location of the soil absorption system. All unsuitable material must be removed and the bottom of the system properly graded in compliance with the design plans prior to the placement of any fill material or soil absorption appurtenances.
2. Prior to backfilling the final soil absorption system to witness the placement of any soil absorption appurtenances (if applicable).
3. Upon completion of construction, allow MassDEP representatives to witness a hydraulic clear water test verifying operation of all treatment units.
4. Any other inspections deemed necessary by MassDEP during the construction phase.

Any and all field modifications to the design should be reviewed and approved by the design engineer in advance. Modifications of a substantial nature (e.g. modifying process units) must receive prior MassDEP approval as well.

## **IX. DESIGN CRITERIA**

### **A. COLLECTION SYSTEM**

The following standards apply to conventional collection systems consisting of gravity sewers with standard pump or lift stations. The use of low-pressure sewers may be allowed as an alternative on a case-by-case basis.

**Inflow** - No new sewage collection systems will be approved by MassDEP, which allow for the introduction of rainwater, surface drainage, sump pump discharges, non-contact cooling water or any other source of inflow.

**Overflows** - Overflows from sewage collection systems shall not be permitted.

**Design Flows** - New sewage collection systems at small-scale installations shall be designed on the basis of the sewage flow estimates previously developed. An appropriate allowance for infiltration shall be added to this flow when sewers are installed in areas of high ground water. An allowance of 200-500 gpd/inch diam/mile of sewer is suggested under these circumstances.

**Minimum Diameter** - No gravity sewer shall be less than six inches (15 cm) in diameter. No building sewer shall be less than 4 inches (10 cm) in diameter. Gravity sewers within a municipally owned right-of-way shall be a minimum of 8 inches (20 cm) in diameter.

**Depth of Cover** - Sewers should be designed to be deep enough to drain basement fixtures (where feasible) and to prevent freezing. Insulation may be required for sewers that cannot be placed at depths greater than 4 feet (1.22 m).

**Minimum Velocities** - All sewers shall be designed and constructed to yield a velocity when flowing full of not less than 2.0 feet per second (0.61 m/s) based on “Manning’s” formula. An “n” value of 0.013 constant with depth shall be used for all pipes constructed of materials other than PVC. An “n” value of 0.011 shall be used for PVC pipe. The following minimum slopes shall be used:

<b><u>Sewer size</u></b>		<b><u>Minimum slope (ft/100ft)</u></b>
6 inches	15 cm	0.005
8	20	0.004
10	25	0.0028
12	30	0.0022
14	36	0.0017
15	38	0.0015
16	41	0.0014
18	46	0.0012
21	53	0.0010
24	61	0.0008

**Maximum Velocities** - Velocities greater than 12 feet per second (3.7 m/s) shall not be allowed under any flow conditions.

**Alignment** - Sewers shall be laid with uniform slope and straight alignment between manholes. When a sewer joins one of a larger diameter, the connection shall be made at a manhole. The invert of the larger sewer shall be lowered sufficiently to maintain the same energy gradient. The standard is to match pipe crowns.

**Pipe Materials** - Sewers shall be constructed of SDR - 35 PVC, ductile iron, reinforced concrete or other material approved by MassDEP. All sewers shall be designed to prevent damage from superimposed loads. All sewer piping located beneath any street, roadway, driveway or passageway upon which vehicular traffic could occur, should be designed for H-20 Loading.

**Material Strength** - Proper allowance for loads on the sewer shall be made based upon the width and depth of trench. When standard strength sewer pipe is not sufficient, the additional strength needed shall be obtained using extra strength pipe appropriate bedding or encasement. Sewers greater than 20 feet in depth shall be constructed of SDR – 80 PVC or Schedule 40 ductile iron pipe or equivalent.

**Leakage Testing** - The method of joining pipes and the materials used shall be included in the specifications. Sewer joints shall be designed to minimize leakage and to prevent the entrance of roots. Allowable infiltration or exfiltration shall not exceed 200 gpd/inch

diam/mile of sewer ( $0.19 \text{ m}^3/\text{day}/\text{cm diam}/\text{km}$ ). Leakage tests shall be specified in the specifications and may include water or low pressure air testing. Such tests shall be performed with a minimum positive head of 2 feet (0.61 m) above the water table. Proof of leakage testing shall be required for the final hydraulic clear water test of the WWTF.

**Manholes** - Manholes shall be installed at the end of each line, at all changes in grade, size or alignment, at all intersections, and a distance not greater than 400 feet (122 m).

**Drop Manholes** - A drop pipe shall be provided for a sewer entering a manhole at an elevation of 24 inches (61 cm) or more above the manhole invert. Where the difference in elevation between the incoming sewer and the manhole invert is less than 24 inches (61 cm), the invert shall be filleted to prevent solids deposition.

**Minimum Manhole Diameter** - The minimum diameter of manholes shall be 48 inches (122 cm). A minimum access diameter of 24 inches (61cm) shall be provided. Larger openings shall be provided for manholes that house equipment.

**Flow Channel** - The flow channel through manholes shall be made to conform in shape and slope to that of the sewers entering and leaving the manholes. The top of the flow channel shall be constructed so that under peak design conditions the flow will remain in the channel. The channel shall be at least full pipe depth. When curved flow channels are required, increase minimum slopes to maintain acceptable velocities. Provide a minimum 0.1-foot drop through the manholes.

**Manhole Materials** - Precast or cast-in-place concrete manholes with O-ring gasketed joints manhole covers adjusted to grade using concrete spacer rings shall be used. Manhole cover type shall be specified on the plans and shall be either steel, cast iron or ductile iron. Water tight, gasketed covers shall be used in areas subject to flooding.


**Water tightness** - The specifications shall include a requirement for inspection of manholes for water tightness prior to placing into service. Leakage tests may include appropriate water or vacuum testing.

**Location Relative to Water Supplies** - Sewers shall be kept remote from public water supply wells or other potable water supply sources and structures. Wherever possible, sewers shall be laid at a minimum of at least 10 feet (3.0 m), horizontally, from any existing or proposed water main. Should local conditions prevent a lateral separation of 10 feet, a sewer may be laid closer than 10 feet to a water main if it is laid in a separate trench and the elevation of the crown of the sewer is at least 18 inches (46 cm) below the invert of the water main.

Whenever sewers must cross under water mains, the sewer shall be laid at such an elevation that the crown of the sewer is at least 18 inches (46 cm) below the invert of the water main. When the elevation of the sewer cannot be varied to meet this requirement, the water main shall be relocated to provide this separation or constructed with mechanical-joint pipe for a distance of 10 feet (3.0 m) on each side of the sewer. One full length of water main shall be centered over the sewer so that both joints will be as far from the sewer as possible.

Please note that the same 10-foot separation requirement applies between potable and reclaimed water lines **and** reclaimed water and sewer lines.

**FIGURE 2**



When it is impossible to obtain horizontal and/or vertical separation as stipulated above, both the water main and sewer shall be constructed of mechanical-joint cement-lined ductile iron pipe or equivalent that is watertight and structurally sound. Both pipes should be pressure tested to 150m psi to ensure that they are watertight. For further information, please see the policy entitled: **DWS Policy #BRP/DWM/WS/P03-1: Review of Sewer Line/Water Supply Protection** located in Appendix C.

**Pressure Sewer Systems** - Wastewater can be conveyed to a pressure sewer using various approaches, such as septic tank effluent pumping (STEP) or grinder pumps. A pressure main is common to both systems. In addition, components such as isolation valves, air release valves, external power transfer switches and cleanouts make up a pressure sewer system. The branched configuration of a pressure sewer is similar to that of a conventional gravity sewer system. Pipe routing should include long radial sweeps no less than those recommended by the pipe manufacturer. Pressure piping should be deep enough to prevent freezing. The diameter of the pressure sewer should be sized to provide a cleansing velocity based on the average daily flow. Use of the equivalent of Class 200, SDR 21 PVC piping or greater should be used in order to provide the necessary working pressure rating for the system.

Air relief valves should be provided at high points in the pressure sewer system to release air trapped in pressure lines. Air relief valves should be located to allow access for repair and maintenance. Automatic air release valves should be considered to reduce operating and maintenance costs. A means should be provided for cleaning out pressure mains at sags and other locations where debris can accumulate and clog the lines.

The pressure system owner should provide in writing how the pumps in the system will operate during a prolonged power outage, and which parties will be responsible for operation and maintenance of the pump systems. The components of a proper emergency plan will be required as part of an Operations & Maintenance plan.

**Vacuum Sewer Systems** – Vacuum sewer systems can be designed for areas in similar situations as low pressure sewer systems. They can provide a low profile, minimizing excavation in areas of both undulating and flat topography; however, there are limitations on uphill transportation of sewage. Vacuum sewers use differential air pressure to create flow, and require that the vacuum mains maintain negative pressure. A typical vacuum system consists of a central vacuum station (CVS), valve pits, buffer tanks (to accommodate larger flows, if necessary) and the sewer lines themselves. In some instances, hybrid systems consisting of low pressure sewers feeding vacuum systems have been designed; however, special care and design consideration is essential to insure that flow from the low pressure system does not inundate the vacuum system that may result in loss of negative pressure in the vacuum lines and create a failure condition.

Since vacuum systems are two-phase flow (air combined with water), the behavior of the fluid in the pipe is not easily modeled mathematically; therefore, most of the design criteria and guidelines are based on empirical data and design experience. As a result, it is extremely important that the design engineer coordinate with the manufacturer of the vacuum system before finalizing the design and also to follow closely the manufacturer's design guidance.

**Central Vacuum Station (CVS)** – The CVS houses the vacuum pumps, system controls, collection tank, and discharge pumps. The CVS's centralized location often makes it ideal to house space for maintenance, a stand-by generator, administrative space, or other "non-process" elements, not common to all projects. Design considerations are similar to those of a conventional lift stations with regard to redundancy requirements. Essentially, the vacuum pumps provide the negative pressure in the sewer lines to create the vacuum. The pumps are designed to maintain a normal vacuum pressure throughout the system of 16-20 inches Hg, but the pumps should be capable of maintaining 25 inches Hg. Pump sequencing should distribute run times equally and all pumps must be capable of providing 100 percent of the required airflow to maintain appropriate vacuum pressure. The airflow discharged from these vacuum pumps used to create the negative pressure is evacuated from a sealed collection tank, which in turn is connected directly to the vacuum sewer mains. Sewage collected from the vacuum mains enters a sealed collection tank which essentially acts as a wetwell for the discharge pumps which in turn transport raw sewage to either the treatment facility or to an intermediate lift station. Because this tank also acts to convey the negative pressure to the vacuum sewer mains, wastewater in the tank must be kept below the elevations of the vacuum mains connected to it, typically less than ½ of the tank's volume is used to store the wastewater prior to discharge. It must be noted that because the collection system is

constantly under negative pressure, the discharge pumps must be designed to overcome the vacuum pressure on the suction side.

Typically, CVSs are equipped with low vacuum alarms. Additionally, an alarm for pumps running simultaneously should be provided. The number of pumps running to trigger this alarm condition will vary depending on the configuration and size of the system. However, it does provide an early warning to potential trouble whereas a low vacuum alarm indicates a system already in distress.

Other instrumentation should include vacuum gauges on all incoming lines to the CVS. Isolation valves must also be provided on all incoming mains and should be easily accessible to operating staff.

The CVS must have a backup source of power. Typically, this source would be a fixed backup generator. Whereas the CVS is the heart of the vacuum system, portable generators are not normally an acceptable alternative.

The CVS should be located at a low spot in the system in order to take advantage of flat terrain and downhill slopes. Since static vacuum loss in the system should be limited to 13 feet, there are restrictions on uphill gradients and, to a much lesser degree, sewer main length. Designers should keep in mind that since vacuum systems employ two phase air/water flow, conventional pressure pipe flow does not apply and calculations of losses must be carefully coordinated with the system manufacturers..

**Vacuum Sewers** – Vacuum sewer pipelines should be the equivalent of Class 200, SDR 21 PVC, Schedule 40 PVC pipe or greater to provide the necessary working pressure rating for the system, and to provide durability during installation and operation. Velocities in the vacuum mains can reach 20 fps, and must be durable enough to handle the forces from wastewater, and the debris often found in wastewater, travelling at those velocities. Pipe sizes range from 3” to 10”, and the 10’ limitation obviously sets an upper limit on flow. This must be taken into account by the system designer. If more flow has to be accommodated, then a parallel main can be installed. Piping should be deep enough to prevent freezing.

Fittings accommodating changes in direction should be reinforced in some manner. (Examples would include the use of Schedule 80 fittings or concrete encasement.) If foreign objects are introduced in the sewer lines the potential for generating projectile-like velocities may cause ruptures or holes in the line leading to loss of vacuum and system failure.

Division, or isolation, valves should be provided at appropriate intervals along the mains and at strategic locations such as intersections. When the system experiences low vacuum, these valves are essential in isolating segments of the system in order to identify the location or segment causing the actual vacuum loss and helping to isolate problems so that the entire system is not compromised. Vacuum monitors should also be installed at strategic points along the vacuum lines. These monitors will help the operator evaluate system performance and also aid in locating the origin of vacuum loss should it occur. Also, in some instances, depending on the configuration of the collection system, air injection may be necessary to maintain proper air/liquid ratios.

The layout of a vacuum system is generally in a sawtooth profile along flat and uphill terrain. As mentioned previously, static losses are generally limited to no more than 13 feet and are cumulative from the extremities to the vacuum station whether occurring along a flat layout or uphill slope. Lifts maintain a shallow trench depth and are constructed with two 45 degree bends and a section of pipe. Lift heights are measured from invert to invert and should measure 12 inches for 3” and 4” diameter pipes and 18 inches for 6” diameter and greater pipe. The actual vacuum loss is calculated by subtracting the inside diameter of the pipe from the lift height. For example, for 4 inch pipe, the vacuum loss would be 1 foot of lift height – 0.33 feet diameter = 0.67 feet of vacuum loss.

For downgrade transport, the pipe should follow any slope greater than 0.2% and does not require a sawtooth profile. However, if a series of lifts, either in flat terrain or uphill, follows a downhill slope a minimum 50 foot transition laid a 0.2% must be installed prior to the lifts.

Specifics on the layout of the system profile should follow manufacturer’s recommendations with respect maximum lengths, vertical fall between profile changes and all transitions from downhill slopes to flat terrain or uphill slopes.

**Valve Pits and Buffer Tanks** – Service connections are to vacuum valve pits which may be dedicated to a single facility or shared among more than one facility. In domestic applications, a valve pit will accommodate a maximum of four single family homes. The valve pits consist of a pre-manufactured housing which provides a sump, storage and the vacuum valve and associated piping. 3 inch valves are used for domestic wastewater collection.

The valves are operated on pressure differentials and do not require a power source. Liquid enters the holding tank in the valve pit by gravity and as the level rises, it pressurizes a sensor pipe. The change in pressure is conveyed through a tube to a controller on the valve unit which activates the vacuum valve, causing it to open and evacuate the contents of the tank. The opening of the valve is also controlled by a timer, which is field adjusted, so that the valve remains open long enough to propel the liquid from the pit, allow the introduction of atmospheric air but does not remain open long enough to cause undue loss of vacuum in the system. Because introduction of atmospheric air is required for the operation of the system, an air inlet vent is constructed on the gravity line from the facility. Generally this line should be located a minimum of 20 feet from the valve pit. Because of the large amount of atmospheric air introduced through the valves, in colder climates the timing of the valve must be adjusted seasonally by trained and experienced staff to minimize freezing concerns.

Certain high flow facilities may require buffer tanks which essentially provide larger storage volumes but employ the same vacuum valves. Buffer tanks can be designed to accommodate one or two vacuum valves. Vacuum systems are highly dependent on an appropriate air/liquid ratio, and buffer tanks may upset the balance of that ratio throughout the system. Accordingly, rules of thumb are that should not be used for any more than 25% of system flow and that buffer tanks should not be placed at the extremities of any system.

**Operation** – Operators of all vacuum systems should prepare a site specific Operation and Maintenance plan. In particular, a detailed troubleshooting and emergency plan should be in

place because if a system experiences low vacuum, performance of the system can deteriorate quickly leading to loss of vacuum and system failure.

## **B. RAW SEWAGE PUMPING STATIONS**

**General Location** - Sewage pumping stations shall be used only where necessary. Pumping stations shall be protected from physical damage and remain fully operational during a 100 year frequency flood. Wherever possible, pump stations for small-scale installation shall be constructed without a superstructure. Pumping stations shall be readily accessible during all weather conditions.

**Type** - Submersible pumps shall be used whenever possible. Manholes over pumps shall be of a size that will permit removal of pumps via slide-rails without entering the pump chamber. Minimum access diameter of 24 inches (61 cm) shall be provided. Wet wells shall be vented to the atmosphere by means of a vent pipe, extending not less than 15 feet (4.57 m) above the finish grade, attached to a utility pole, or adjacent building, or other appropriate structure. Centrifugal, suction head pumps are allowed provided the pump station consists of separate wet and dry well.

**Capacity** – The working capacity (between pump-on and pump-off) should provide a holding period not to exceed 30 minutes for the average daily design flow. All pump stations shall have an emergency storage capacity (above the working level) of 6 hours without overflowing or causing backups.

**Pump Type** - Submersible pumps shall be designed specifically for submerged use in raw sewage. An effective method to detect shaft seal failure or potential seal failure shall be provided. Pumps shall be capable of passing spheres of at least 3 inches (7.62 cm) in diameter. Pump suction and discharge openings shall be at least 4 inches (10.2 cm) in diameter. A full description of the pumps including pump curves shall be provided in the specifications. Discharge openings of 2 inches (5.08 cm) will be allowed in the case of grinder pumps.

**Pump Removal** - Submersible pumps shall be readily removable and replaceable without dewatering the wet well or disconnecting any piping in the wet well. Pumps shall be mounted on a slide rail for easy removal.

**Duplicate Pumps** - Duplicate pumping equipment shall be provided. If only two pumps are provided, either shall be capable of handling peak design flows. Where three or more pumps are provided, they shall be designed to fit actual flow conditions and must be so designed so that with any one pump out of service the remaining pumps will have capacity to pump peak design flows.

**Level Controls** - Level sensing devices shall be located in the wet well so as not to be unduly affected by flows entering the chamber or by the suction of the pumps. Provisions shall be made to automatically alternate the pumps in use. Please see the chapter on Instrumentation Guidance for additional detail.

**Alarms** - An alarm system shall be provided for all pump stations. The alarm shall be activated in any one of the following cases:

- low water in the wet wells;
- high water in the wet well;
- loss of one or more phases of power supply;
- high temperature or moisture alarm
- loss of the alarm transmission line; or
- pump failure.

The alarm shall signal at the treatment plant and a facility that is manned 24 hours a day. An automatic dial up capable of dialing several numbers will be accepted as an alternative to the secondary alarm at a manned facility. Please see the chapter on Instrumentation Guidance for additional detail.

**Valves** - Suitable shut-off valves shall be placed on the discharge lines of each submersible pump. A suitable check valve shall be placed on a horizontal section of each discharge line between the shut-off valve and the pump. A valve pit outside of the wet well shall be provided.

**Electrical** - Electrical supply and control circuits shall be designed to allow disconnection at a junction box located or accessible from outside the wet well. Terminals and connectors shall be protected from corrosion by location outside of the wet well or by watertight seals and shall be protected by separate strain relief.

Electrical equipment in enclosed areas where explosive gases such as methane and hydrogen sulfide vapors may be present should be corrosive resistant and must comply with the requirements provided in the most recent editions of the National Electric Code for Class I Group D, Division I locations and NFPA 820.

**Alternate Power** - Pump stations shall be equipped with an alternate electrical supply or a permanently installed standby generator sized to operate all electrical components. Where it is infeasible to provide a connection to the treatment plant generator, a separate generator(s) shall be provided. Portable backup generators may only be used for pump stations with pumps of 5 hp or less.

**Motor Control** - The motor control center shall be located outside of the wet well and protected by a conduit seal or other appropriate sealing method meeting the requirements of the National Electrical Code for Class I, Division 2 locations and NFPA 820.

**Pump Motor** - The pump motor shall meet the requirements of the National Electrical Code for Class I, Division 2 locations and NFPA 820.

**Pump Removal Hoists** - Provisions should be made to remove pumps and motors, including provisions for portable or permanent chain lifts.

**Flow Metering** - Run-time meters should be installed on the motor control of each pump. A flow-totalizing meter should be installed on the force main just before it exits the pump station structure.

**Buoyancy Calculations and Anti-Buoyancy Ballast** - In order to assure that the wet well of the pump stations will not float when the wet well is empty and the groundwater level is at grade, buoyancy calculations for all structures of any pump station constructed below grade should be submitted for review. In the event that these calculations determine that anti-buoyancy ballast is needed, the designed should specify on the pump station design plans, the thickness and coverage of the ballast required.

**Power Cords** - Pump motor power cords shall be designed for flexibility and serviceability under conditions of extreme usage and shall meet the requirements of the Mine Safety and Health Administration for trailing cables. Ground fault interruption protection shall be used to de-energize the circuit in the event of any failure in the electrical integrity of the cable. Power cord terminal fittings shall be provided with strain relief appurtenances, and shall be designed to facilitate field connecting.

**Force Main** - The minimum diameter of force mains shall be 4 inches (10.2 Diameter cm). Smaller diameters may be allowed where grinder pumps are used.

**Velocity** - At design flow, a velocity in excess of 2 feet per second (0.61 m/s) shall be maintained.

**Air Relief** - An automatic air relief valve shall be placed at all relative high points in the force main.

**Thrust Blocks** - Thrust blocks shall be provided at all bends and changes of direction of the force main. Restrained joints may be used in place of thrust blocks

**Termination** - Force mains shall enter the gravity sewer at a point not more than 2 feet (0.61 m) above the flow line of the receiving manhole.

**Drains** - Drain valves shall be placed at all low points in the force main. These valves should be connected to gravity sewers if feasible or provided with connections for vacuum pumps.

**Overflows** - Overflows and by-passes shall not be provided on pumping stations.

## C. **FLOW EQUALIZATION**

**General** - Flow equalization shall be provided at all small-scale installations to normalize the flow over a twenty-four (24) hour period. (Note: Larger facilities designed on the basis of both average day and maximum day flows will not be required to provide flow equalization unless otherwise needed for a specific unit operation/process.) Pumps shall be designed to normalize flow throughout the day so as to feed the treatment facility at a

constant rate. This may lead to a fluctuating water surface in the tank. Float controls for pump activation shall only be utilized for high and low water alarm events or to prevent overflow conditions.

**Location** - The flow equalization tank shall be located prior to the primary settling tank(s).

**Capacity** - The flow equalization tank shall have an adequate effective liquid capacity to accommodate variations in the influent flow rate when the effluent is pumped (or gravity flow is controlled) at a constant rate equal to the average design flow for the facility. For treatment plants serving residential developments with design flows of less than 40,000 gallons per day (151 m<sup>3</sup>/d) the flow equalization tank shall have a minimum effective liquid capacity of fifty (50) percent of the design flow. For treatment plants serving residential developments with design flows between 40,000 and 100,000 gallons per day (151 - 379 m<sup>3</sup>/d) the flow equalization tank shall have a minimum effective liquid capacity of thirty-three (33) percent of the design flow. For treatment plants serving residential developments with design flows greater than 100,000 gallons per day (379 m<sup>3</sup>/d) the flow equalization tank shall have a minimum effective liquid capacity of twenty-five (25) percent of the design flow. Smaller or larger capacity flow equalization tanks may be warranted for nonresidential uses depending on the expected variations in sewage flow rates.

**Construction** - The flow equalization tank shall be watertight and shall be constructed of poured or precast reinforced concrete. The tank and covers shall be designed and constructed so as to withstand an H-20 wheel load. Any tank installed in a location where there is high ground water shall be weighted to prevent the tank from floating when emptied. Buoyancy calculations shall be included on the design plans for any tank with any portion installed below the anticipated high ground water or flood elevation.

**Base** - The flow equalization tanks shall be installed on a level stable base that will not settle.

**Access Manholes** - The flow equalization tank shall be provided with at least two 24-inch (61 cm) diameter manholes (over inlet and tank center) with metal frames and covers at finished grade. Additionally a double leaf, hinged pump access frame and lid at grade, large enough to accommodate the removal of pumps without entering the tank, shall be provided over the flow equalization pumps. Distance between access manholes shall not exceed fifteen feet (4.57 m) on center.

**Accessibility** - The flow equalization tank shall be located so as to be accessible for servicing and cleaning.

**Backfill** - Backfill around the flow equalization tank shall be placed in such a manner as to prevent damage to the tank and piping.

**Groundwater** - The invert elevation of the inlet and outlet and any joint of the flow equalization tank shall be at least one foot (0.3m) above the maximum ground water elevation.

**Pumps** - The flow equalization tank shall be equipped with at least two (2) submersible sewage pumps. Pumps shall be non-clog or grinder type. The design criteria for pump removal, level controls, alarms, valves, electrical, motor control, pump motor, and power cords, shall be the same as those listed under sewage pump stations. Centrifugal suction lift pumps may be used provided a separate dry well is provided or the pumps are located within the treatment plant building. Air lift pumps are also acceptable. Gravity flow through the equalization tank should be considered where the hydraulics permit.

**Mixing** – The designer should consider the use of either mechanical or air mixing of the tank contents.

#### **D. PRELIMINARY AND PRIMARY TREATMENT**

**General** - Either septic tank pretreatment or mechanically cleaned (circular or rectangular) settling tanks shall be provided for all small-scale sewage treatment facilities.

Grit removal should be provided for all facilities, either by means of septic tank pretreatment or separate grit removal facilities. This is necessary to protect downstream mechanical equipment.

##### **Septic Tank Pretreatment**

**Capacity** - A septic tank used for pretreatment (note: not applicable for larger treatment facilities) shall have an effective liquid capacity of not less than 50 percent of the estimated design flow. When garbage grinders are employed or the septic tank is used for sludge storage the effective liquid capacity shall be no less than 75 percent of the estimated design flow. When garbage grinders are employed and the septic tank is utilized for sludge storage, the effective liquid capacity shall be no less than 100 percent of the design flow. Multiple tanks are encouraged for tank sizes greater than 25,000 gallons.

**Liquid Depth** - The liquid depth of the septic tank shall be a minimum of 4 feet. The septic tank may be rectangular, or square in plan, provided the distance between the outlet and the inlet of the tank is at least equal to the liquid depth of the tank.

**Compartments** - Multi-compartment tanks with transverse baffles may be used for pretreatment.

**Tanks in Parallel** - Septic pretreatment tanks may be installed in parallel provided the sewage flow is properly divided such that each tank receives an equal proportion of the total flow.

**Construction** -Septic pretreatment tanks shall be watertight (type WT) and shall be constructed of reinforced concrete. Tanks and covers shall be designed and constructed so as to withstand an H-20 wheel load. Any tank installed in a location where there is high ground water shall be weighted to prevent the tank from floating when emptied. Buoyancy calculations shall be included on the design plans for any tank with any portion installed below the anticipated high groundwater elevation.

**Tees** - Inlet and outlet tees shall be of cast-iron, SDR - 35 PVC, or cast-in-place concrete, and shall extend a minimum of 6 inches above the flow line of the septic tank and be on the centerline of the septic tank located directly beneath the clean out manhole. Any piping extending beyond 6 inches (15 cm) from a tank wall shall be properly supported. There shall be an air space of at least 3 inches (7.62 cm) between the tops of the tees and the inside of the tank cover, and the tops of the tees shall be left open to provide ventilation.

**Depth of Tees** - The inlet tee (baffles are not acceptable) shall extend a minimum of 12 inches (30 cm) below the flow line. The outlet shall be provided with a tee extending below the flow line in accordance with the following table:

<b><u>Depth of Outlet Tee</u></b>	
<u>Liquid Depth in Tank</u>	<u>Below Flow Line</u>
4 feet	14 inches
5 feet	19 inches
6 feet	24 inches
7 feet	29 inches
8 feet	34 inches
9 feet	39 inches
10 feet	44 inches

**Base** - Septic tanks shall be installed on a level stable base that will not settle.

**Materials** - Septic tanks may be constructed of poured reinforced concrete or precast reinforced concrete.

**Access Manholes** - Septic tanks used for pretreatment shall be provided with at least two 24-inch (61 cm) diameter manholes (over inlet and outlet tees) with metal frames and covers at finished grade. Manhole covers shall be labeled and the type shall be specified in the specifications. Distance between access manholes shall not exceed 15 feet (4.57 m) on center.

**Accessibility** -Septic tanks shall be located so as to be accessible for servicing and cleaning

**Invert Elevation** -The invert elevation of the inlet of a septic tank shall be at least 2 inches (5.1 cm) above the invert elevation of the outlet.

**Groundwater** - The invert elevation of the septic tank outlet shall be at least one foot above the maximum ground water elevation. In the case of segmented tanks all joints shall be at least one foot above the maximum ground water elevation.

### **Mechanically Cleaned Settling Tanks**

**Inlets** - Inlets shall be designed to dissipate the inlet velocity, to distribute the flow equally and to prevent short-circuiting. Channels shall be designed to maintain a velocity of at least one foot per second (30 cm/s) at one-half design flow and to distribute the flow proportionately between parallel units. Corner pockets and dead ends shall be eliminated and corner fillets or channeling shall be used where necessary. Provisions shall be made for easy removal of floating materials in inlet structures having submerged ports.

**Scum Baffles** - Scum baffles shall be provided ahead of outlet weirs. Baffles shall be constructed of fiberglass reinforced plastic or other suitable material.

**Weirs** - Overflow weirs shall be constructed of fiberglass reinforced plastic or other suitable material. Weirs shall be properly supported and vertically adjustable. Multiple weir troughs shall be placed sufficiently far apart to avoid excessive upward velocity between the troughs.

**Protective Devices** - All settling tanks shall be designed to provide easy access for maintenance and protection to the operator. Such features shall include stairways, walkways and handrails.

**Surface Loading Rates** - Surface loading rates for mechanically cleaned settling tanks shall not exceed 600 gallons per day per square foot ( $24 \text{ m}^3/\text{m}^2\text{d}$ ) under average flow conditions nor shall the surface loading rates exceed 3000 gallons per day per square foot ( $122 \text{ m}^3/\text{m}^2\text{d}$ ) under peak conditions.

**Scum Removal** - Provisions shall be made for automatic equipment for scum removal. Provisions shall be made to discharge the scum with the sludge.

**Sludge Removal** - Removal of sludge from primary settling tanks shall be by direct pump suction. A sludge well shall be provided. All sludge hoppers shall have an individual valved sludge withdrawal line at least 3 inches (7.6 cm) in diameter.

**Depth** - The liquid depth of mechanically cleaned settling tanks shall not be less than 8.0 feet (2.441.82 m).

**Diameter** - The diameter of primary settling tanks shall not be less than 8.0 feet (2.4 m).

**Tank Material** - Primary settling tanks shall be constructed of reinforced concrete or structural grade steel. Steel tanks shall be adequately protected from corrosion through the use of appropriate coating material. Cathodic protection shall be provided for all buried steel tanks.

**Foundation Pad** - A poured reinforced concrete foundation pad of sufficient design to withstand the structural load of the settling tank under peak operating conditions shall be provided. The foundation pad shall be flat and level. If steel tanks are used, anchoring devices shall be provided to properly secure the settling tank to the foundation pad.

<b>TABLE 4</b>	
<b>SUMMARY OF</b>	
<b>PRIMARY CLARIFIER</b>	
<b>DESIGN CONSIDERATIONS</b>	
Avg. Surf. Load Rate	600 gpd per square foot
Peak Surf. Load Rate	3,000 gpd per square foot <sup>7</sup>
Side Water Depth	8.0 feet minimum
Scum and Sludge	
Removal:	mechanical at least once per hour
Placement	before equalization
Tank Material	steel or concrete
Base	reinforced concrete
Can Use a Septic Tank	with Inlet/Outlet Tees

## **E. SECONDARY TREATMENT PROCESSES**

The following processes are commonly used for biological wastewater treatment. However, this is not a complete list of technology, and MassDEP will consider other processes on a case-by-case basis.

### **Rotating Biological Contactor**

**General:** The Rotating Biological Contactor (RBC) process is the biological treatment system most commonly used at small-scale installations in Massachusetts. Its popularity is attributed to its ease of

<sup>7</sup> If waste activated sludge is cosettled, the peak loading rate will be 1,200 gpd per square foot.

operation, ability to withstand shock loadings both hydraulically and organically and its low operating costs.

**Bases of Design:** The basis of design for the RBC process is typically pounds per day of soluble BOD<sub>5</sub> applied per 1,000 square feet (lbs BOD<sub>5</sub>/day/1,000 sf) of available surface area. Soluble BOD accounts for approximately fifty (50) percent of the total BOD<sub>5</sub> of sanitary sewage.

**Organic Loading:** The total amount of media surface area required shall be calculated on the following basis:

Effluent Limit	Organic Loading
30 mg/l BOD <sub>5</sub>	≤ 1.8 lbs soluble BOD <sub>5</sub> /day/1000 sf
20 mg/l BOD <sub>5</sub>	≤ 1.25 lbs soluble BOD <sub>5</sub> /day/1000 sf
10 mg/l BOD <sub>5</sub>	≤ 0.825 lbs soluble BOD <sub>5</sub> /day/1000 sf

The required surface area shall be increased by (50) percent for systems with septic tank pretreatment.

**Nitrification:** Where nitrification is desired additional surface area shall be provided. The amount of additional surface area required for nitrification shall be calculated on the basis of 0.2-0.4 pounds per day of ammonia removed per 1,000 sf of available surface area (lbs ammonia removed/day/1000 sf) depending on the required effluent concentration. A typical design value is 0.24 lbs. Ammonia removed/day/1000 sf.

Actual influent wastewater characteristics (or in the case of new construction, experience from similar establishments) must be provided for facilities that generate higher than expected amounts of nitrogen such as schools and office parks.

**Temperature:** Wastewater temperatures below 55° F (13°C) will result in a reduction of biological activity and in a decrease in BOD removal. Temperature corrections shall be made using the appropriate manufacturer's correction factors for installation where the wastewater temperature is expected to fall below 55° F (13°C).

Effects of temperature should be examined in cases where the detention time of wastewater preceding the RBC unit is excessive resulting in heat loss or in cases where pre-treatment tanks are susceptible to ambient temperatures. Covers may be necessary to prevent excessive heat loss.

**Bucket Feed Well:** Some RBC units employ a bucket feed well to convey wastewater to the RBC via rotating buckets with a varying number of plugs. In these cases the number of buckets and plugs utilized must be determined at design flow. The flowrate of the buckets cannot exceed the allowable loading rate of the RBC unit.

Floats and alarms must be provided in the bucket feed well if preceded by a pump station. Any pumping to a bucket feed well shall be designed as to prevent the need for an overflow pipe.

**Stage:** Media shall be arranged on the shaft in groupings or stages. Staging is used in order to maximize the effectiveness of a given amount of media surface area in addition to eliminating short-circuiting and dampening shock loadings. Baffles shall be provided within the tank to separate stages.

**First Stage**

**Organic Loading:** First stage organic loadings shall not exceed 4.0 pounds soluble BOD<sub>5</sub>/day/1000 sf.

**Number of Stages:** A minimum of three (3) stages shall be provided. Where nitrification/denitrification is required a minimum of four (4) stages shall be provided. In such cases provisions shall be included to recirculate a portion of the flow from the denitrification unit back to the fourth RBC stage to enhance the nitrification/denitrification process.

**Recirculation:** Provisions must be provided for piping to recirculate effluent from the RBC unit(s) to either the headworks, pretreatment septic tank, or to the beginning of the RBC unit(s).

**Tank Volume:** The tank liquid volume-to-media surface area shall not be less than 0.12-gallons/square foot (0.0049 m<sup>3</sup>/m<sup>2</sup>).

**Media**

**Submergence:** At least forty (40) percent of the media shall be submerged at anytime.

**Tank Material:** Tanks shall be constructed of structural grade steel or reinforced concrete. Steel tanks shall be provided with a protective coating of coal tar epoxy, or other suitable covering to protect against corrosion.

The tank configuration shall be shaped to conform to the general shape of the media to eliminate dead spots where solids could settle and cause septic conditions and odors.

Underdrains or another means of removal of solids, which may settle out in the tank, must be provided.

**Enclosure:** All RBC units shall be enclosed in a building. If the RBC unit is proposed to be enclosed within a fiberglass cover located outside a building then sufficient heating and ventilation must be provided.

**pH control**

**Alkalinity control:** Treatability of wastewater is dependent on the pH level and the alkalinity especially when dealing with nitrification. Provisions must be included for at the head of the RBC unit(s) for chemical addition for controlling pH and alkalinity.

**Media Material:** Media shall be constructed of polyethylene containing UV inhibitors or other suitable plastic materials properly supported on the shaft to withstand the load of the biological growth.

Media shall not be exposed to direct sunlight to prevent growth of algae.

**Shaft Material:** RBC shafts shall be fabricated from structural steel and provided with a heavy protective coating of coal tar epoxy suitable for water and high humidity service. Shafts shall be capable of withstanding the expected stresses without failure for at least a twenty (20) year design life.

**Drive Units:** RBC units shall be equipped with the necessary motor drive assembly and bearings to obtain a constant rotation of the shaft and media sufficient to maintain a peripheral speed of at least (60) feet per minute (18.3 m/minute).

**Foundation Pad:** A poured reinforced concrete foundation pad of sufficient design to withstand the structural load of the RBC tank and appurtenances, under peak operating conditions shall be provided. The foundation pad shall be flat and level.

**Sampling:** Sampling provisions for process control and compliance monitoring shall be incorporated into the system. It is recommended that sampling ports be included for influent, effluent, and within any recycle lines. Sampling locations shall be clearly labeled on the plans.

**Splash Guards:** These are to be included in the design.

**Table 5**  
**Summary of Rotating Biological Contactor Design Considerations**

Total Maximum Organic Loading	1.25 lbs. soluble BOD <sub>5</sub> /day/1000 sf.
1 <sup>st</sup> Stage Maximum Organic Loading	4.0 lbs. soluble BOD <sub>5</sub> /day/1000 sf.
Wastewater Temperature	Corrections for T < 55°F
Rotational Speed	60 ft/min peripheral velocity
Submergence	40%
Configuration	3 stages minimum
Tank Volume	0.12 gallons/sf media
Tank Material	Coated steel/reinforced concrete
Tank Base	Reinforced concrete
Media Material	Polyethylene copolymer
Shaft	Coated/structural steel
Drive	Gear/chain/belt

## **Activated Sludge**

**General:** The activated sludge process and its various modifications have proven to be an effective treatment technology. It should be noted; however, that these processes require close attention and competent operating supervision, including routine laboratory control. These requirements should be considered when proposing these treatment processes.

A number of modifications of the activated sludge process have been developed, some of which are referred to herein. To allow for proper responses to varying plant loading and process demands, aeration tanks should, wherever possible, have the flexibility to change the operation to alternate modes of activated sludge.

**Tank Capacities:** Aeration tank capacities and permissible loadings for the several adaptations of the activated sludge process are shown in Table 6.

**Tank Arrangement:** The dimensions of each independent mixed liquor aeration tank shall be such as to maintain effective mixing and utilization of air. Ordinarily, liquid depths should not be less than six (6) feet (1.82 m).

Tank geometry may affect aeration efficiency especially if diffused air is employed. The width of the tank in relation to its depth is important if spiral-flow mixing is used in a plug-flow configuration. The width-to-depth ratio for such tanks should be between 1.0:1 and 2.2:1.

**Table 6**  
**Aeration Tank Capacities and Permissible Loadings**

Process	Average Organic Loading (lbs. BOD <sub>5</sub> /1000 cf/day)
Conventional	20-40
Step Feed Aeration	40-60
Extended Aeration	12.5 – 25

**Tank Material:** Aeration tanks shall be constructed of reinforced concrete or structural steel. Steel tanks shall be provided with a protective coating of coal tar epoxy, or other suitable covering. For aboveground steel tanks, anodes shall be installed for galvanic protection. For very small tanks, the shape of the tank and the installation of aeration equipment shall provide for positive control of short-circuiting through the tank.

Drains or sumps for aeration tanks are desirable for dewatering.

**Foundation Pad:** A poured reinforced concrete foundation pad of sufficient design to withstand the structural load of the aeration tank and appurtenances under peak operating conditions shall be provided. The foundation pad shall be level and flat. Anchoring devices shall be provided to properly secure the aeration tank to the foundation pad.

**Inlet and Outlet Controls:**

Inlets and outlets for each aeration tank unit shall be suitably equipped with valves, gates, stop plates, weirs, or other devices to permit controlling the flow to any unit and to maintain reasonably constant liquid level.

For multiple tank configurations the flow must be equalized to each tank through splitter boxes equipped with weirs or control valves or influent control gates.

The valving shall provide the ability for individual tanks to be removed from service for inspection and repair. The common walls of multiple tanks must therefore be able to withstand the full hydrostatic pressure from either side.

**Conduits:**

Channels and pipes carrying liquids with solids in suspension shall be designed to maintain self-cleansing velocities.

**Freeboard:**

All aeration tanks shall have a freeboard of not less than eighteen (18) inches (46 cm). Suitable water spray systems or other approved means of froth and foam control shall be provided.

**Mixing:**

The aeration tanks shall have sufficient mixing to prevent solids deposition in all areas of the tank. Fillets shall be provided around the bottom of aeration tanks where the walls and bottoms meet.

**Aeration Equipment:**

Aeration equipment shall be capable of maintaining a minimum of 2.0 mg/l of dissolved oxygen in the mixed liquor at all times and providing thorough mixing of the mixed liquor. A method for DO control shall be provided. The aeration equipment shall be capable of providing both mixing and oxygen transfer.

**Return Activated Sludge (RAS):**

The importance of the return of activated sludge is to maintain a sufficient concentration of activated sludge in the aeration tank so that the required degree of treatment can be obtained in the time interval desired.

The configuration of the piping from the secondary clarifier to the aeration basin is dependent upon the type of activated process: conventional plug-flow, step-feed aeration, or extended aeration. Ample return sludge pump capacity shall be provided. Return sludge pumping capacities of 50 to 150 percent of the wastewater flowrate are required. All piping of RAS shall be valved accordingly to isolate any pipe section and distribute the RAS in varying configurations. RAS pumps shall have variable frequency drives.

Flow meters and sampling provisions for process control shall be provided on all RAS lines.

**Waste Activated  
Sludge (WAS):**

The excess activated sludge produced each day must be wasted to maintain a given food-to-microorganism ratio or mean cell residence time. The waste sludge may be discharged to a dedicated sludge holding tank or to the primary settling tank.

A flow meter shall be provided on the WAS line. WAS pumps shall be constant speed and on tiers.

**pH control**

**Alkalinity control:**

Treatability of wastewater is dependent on the pH level and the alkalinity especially when dealing with nitrification. Provisions must be included for chemical addition for pH and alkalinity control throughout the aeration tank.

**Air Requirements:**

The aeration equipment should be sized to maintain minimum DO levels of 2 mg/l under maximum organic and nitrogen loadings or mixing requirements, whichever governs. Air requirements shall also be based on the typical low wastewater temperature.

**Oxygen Transfer:**

The air requirements assume equipment capable of transferring at least 1.0 lbs of oxygen to the mixed liquor per pound of BOD<sub>5</sub> aeration tank loading (1kg O<sub>2</sub>/kg BOD<sub>5</sub>) and, when nitrification is required, 4.2 lbs. of oxygen per pound of ammonia nitrogen oxidized, and at seasonal low wastewater temperature. In addition, air required for channels, pumps or other air-use shall be added to the overall demand.

**Blower Capacity:** The specified capacity of blowers or air compressors should take into account that the air intake temperature may reach 104° F (40 °C) or higher and the pressure may be less than normal.

**Motor Capacity:** The specified capacity of the motor drive should also take into account that the intake air may be -22°F (-30°C) or less and may require over sizing of the motor or a means of reducing the rate of air deliver to prevent overheating or damage to the motors.

**Blowers:** The blowers shall be provided in multiple units, so arranged and in such capacities as to meet the maximum air demand with the single largest unit out of service. The design should also provide for varying the volume of air delivered in proportion to the load demand of the plant. The discharge line from the blower shall be equipped with an air relief valve, which protects the blower from excessive backpressure and overload.

Piping from the blower unit should be designed in order to keep vibration to a minimum and to allow for heat expansion.

For multiple blower units a check valve is recommended following a blower unit, which can be used for air flow regulation and which can be closed to prevent the blower from operating in reverse should other blowers in the same system be operating while any one blower is off line. Air filters shall precede any blower unit.

**Diffuser and Piping:**

The air diffusion piping and diffuser system shall be capable of supplying peak diurnal oxygen demand or 200 percent of the normal air requirements, whichever is larger. The spacing of diffusers should be in accordance with the oxygenation requirements through the length of the channel or tank, and should be designed to facilitate adjustments of their spacing without major revision to air header piping. Unless multiple tanks are provided, the arrangement of diffusers should also permit their removal for inspection, maintenance and replacement without dewatering the tank and without shutting off the air supply to other diffusers in the tank.

The piping should be sized so that losses in headers and diffuser manifolds are small in comparison to the losses in the diffusers.

High temperatures of air discharge are expected necessitating the need for incorporating provisions for pipe expansion and contraction.

For diffused aeration systems an electric or mechanical hoist shall be provided to raise the header/diffuser components for servicing.

Air piping below the water level can be pressure rated PVC. All above water air pipe shall be stainless steel or coated steel pipe.

**Alarms:** Alarms, which signifies overheating, or high oil temperature shall be provided.

**Valves:** Individual assembly units of diffusers shall be equipped with control valves, preferable with indicator markings for throttling, or for complete shut off. Diffusers in any single assembly shall have substantially uniform pressure loss.

**Filters:** Air filters shall be provided in numbers, arrangement, and capacities to furnish at all times an air supply sufficiently free from dust to prevent damage to the blower and clogging of the diffuser system used.

**Silencers:** Intake and discharge silencers should be provided to minimize nuisance noise from blowers.

**Sampling:** Sampling provisions for process control and compliance monitoring shall be incorporated into the system. It is recommended that sampling ports be included for influent, effluent, and within the return activated sludge lines.

**Safety:** All exposed tanks shall have handrails along the perimeter.

## **F. SECONDARY CLARIFICATION**

- General:** Secondary clarifiers shall be circular or rectangular. Hopper, and scoop-type clarifiers will not be approved, nor will scum skimmers that depend upon surface velocity created by the removal device. The use of plate settlers may be allowed on a case-by-case basis. Sizing is based on solids loadings, sludge settling, settled sludge concentration, and return sludge rates. Clarifier design based solely on standard overflow rates can lead to improperly designed clarifiers if not based on the above parameters.
- Inlets:** Inlets shall be designed to dissipate the inlet velocity, to distribute the flow equally to prevent short-circuiting, minimize sludge-blanket disturbance, and promote flocculation. Channels shall be designed to maintain a velocity of at least one (1) foot per second (30 cm/s) at one-half (½) design flow and to distribute the flow proportionately between parallel units. Corner pockets and dead ends shall be eliminated and corner fillets or channeling shall be used where necessary. Provisions shall be made for easy removal of floating material in inlet structures having submerged ports.
- Baffles:** Scum baffles shall be provided ahead of outlet weirs.
- Weirs:** Overflow weirs shall be constructed of fiberglass reinforced plastic or other suitable material. Weirs shall be properly supported and fully adjustable.
- Solids Loading Rate:** The peak solids loading is based on the design MLSS under aeration and the maximum daily flow rate plus the corresponding recycling rate required to maintain the design MLSS. It can also be calculated by dividing the total solids applied by the surface area of the tankage. Since the solids loading rate is impacted by the particular characteristics of the sludge, the effluent quality can deteriorate if the rate is excessive. Without the benefit of experimental testing, the designer should be conservative in the choice of rates (Tables 7).
- Surface Overflow Rate:** Surface overflow rates for secondary clarifiers shall not exceed those values listed in Table 7. Peak surface overflow rates with one unit out of service shall not exceed 1,000 gallons per day per square foot (41m<sup>3</sup>/m<sup>2</sup>) regardless of the treatment process; however, for clarification following extended aeration process the peak surface overflow rate shall not exceed 700 gallons per day per square foot. If chemical addition for phosphorus removal is added,

then the peak surface overflow rate shall not exceed 600 gallons per day per square foot.

**Scum Removal:** Provisions shall be made for automatic equipment for scum collection and removal. Provisions shall be made to discharge the scum with wasted sludge.

**Sludge Removal:** Sludge removal from the secondary clarifier shall be accomplished with the use of appropriate scrapers and/or appropriate suction devices. A sludge well shall be provided. All sludge hoppers shall have an individual valved sludge withdrawal line at least 3.0 inches (7.6 cm) in diameter. Sludge removal shall be controlled by the use of adjustable timers. Timers shall be capable of being adjusted from continuous operation to intermittent operation with sludge removal as infrequent as once per hour for three minutes. Typically positive displacement or airlift type pumps shall be provided, although centrifugal pumps can be utilized for RAS. Rapid sludge return systems are recommended in the case of activated sludge processes.

Sludge and scum collection and withdrawal facilities shall be designed so as to minimize density currents and assure the rapid removal of accumulated solids.

**Drive Units:** Secondary clarifiers shall be equipped with motor and drive assemblies to rotate the sludge scraper and surface skimmer arms. A torque limiter shall be provided between the output drive and the main collector drive shaft. Torque overload shall activate a malfunction alarm. As an alternative to the torque limiter, a second torque overload set point could be used to shutdown the drive motor.

**Depth:** The liquid depth of secondary clarifiers shall not be less than 10 feet (3.05 m).

**Diameter:** The diameter of secondary clarifiers shall not be less than 8.0 feet (2.4 m).

**Tank Material:** Secondary clarifiers shall be constructed of reinforced concrete or structural grade steel. Steel tanks shall be adequately protected from corrosion through the use of appropriate coating material.

**Foundation Pad:** A poured reinforced concrete foundation pad of sufficient design to withstand the structural load of the clarifier, under peak operating conditions shall be provided. The foundation pad shall be

flat and level. Anchoring devices shall be provided to properly secure the clarifier to the foundation pad.

**Access:** The secondary clarifiers shall be designed and installed so that there is a ready and convenient access to the motor and drive assemblies for proper inspection and maintenance. A stairway or ladder, service walkway and handrails shall be provided.

**Table 7  
Secondary Clarifier Design Considerations**

Average Surface Overflow Rate	Varies, typically 500 gpd/sf (see Table 7)
Peak Surface Overflow Rate	< 1,000 gpd/sf (< 700 gpd/sf for extended aeration)
Average Solids Loading Rate	Varies
Peak Solids Loading Rate	<2.0 lb/hr/sf (<1.4 lb/hr/sf for extended aeration)
Side water depth	12 feet min.
Scum and Sludge Removal	Continuous/intermittent
Configuration	# of units/location
Tank material	Coated steel/concrete
Base	Reinforced concrete

Please note that in the above table’s consideration must also be given to the concentration of MLSS in the aeration tanks. Higher MLSS results in a lower overflow rate. Additionally, the use of selectors will limit filamentous organisms and produce a better settling sludge.

**G. NITROGEN AND PHOSPHORUS REMOVAL**

**Nitrogen Removal**

Nitrogen in its various forms can have deleterious effects on public health, aquatic life and marine habitat. Ammonia is toxic to fish. Nitrate can cause methemoglobinemia, or “blue baby” syndrome, and contribute to cultural eutrophication in marine waters. As the effects of nitrogen are more fully understood, there is an increased need to control its release to the environment which in turn requires more effective and efficient nitrogen removal in wastewater streams.

Typically a limit of 10 mg/L total nitrogen is imposed on groundwater discharges to insure that the drinking water limit of 10 mg/L nitrate-nitrogen is not exceeded. However, as coastal embayments fall victim to the impacts of nitrogen overload, even more stringent standards need to be met to help protect and restore these resources.

Total Nitrogen consists of Total Kjeldahl Nitrogen (TKN) that is a combination organic and Ammonia nitrogen (NH<sub>3</sub>), Nitrite-nitrogen (NO<sub>2</sub>-N) and Nitrate-nitrogen (NO<sub>3</sub>-N). Raw wastewater typically has nitrogen in the form of TKN (ammonia nitrogen and organic nitrogen). Common concentrations for domestic wastewater are about 45 mg/l for TKN. Schools, roadside rest facilities and office parks can have influent TKN concentrations above 100 mg/l. Systems should be designed according to what the actual concentrations are. Nitrification (the conversion of NH<sub>3</sub> to NO<sub>2</sub>-N and then NO<sub>3</sub>-N) works best when wastewater flows through at a constant flow: thereby necessitating the need for flow equalization. Below are factors that should be considered when designing a nitrification system:

1. **Temperature** – Nitrification growth rates are affected by temperature. When temperatures drop below 12 degrees Celsius nitrification can be inhibited or reaction rates significantly slowed. If nitrification is needed year round the treatment units should be enclosed, temperature controlled or designed larger to account for slower reaction rates.
2. **pH** – The nitrification process is affected by pH. The optimum pH range for nitrification is generally 6.5 to 8.5 standard units. For denitrification the optimum pH range is 7.0-8.0. Nitrification consumes alkalinity so a bicarbonate alkalinity concentration in a wastewater is important. Effluent alkalinity in nitrification systems must be maintained at 60 mg/l or higher. Denitrification will add alkalinity back to the wastewater and must be taken into consideration when determining alkalinity adjustments. If alkalinity is low to begin, or the wastewater has high ammonia-nitrogen concentrations such as observed in schools and office parks, pH control will be needed.
3. **Aeration** – Aeration systems that conduct nitrification must have an ability to vary the amount of oxygen. Dissolved oxygen concentrations must be a minimum of at least 1-2 mg/l for nitrification to occur.

### **Denitrification**

Denitrification occurs when nitrate-nitrogen (NO<sub>3</sub>-N) is converted to nitrogen gas under anoxic conditions. It is critical that the secondary aerobic treatment process is designed to allow for as complete nitrification as possible. If large quantities of organic or ammonia nitrogen pass through the aerobic stages into the anoxic phase, then denitrification will not occur at the desired levels and permit limits may not be met.

Nitrified effluent from secondary treatment is carbon poor and because denitrification is biologically mediated by heterotrophic bacteria, a carbon source must be provided to allow for bacterial growth. Depending on the treatment scheme carbon can be introduced

as raw influent or by addition of chemicals such as methanol, sugars or proprietary compounds.

Treatment processes can employ either fixed media such as anoxic RBCs or denitrification filters or suspended growth systems utilizing pre- or post-anoxic reactors. In some design schemes both pre- and post-anoxic reactors may be used. Anoxic units placed ahead of aerobic reactors will require nitrified wastewater to be recirculated to the head of these units at recirculation rates greater than 1:1 (usually 4:1 to 5:1). When methanol is used as a carbon source, all denitrification systems must include reaeration to remove excess methanol and maintain dissolved oxygen in the clarifiers. Since this aeration can create a scum layer, a scum baffle must be provided to reduce carry-over to subsequent treatment units.

### **Attached Growth Denitrification Systems**

1. RBC – The RBC shall be submerged in the effluent. The loading rate shall be 1.0 lbs NO<sub>3</sub>- N/day/1000 square feet. Methanol or another carbon source shall be added prior to the unit.
2. Denitrification filters – Denitrification filters shall consist of media, an underdrain and a backwash facility. The media shall be large round sand with an effective size of 1.8-2.3 mm, a sphericity of 0.8-0.9 and a specific gravity of 2.4-2.6. The media shall be 4-6 feet in depth. The loading rate shall be 1 gpm/sq ft and the time to travel through should be approximately 30 minutes. The air/water backwashing shall be 5-15 minutes at a rate of 6-8 gpm/sq/foot. Air scouring is 5-6 cfm/sq/ft. The rate should not be too large to cause air to be trapped in the media. Backwashes should occur every one to five days. Backwashing too often will cause air entrainment within the media and the filter not to be anoxic. Every one to six hours the denite filter should have a nitrogen release cycle where water is run through the filter to release the nitrogen gas and air. This is a water-only wash at a rate of 5 gpm/sq/ft for up to 5 minutes.
3. Carbon addition – Attached growth denitrification systems will require an additional carbon source added prior to the unit. The use of raw influent is often ineffective in these systems. Methanol is the most common carbon source. Methanol addition shall be flow paced so that methanol is not added when flow is not passing the unit. Additional methanol will cause BOD violations in the effluent and a scum layer build up in the clear well of the denite backwash filter.

### **Suspended Growth Denitrification Systems**

1. **Anoxic zones** – Anoxic zones are areas or tankage where the nitrified effluent from an aeration process passes through. Dissolved oxygen in these tanks will be close to 0 mg/l. These zones will need a submerged mixer to prevent solids from settling. Care must be used to prevent aeration from occurring. A carbon source is added prior to the anoxic zone. The carbon source is often methanol, but can be raw wastewater if the

anoxic zone precedes the aeration system. Anoxic zones shall be sized based on denitrification requirements, temperatures, and appropriate denitrification rates or selector volume requirements, whichever governs.

- a. **Anoxic Zone Pre-aeration** – When the anoxic zone precedes the aeration process, the raw wastewater entering the zone is often used as a carbon source. A supplemental carbon source such as methanol should also be present if the BOD:N ratio is not adequate. This set up requires the wastewater from the aeration tank to be recycled back to the head of the anoxic zone at a rate of up to four or more times the design flow.
  - b. **Anoxic Zone Post-aeration** – When the anoxic zone is after aeration the zones are often divided into two sections with the first compartment having a DO approximately 0.5 mg/l and the second compartment with a DO approximately 0.2 mg/l. Mixers keep the solids in suspension. Sludge and (or) methanol can be added to the first anoxic zone as a carbon source.
2. **Post aeration** – After the wastewater has been denitrified in suspended solid anoxic zones, the wastewater must be aerated to remove excess methanol.
  3. **Special considerations for Sequencing Batch Reactors (SBRs)** - SBRs combine aerobic, anoxic and settling functions in a single reactor vessel. The cycling for the different processes is usually on a timed basis; however, cycling times may not always coincide with oxygen requirements. As such, it is important to design flexibility in the process to allow cycles to be dictated by timers, oxygen sensors or oxidation-reduction probes (ORPs) as may be necessary.

### **Phosphorus Removal**

Phosphorus is a critical parameter in most fresh water systems, and can be the limiting parameter with regard to eutrophication of surface waters. For this reason, controlling phosphorus in wastewater discharges is important. In subsurface effluent disposal systems, phosphorus is often, but not always, bound to particulates in the soil. Most all groundwater discharge permits require sampling of effluent and monitoring wells for both total phosphorus and orthophosphorus, to monitor for fate and transport of phosphorus. In some cases, based on monitoring well data, or risk of surface water impacts, phosphorus limits for effluent may be incorporated into the permit requirements.

Phosphorus is present in raw wastewater at typical concentrations of 6-12 mg/l. A typical biological treatment unit will remove at least 2 mg/l of phosphorus. To remove additional phosphorus there is biological phosphorus removal that takes a specific design and closer operator control, or chemical addition. The most common form of chemical addition is a Metal Salt Chemical Addition that forms an insoluble precipitate with orthophosphate. Phosphorus removal efficiencies decrease in cold weather due to decreased settleability of chemical flocculents. Chemical addition of

metal salts can lower pH levels in the effluent to concentrations below permit limits so pH control may be required. Very low concentrations may also require the addition of polymer to aid in chemical flocculent settling.

### ***Chemical Phosphorus Removal***

If phosphorus concentrations less than 1.0 mg/l are required and metal salt chemical addition is proposed, the following shall be included in the design:

1. Two-point chemical addition – Metal Salts shall be added prior to the primary pretreatment unit and before the final clarifier. The addition of the chemicals shall be flow paced and the chemical shall have adequate a good turbulent mixing zone of at least 30 seconds travel time with the wastewater so a floc can be formed between the chemical and the wastewater.
2. Polymer Addition – Design for addition of polymer to the wastewater in addition to the metal salt addition to aid in settling of inorganic solids in the primary and/or secondary clarifiers. Inorganic solids may carry over to the RBC or final sand filter if polymer is not added. Inorganic solids going to an RBC will result in a biofilm layer that will interfere with normal treatment.
3. pH control – Metal Salts will drop the pH in the effluent and bring the facility out of compliance with permit limits.
4. Effluent polishing – A filter may be required after flocculation and settling to remove remaining suspended solids.
5. Solids handling – Chemical addition for phosphorus removal can double the amount of sludge handled at the facility. The sludge storage tanks shall be sized as large as possible to accommodate the additional sludge. In addition, the secondary clarifiers should have lower loading rates, <600 gpd/sq.ft to aid in the settling of the sludge.
6. The Suspended Solids concentrations must be 15 mg/l or less.
7. Eye Wash and Emergency showers should be located adjacent to chemical systems. Hand and face protection will be required when handling.
8. Sludge streams must be treated to prevent removed phosphorus from being released from the sludge. Phosphate release occurs from sludge when there are changes in pH, in the redox condition or in anoxic or anaerobic conditions. Additional storage facilities other than the pretreatment tank will be necessary to prevent phosphorus release.
9. For facilities using ultraviolet (UV) light for disinfection, the use of iron salts is discouraged as they produce fouling of the quartz jackets. This leads to an accumulation of scale over the wetted surface of the quartz jacket and will impede radiation transmission.
10. For facilities using aluminum salts, care should be taken to insure that their addition will not lead to a violation of effluent standards for aluminum.

There are three main chemicals used for Chemical Precipitation of Phosphorus in Wastewater; Aluminum, Ferric iron or Lime. Each has different handling issues. Design of these systems shall consider the following criteria;

1. Aluminum Sulfate (Alum)

- a. The pH of Alum is 3.0-3.5 so pH control will be needed afterwards.
  - b. Corrosive when wet. All storage bins and piping should be constructed with stainless steel, fiberglass-reinforced plastic, PVC or other plastics, or concrete tanks.
  - c. Shall be stored and added at temperatures 25 degrees F and above to prevent crystallization.
  - d. Works best at wastewater pH of 5.5-6.5.
2. Sodium Aluminate
- a. Formation of NaOH increases pH. This is a strong caustic and is not corrosive.
  - b. Shall be store and used within three months. Dry Aluminate deteriorates with exposure to the atmosphere.
  - c. Store in stainless Steel or concrete. Avoid alloys, rubber and aluminum parts.
3. Ferric Chloride
- a. Has a pH of 2.0 and is very corrosive. Will require pH control.
  - b. Corrosive, use steel lined with rubber or plastic or synthetic resin storage tanks.
  - c. Stored in heated building or in heated tanks to prevent crystallization.
  - d. Pump component should be constructed of graphite or rubber lined pumps with Teflon seals. Metering pumps are typically of the positive displacement type, either diaphragm or plunger.
  - e. Piping, use steel lined with Saran, FRP or plastics. Valves should be rubber or resin lined diaphragm valves, Saran lined valves with Teflon diaphragms, rubber sleeved pinch valves or plastic ball valves.
  - f. Works best at wastewater pH of 4.5-5.0.
4. Ferrous Chloride
- a. Corrosive. Same storage, pumping and piping as Ferric Chloride.
  - b. Precipitation will not occur until ferrous ion is oxidized to ferric ion.
  - c. Works best at wastewater pH of 8.0.
5. Ferrous Sulfate.
- a. Acidic when dissolved in water.
  - b. Phosphorus precipitation does not occur until ferrous ion is oxidized to ferric ion.
  - c. Oxidizes and hydrates in moist air. Must be kept in dry area and out of humidity.
  - d. Will cake up at storage temperatures greater than 68 F, must be kept cool.
  - e. Storage containers may be constructed of concrete, synthetic resin or steel lined with asphalt, rubber, PVC or chemically resistant resins.
  - f. Works best at wastewater temperature of 8.0.
6. Lime (Calcium Carbonate)

- a. Creates significant increases in sludge up to 2-3 times the normal amount generated.
  - b. Must be added till pH is up around 10. This often causes the biological upsets in treatment facilities.
  - c. Phosphorus is released under anaerobic conditions. Sludge handling must be addressed.
7. Polymer – dry or liquid form
- a. Used in conjunction with aluminum and iron salts to assist in flocculation and settling of metal phosphate floc.
  - b. Added at least 10 seconds after metal salt addition, preferably 2-5 minutes later.
  - c. Dry polymers require mixing and aging before use. Liquid polymers can be used immediately.
  - d. Must be stored in cool, low humidity areas. Storage tanks are FRP, type-316 stainless steel, or plastic lined steel tanks.
  - e. Do not store polymer for a long time, three days after dry solution is mixed.

### ***Biological Phosphorus Removal***

Biological phosphorus removal occurs when wastewater is cycled through alternating anaerobic and aerobic conditions. Wastewater sludge must first pass through an anaerobic condition where bacteria release stored phosphorus. The wastewater then passes through an aerobic phase where bacteria store excess phosphorus in their cells. Design calculations shall show the sludge retention time, the anaerobic contact time and the aerobic detention time. Biological phosphorus removal can usually reach a limit of 0.5 mg/l.

### ***New Technology***

There are a number of new technologies that can be employed if the phosphorus limit is 0.1 mg/l or below. Please review operating data from similar facilities in determining the appropriate technology for your project.

#### References:

1. EPA Design Manual Phosphorus Removal, EPA/625/1-87/001, September 1987
2. EPA Manual Nitrogen Control, EPA/625/R-93-010, September 1993
3. Sedlak, Richard. Phosphorus and Nitrogen Removal from Municipal Wastewater, Principles and Practice, Second Edition.1991. Lewis Publishers, New York.

### ***Continuous Backwash Upflow Sand Filters***

Continuous Backwash Upflow Sand Filters achieve continuous filtration when wastewater is distributed through a counter flow sand filtration material.. The solids and

impurities in the wastewater are trapped in this sand filter material. The effluent filtrate exits the sand filter bed via an effluent weir, while sand particles are cleaned and recycled in the filter system. These sand filters have demonstrated their ability to meet a total phosphorus effluent concentration of 0.1 mg/l.

The continuous backwash filter process takes advantage of adsorption, but also of filtration mechanisms. Iron-based salts are first added to the influent wastewater, which is then distributed through stationary arms in the bottom of the sand bed. As the influent fluidizes the bed, the iron chemical reacts with the silica sand and created a hydrous ferric oxide coating. Adsorption is thus the primary mechanism for phosphorus removal, while coagulation/filtration offers some additional removal but to a much lesser extent.

Typically, each filter module consists of a bottom cone, an airlift pump and inlet, and discharge and backwash pumping. The units continually backwash due to their upflow design and the airlift pump system that returns a sand slurry from the bottom of the cone back to the top of the bed. The airlift pumps are supplied with compressed air by a vendor-provided compressor package, consisting of two screw compressors housed in a separate building or enclosure.

During the airlift process, iron and phosphorus particles are abraded from the sand and the sand slurry, comprised of sand, solids, and water, is pushed to the top of the airlift pipe and into a reject compartment. From the reject compartment, the sand falls into the sand washer and is returned to the filter bed, while the lighter reject solids are carried over the reject weir. Treated water emerges from the top of the filter and exits the sand bed via an effluent weir and is discharged into an effluent line.

## **H. FILTRATION**

There are three main filtration treatment technologies in the market. They are sand filtration, cloth filtration and membrane filtration, including microfiltration (MF), ultrafiltration (UF), nanofiltration(NF) and reverse osmosis(RO). Cloth filtration and membrane systems are both proprietary technologies and it is up to the manufacturer to properly size the units for the design of the WWTF. Below is sampling of what should be looked for when reviewing the designs:

1. **Sand Filtration** – Sand Filtration consists of upflow or downflow sand filters. The filters consist of sand media overlying air scour and backwash lines. Units also contain a clear well of treated effluent to backwash the filters and a method to pump or flow the backwash water back to the headworks. Sand filters shall have dual units so that as one unit is backwashing, the other unit shall be able to handle the flows. Design should not exceed a loading rate of 5-gpd/square foot at peak flow. Backwashes shall be on timers and be float activated if the filter gets clogged before its allotted backwash occurs. The clear well shall contain at least enough water for a complete backwash and shall have a permissive float that will not allow a backwash to occur unless there is enough water. Automatic backwash filters, where the filter is

backwashed continuously, can also be used. In this system, the filter is divided into cells, and each cell is individually backwashed by the traveling bridge, which continuously moves over the length of the filter and positions itself over the cell that is to be cleaned. This method of backwashing does not require the entire filter to be taken out of service for cleaning, reduces the headloss through the filter, and reduces the washwater flowrate which in turn will eliminate the need for a washwater collection and equalization basin.

2. **Cloth Filtration** – Cloth filtration along with sand filtration are considered conventional media filtration methods. Cloth filtration consists of cloth discs. The discs have the ability to spray off particulate matter and backwash. The spray water should be disinfected prior to spraying on the media.
3. **Microfiltration** – Microfiltration is composed of small microfilter membranes with small pores where wastewater filters through. It will retain very small suspended materials, most bacteria, and some colloidal material. The membranes must be located in a continuously aerated tank, backwashed hourly and have periodic cleaning in a soak tank every one to four months. Studies have shown that the use of membranes works best when there is grit removal at the headworks and Sludge Retention Times of 25 days or more in the aeration system. Having an SRT less than 25 days causes more fouling and the need for more membranes to account for the increase in maintenance and reduced efficiency of the membranes. Membranes typically need replacement every 5 years. Membrane technology should always be oversized to account for one or more systems being cleaned and backwashed. It can also be used as a pretreatment step for NF and RO to help prevent fouling.
4. **Ultrafiltration** – Ultrafiltration is similar to MF but is capable of higher removals due to higher pressures and smaller pore sizes. It will remove colloidal material, bacteria and viruses, and organics with a molecular weight greater than 1000. As with MF, it can also be used as a pretreatment to NF and RO.
5. **Nanofiltration** – Nanofiltration operates at a lower pressure than RO but will remove a significantly higher percentage of material than either MF or UF. It does have a higher recovery rate than RO so there is less “brine”, or reject water, to dispose of. It will remove organics with a molecular weight in the range of 300-1000, microorganisms and many salts. In terms of TOC removal, it may be possible to meet a TOC of 3 mg/l if the discharge is proposed for a Zone II/IWPA outside a 2-year travel time, but it is recommended that you check with the manufacturer.
6. **Reverse Osmosis** – Reverse Osmosis is used for the removal of dissolved constituents following other forms of treatment, and is effective for compounds with a molecular weight below 300. It typically will be used in

reclaimed water applications, including groundwater recharge and other instances such as cooling towers and high pressure boiler feedwater where high quality water is required. TOC levels at or below 1 mg/l can be achieved so this technology can be used for discharges in a Zone II/IWPA within a 2-year travel time. There will a high volume of reject water produced, frequently in the range of 20-30%, which must be properly disposed of. Finding a suitable disposal option for the reject water has proven to be difficult and expensive.

For both NF and RO, the characteristics of the feedwater are critical. Considerations include:

- Low suspended solids and turbidity
- pH to avoid membrane degradation
- Low FOG to prevent fouling
- Low iron and manganese to prevent scaling

## **I. OTHER ADVANCED TREATMENT PROCESSES**

### **Sequencing Batch Reactors**

The Sequencing Batch Reactor (SBR) is a suspended growth biological treatment system. As opposed to a conventional activated sludge system where aeration and clarification are carried out simultaneously in separate tanks, in an SBR system the processes are carried out sequentially in the same tank.

In the SBR, there are five steps that are performed in sequence:

- ◆ Fill – mixing and/or aeration occur as necessary for biological oxidation
- ◆ React – mixing and/or aeration occur as necessary for biological oxidation
- ◆ Settle – mixing and aeration terminated. Biomass settles
- ◆ Decant – Treated effluent removed
- ◆ Idle – Reactor ready to be placed back in service to receive effluent

Completion of all of these steps is referred to as a cycle. The cycle times can vary but generally there are 4 to 6 cycles per tank per day. Additionally, the times of each step within a cycle can be varied depending on the treatment objective. Solids' wasting is typically done at the end of the settle period. Following the decant period, the liquid and biomass remaining in the reactor constitutes the biomass recycle for the next cycle. Therefore, a return activated sludge system (RAS) is not needed.

Because wastewater is only fed during the fill step, a minimum of two reactors is necessary for continuous operation. When one reactor is filling, the other is completing the other steps in the cycle. SBR systems will also require an effluent equalization tank of sufficient size to maintain a constant flow to downstream units, since treated wastewater is withdrawn only during the decant step. (Note: There are several

proprietary designs that allow for the continuous addition of influent, including settling and decant. This would permit the operation in a single-tank mode if one reactor were taken off-line. If proposed, please review tank sizing, influent piping and baffle arrangements, and effluent decanter location to minimize short-circuiting during monthly maximum flow conditions.)

The SBR process offers a great deal of flexibility to vary the environmental conditions within the reactor to yield particular results. If the fill and react periods are aerobic throughout, then only carbon oxidation and nitrification will occur. On the other hand, denitrification will result if the air is cycled on and off during portions of the fill and react steps, thereby creating anoxic conditions.

In terms of design criteria, an SBR shares many of the same principles as an activated sludge system. It should be noted; only portions of each cycle is devoted to biological reaction, namely the fill and react cycles. Depending on such factors as wastewater characteristics, effluent requirements, and sludge production rates, the active reaction time is 40-60% of the total cycle time. An SBR and an activated sludge system will yield a similar overall process performance if the solids retention time (SRT) for the two systems is comparable. To do this, and insure that the SBR has sufficient volume to adequately treat the wastewater, one must account for the portion of the cycle not devoted to biological reaction. Remember that an SBR includes volume for both reaction and settling. This can be illustrated using the following example for nitrification:

**SRT** = solids retention time (varies, but assume 11 days for a nitrifying system at 10 degrees C)

**BOD<sub>r</sub>** = BOD removed in lbs/day

**Y** = net yield coefficient in lbs/lbs BOD<sub>r</sub> (typical range of 0.6-1.2 [M&E-3<sup>rd</sup> Edition])

**F** = aerated fraction of total reaction time (typical range of 45-50%)

**LWL<sub>volume</sub>** = Total reactor volume at low water level in million gallons

**LWL<sub>MLSS</sub>** = Mixed liquor suspended solids at low water level (typical range of 1500-5000 mg/l [M&E-3<sup>rd</sup> Edition] with the higher range, say 4500 mg/l, used)

**HWL<sub>volume</sub>** = Total reactor volume at high water level in million gallons

$$\text{Solids produced (lbs/day)} = Y \times \text{BOD}_r$$

$$\text{Required mass under air (MLSS in lbs)} = \text{Solids produced} \times \text{SRT}$$

$$\text{Required mass SBR system} = \text{Required mass under air}/F$$

$$\text{LWL}_{\text{volume}} = \text{Required mass SBR system}/(\text{LWL}_{\text{MLSS}} \times 8.34)$$

The **HWL volume** is then calculated to accommodate the maximum day wastewater flow based on the selected number of cycles per day. This allows the operator to treat the maximum day flow during the design period without any reduction in cycle time.

To complete the design, make the following assumptions:

Average day flow = 0.25 mgd  
Maximum day flow = 0.5 mgd  
 $LWL_{\text{volume}} = 220,000$  gallons  
2 reactors  
Depth at lwl = 12 feet  
5 cycles each tank = 10 cycles total

With an  $LWL_{\text{volume}}$  of 220,000 gallons, two SBR reactors and an lwl of 12 feet, each tank is 35 feet by 35 feet. At a max day flow of 0.5 mgd and 5 cycles per reactor, then each reactor would fill 5.5 feet to a depth of 17.5 feet (hwl). Then add 2 feet for freeboard. Each reactor is 35 feet by 35 feet at a depth of 19.5 feet.

If the SBR system must also denitrify, the design process is similar. The *Required mass SBR system* also includes both the MLSS associated with aeration and denitrification divided by the fraction of the total cycle time associated with both aerobic and anoxic conditions. To calculate the required mass, you must determine an SRT under anoxic conditions that is to be added to the aerobic SRT. The value of anoxic SRT ranges from 1.5-4 days (Grady, Daigger & Lim – Biological Wastewater treatment – 2<sup>nd</sup> Edition). To account for low temperatures in the winter months, the SRT will most likely be in the higher range, such as 4 days. Therefore, the combined total system aerobic/anoxic SRT is 15 days in this example. Substituting the combined SRT and F values in the above equations will yield the necessary tank volume for denitrification.

Other design considerations include:

- a. When chemical addition for phosphorus removal is proposed, then the tank size must be checked to verify that sufficient space is available for the additional chemical sludge.
- b. The design must include provisions for screening and grit removal.
- c. The design must incorporate provisions for access to diffusers, decanter, and mixer to facilitate maintenance and repair.
- d. Design must include provisions for monitoring DO, pH, and other operational control parameters.
- e. Sidestream flows should be added at an equalized rate throughout the day to avoid shock loading.
- f. The system should be operated to minimize filamentous bacteria that could carry over into the equalization tank. This is accomplished by creating an anoxic/anaerobic condition during the “Fill” phase.

Please note that many of the values for the design parameters, such as SRT and MLSS, are not absolute numbers, but typical values that have been used in approved designs. The consultant engineer can propose different criteria. If there are questions concerning the design criteria, then the reviewer can request that the consultant submit justification for those values.

### **Advanced Oxidation**

Advanced oxidation is used, frequently in conjunction with reverse osmosis, to remove trace constituents, in order to produce high quality water for many reclaimed water applications. It will further reduce compounds of critical concern such as endocrine disruptors, pharmaceuticals, and personal care products. TOC levels can be reduced below 1 mg/l. This process will generate higher concentrations of the hydroxyl radical (HO-) that is a strong oxidant capable of the complete oxidation of most organic compounds.

Examples of advanced oxidation processes include:

- Hydrogen Peroxide/Ultraviolet Light
- Hydrogen Peroxide/Ozone
- Ozone/Ultraviolet Light

Please note that pilot testing may be required to determine the optimal method and design/operational parameters.

## **J. DISINFECTION**

### **General**

All small-scale treatment facilities, unless otherwise directed by MassDEP, shall have the capability to easily integrate disinfection into their treatment processes should the need arise. Disinfection is required at facilities that discharge their effluent to open sand beds or by means outlined in 314 CMR 20.000 *Reclaimed Permit Program and Standards*. The following reclaimed water uses require disinfection:

- Indirect recharge of aquifers through discharge to an Interim Wellhead Protection Area (IWPA) or a Zone II;
- toilet flushing;
- irrigation;
- any discharge within 100 feet of an irrigation well;
- landscaping;
- cooling water;
- car washes;
- industrial process water;
- snowmaking;
- fire protection;

- creation of wetlands and recreational impoundments;
- agricultural uses;
- dust control;
- soil compaction;
- concrete mixing and aggregate washing;
- street cleaning, industrial boiler feed; and
- silviculture.

The disinfection method should only be selected after careful consideration of wastewater flow characteristics, intended application, demand rates, pH of the wastewater, cost of equipment, availability, reliability, maintenance issues and safety concerns. The most common methods of disinfection in small wastewater treatment facilities today are ultraviolet (UV) disinfection and chlorination. The form of chlorine most often used is sodium hypochlorite liquid. Advantages and disadvantages must be weighed prior to selecting a method of disinfection.

Please note MassDEP discourages the use of gaseous chlorine for disinfection in small wastewater treatment facilities due to increased safety concerns. MassDEP recommends the use of non-chlorine disinfection. Calcium hypochlorite and sodium hypochlorite are acceptable and far-safer alternatives to chlorine as disinfecting agents. Although the use of ultraviolet lamps and chlorination are the only methods discussed herein other methods may be acceptable to MassDEP.

The type of disinfection system that is incorporated into a wastewater treatment facility shall be capable of producing effluent metering the minimum standards for the class of reclaimed water to be produced. Reference should be made to 314 CMR 20.17(1), (2) and (3) for further information.

### **Ultraviolet (UV)**

Ultraviolet disinfection occurs when the UV rays are absorbed by the pathogenic organisms through induced photochemical changes in the cells' DNA. The UV radiation inactivates the pathogens by interfering with and interrupting their ability to replicate, assimilate food and respire, thereby making the pathogen nonviable.

In order to maintain peak performance and operate within permitted parameters, the UV disinfection system should consist of multiple banks of lamp modules, which are capable of continuously disinfecting the peak flow at the wastewater treatment plant when one bank out of service.

The UV disinfection system shall maintain a minimum dose of 30,000 microwatt seconds/sq cm while operating under the following conditions:

- Peak flow of effluent
- 65% of new lamp output, representing lamps

- Clear quartz sleeves
- Minimum average UV intensity in the UV reactor of 6,100 microwatts/sq cm.
- WWTF design incorporating total suspended solids of less than 30mg/l and UV transmittance of 250 – 265 nanometers.
- The UV lamp shall be a low-pressure mercury vapor lamp that will produce short-wave (2000-2959A) ultraviolet energy.

All electronic and electrical components in the UV system shall be designed and installed in accordance with the National Electrical Code. The control box shall be housed outside the UV disinfection chamber. All electrical components shall be tied into the main control panel located in the control room.

Each UV disinfection unit shall be equipped with an automatic shutoff for electrical power when the access panels to the disinfection chamber are opened. A sight port shall be provided for visual inspection of lamp operation.

The most common lamp array configuration is in the horizontal direction, with all of the lamps parallel to each other and to the flow of effluent. There are also vertical lamp array configurations. The system shall be designed for complete immersion of the UV lamps in the effluent at normal operation. The design shall ensure that a constant head of effluent is maintained above the lamp surfaces

Monitoring of the UV disinfection system is a necessary part of maintaining the system at peak performance. Each UV disinfection unit shall be equipped with a UV intensity meter (housed behind a quartz window) that is fixed at the area of minimum expected intensity. The UV intensity meter shall be calibrated at least quarterly to ensure accurate readings. An audio/visual alarm will be activated in the event that the UV intensity has dropped to 70% of the original lamps output or when any of the individual lamps fail. All alarm functions will be connected to the main control panel housed in the control room.

Each UV disinfection system shall be designed and equipped with a convenient method for cleaning all surfaces that come into contact with the effluent. Each system shall have a mechanical wiper system for cleaning the sleeve surface without having to shut down the unit. The system should allow for manual cleaning as well. A cleaning and bulb replacement schedule shall be provided in the Operation and Maintenance Manual, and the design must include adequate room for access, cleaning and bulb replacement. Permit standards shall be maintained at all times.

Some advantages in using UV disinfection are:

- Most pathogens are inactivated by UV radiation.

- UV disinfection is a physical process and there is no need to handle corrosive chemicals.
- UV disinfection also requires shorter contact times and takes up considerably less space.

Some disadvantages in using UV disinfection are:

- If the UV dosage is low, some pathogens may not be inactivated.
- In some cases, pathogenic organisms can repair themselves after being exposed to UV radiation.
- Strict operation and maintenance procedures must be followed to prevent the tubes from being fouled.
- If turbidity and/or the total suspended solids concentration are not within permitted levels, UV radiation becomes less effective or ineffective.
- The use of salts to aid nutrient removal may result in more frequent fouling of the bulbs and affect disinfection.
- Lamp replacement costs are high and mostly proprietary.
- Chemical use in process can quickly foul lamps requiring frequent cleaning and replacement.
- The UV disinfection process is susceptible to interference from color, which can reduce the effective transmittance of the UV rays. Appropriate measures should be taken to reduce the color in the effluent in order to achieve optimal transmittance through the wastewater.

### **Chlorination**

Chlorination refers to the addition of chlorine gas or chlorine compounds, such as calcium hypochlorite or sodium hypochlorite. The addition of chlorine or chlorine compounds for disinfection should only occur where adequate mixing of the wastewater with the chlorine or chlorine compounds can occur. Typically, the chlorination equipment is fixed at the inlet end of the contact chamber. The chlorine diffuser shall be located at a maximum depth below the water surface. In order to provide adequate disinfection, the minimum contact time at peak flows shall be 30 minutes.

A baffle type contact chamber shall be provided. The chamber shall be constructed of reinforced concrete or structural grade steel. Steel chambers shall be protected against corrosion through the use of adequate covering material. A sump shall be provided in the chamber as a method to remove any solids build-up. Baffles shall be provided within the chamber to prevent short-circuiting and shall be designed to keep floating material from leaving the chamber. A method for removing any floating material shall be provided.

If dechlorination equipment is necessary for the treatment process, the guidelines outlined in the most recent edition of *TR-16, Guides for the Design of Wastewater Treatment Works* (2011 edition) shall be followed.

Equipment shall be provided at the plant to monitor free and total chlorine levels using accepted test procedures. All chlorine products shall be stored in a dry location and in suitable containers. Safety equipment shall be kept on hand in case of an emergency.

Some advantages in using chlorination:

- Chlorination is an established technology using established delivery systems.
- It is a very effective disinfectant.
- A residual is maintained to inhibit regrowth of bacteria.

Some disadvantages in using chlorination:

- Residual chlorine is toxic to aquatic life.
- The formation of trihalomethanes (THMs), known carcinogens, is possible.
- There is the potential for volatile organic compounds (VOCs) to be released from the contact chamber.
- There are extensive safety issues with the handling of chlorine, especially chlorine gas.

#### **K. RESIDUALS MANAGEMENT/FOG REQUIREMENTS/GREASE TRAPS**

Sewage sludge is the resultant residual of the wastewater treatment process. Residuals management has become a major environmental problem for any wastewater treatment facility that is being proposed today. Reliable and environmentally sound long term residuals handling and re-use or disposal are critical to the operation of a wastewater treatment facility. Effective residuals management will help a wastewater treatment facility maintain compliance with its discharge permit requirements.

The design and operation of residuals management and disposal facilities should comply with all federal and state regulations. The applicable federal regulations are 40 CFR Part 503 “*Standards for the Use or Disposal of Sewage Sludge*”. State regulations that govern these facilities are 314 CMR 12.00 and, if beneficial re-use is proposed, 310 CMR 32.00, “*Regulations for Land Application of Sludge and Septage*”.

For beneficial re-use and land application of residuals, MassDEP has developed a permit fact sheet that directs the applicant to all appropriate permit applications and policies. The permit fact sheet and any relevant applications can be found in MassDEP’s service center. However, due to the complexity of equipment and process control, staffing requirements and issues related to odor control; sludge processing facilities are commonly not associated with small wastewater treatment facilities. Efficient sludge processing requires continuous operation under close supervision of the treatment plant operator. Guidelines for all methods for sludge processing and disposal that are not covered in this document can be found in TR-16, “*Guides for the Design of Wastewater Treatment Works*”, 2011 addition.

Therefore, as a general rule when dealing with small facilities, wasted sludge shall be collected, properly stored and periodically transported to an approved off-site facility for proper treatment and disposal as a liquid or, in some situations, dewatered product.

Sludge holding tanks shall be provided at a capacity of 2.0 cubic feet/population equivalent for either aerobic or anaerobic designs. Sludge may be stored in the septic pretreatment tanks provided that additional capacity (an increase in 25%) for sludge storage is taken into account in the final design.

Sludge holding tanks shall be water tight and constructed of sound and durable material not subject to excessive corrosion decay, frost damage, cracking or buckling due to settlement or backfilling. To ensure proper placement the tank shall be installed on a six (6) inch bed of gravel. Tanks and covers shall be designed and constructed to withstand an H-20 wheel load if vehicle travel over the tank is anticipated. All specifications outlined in the previous section on septic tanks shall apply to sludge holding tanks except that the outlet (supernatant return) shall be connected to the septic pretreatment tank or the flow equalization tank.

All septic pretreatment tanks and sludge holding tanks shall be vented to the atmosphere through vent pipes that extend above the roofline. Odor control may become necessary for these vent lines. Consideration should be given for mixing and/or aeration in sludge storage tanks that are large and have long duration storage. A lack of this could promote anaerobic conditions, hydrogen sulfide formation, concrete (tank) corrosion, excessive odors, and a sludge that becomes more difficult to process in age.

**FOG Requirements:** Yellow Grease and Grease Interceptor (Trap) Waste are the two basic types of animal and vegetable greases covered in a FOG Program and they are both captured onsite at the facility prior to discharging to the sewer. Mineral origin greases such as

petroleum, hydrocarbon and non-polar fats, oils and greases are also captured onsite, however, this form of FOG is usually covered under a facility's industrial pretreatment program/sewer use regulations and is not discussed here.

Yellow Grease is derived from used cooking oils and waste greases that are separated and collected at the point of use by a food service establishment. These wastes and the facilities that transport and treat these wastes are subject to the Solid Waste Regulations. Grease Interceptor (Trap) Waste originating from devices either inside or outside a building are also considered solid waste but may also be permitted for hauling under Title 5, 310 CMR 15.000.

In order to minimize the impacts of FOG, at a minimum, the following steps should be covered in the O & M manual for the treatment works, any tenant leases for sewer connections that may contribute grease or any other contracts or agreements as appropriate:

1. Establish a permit system, pretreatment standards and best management practices for prohibiting discharge of specific materials such as free-floating FOG and solid or semisolid forms of FOG to the collection system.
2. Establish a penalty program for violating FOG discharge prohibitions or failure to maintain grease interceptors, including cost recovery requirements for impacted sewer cleaning or WWTF mitigation.
3. Designate personnel on the operating staff with specific duties and responsibilities to monitor collection system for FOG issues.
4. Review design of all existing Grease Interceptors to insure they are adequate for current use,
5. Identify all FOG sources without adequate Grease Interceptors and require timeframe for design, permitting and construction of interceptors.
6. Locate information about approved FOG disposal facilities and make the information available to the source facilities on your collection system.
7. Educate and involve those served by the sewer on the importance of isolating FOG from discharge to the sewage collection system and properly disposing of FOG with solid waste.
8. A separate Operations and Maintenance (O&M) Manual, similar to the one for the WWTF, should be available to cover the collection system including FOG issues.
9. Coordinate FOG control program with the local plumbing inspection and Board of Health, to ensure compliance with local requirements.

**Grease Interceptors (TRAPS):** The design and maintenance must be in accordance with 310 CMR 15.000, The State Environmental Code, Title 5 Sections 15.230 and 15.351(2) and 248 CMR 10.00, The Uniform State Plumbing Code.

## **L. INSTRUMENTATION GUIDANCE**

Instrumentation is used for the control of equipment and processes. An integral component of an instrumentation system is the ability to alarm components critical to the integrity of the system.

Instrumentation systems are integral components of raw wastewater pumping stations and wastewater treatment facilities. The majority of equipment and processes are automatically controlled and monitored via instrumentation control systems. All automatically controlled equipment must have the capability of manual control in the event of a failure of feedback sensors or the instrumentation control system.

The instrumentation control system design should be based on the type of operator interface to be provided. Small wastewater treatment plants that do not have full time operator presence may need control automation that provides for remote process control and at minimum alarm telemetry. Large wastewater treatment plants, even with a 24-hour/day on-site operator presence, should also be highly automated to achieve process control that will maximize treatment efficiency at the lowest cost.

Instrumentation is used in raw wastewater pumping/ejector stations and wastewater treatment facilities for:

- Pump and process equipment control
- Flow metering
- Alarms
- Data acquisition
- Ventilation control

### **Process and Pump Equipment Control**

Instrumentation for the manual and automatic control of process equipment is often times equipment specific. For equipment systems provided as an integral unit the critical control functions should be integrated into a single vendor control panel with some functions interlocked with the facilities control system.

Flexibility in the design of the instrumentation for key mechanical process equipment is necessary to provide for good process control. Systems which benefit from sophisticated control systems that can match the supply requirements to the process demand will require feedback control. Signal output from instruments in the process will be used as the input to a programmable logic controller (PLC) and to a Supervisory Control and Data Acquisition (SCADA) System. It should be noted that for the smallest systems SCADA may not be necessary and the use of a PLC with Human Machine Interface (HMIs) at all critical processes may be desirable. A diffused aeration system with PLC can benefit from such control with the result being lower energy costs by matching blower output to the oxygen demands of the aeration system. Also the chlorine feed rate for disinfection can be paced off of the plant flow rate and trimmed off of the concentration of chlorine residual in the plant effluent.

Other wastewater processes can benefit from basic control via a timer. The introduction of septage into the plant influent can be automatically controlled to occur regularly over a 24-hour period via a timer. A low level septage pump shut-off should be provided in the event the septage receiving tank level is too low, and a high level alarm should be provided in the event that the septage receiving tank level is too high.

For pump stations, Instrumentation for the automatic control of raw wastewater pumps shall at a minimum consist of:

- Low level alarm
- Pump “OFF”
- Lead pump “ON”
- High level alarm
- Lag pump “ON”
- Power loss alarm
- General alarm “OFF”

Instrumentation should be provided to alternate the pumps to the “lead” position after each pump cycle. Alternating pumps evenly distributes wear and checks the operability of both pumps through regular usage.

Types of level controls switches include the trash service float switch, the air activated pressure switch, bubbler systems, and electronic sensor.

Alarms should at a minimum be:

- locally indicated on a control panel and visually alarmed to a flashing beacon on the exterior of the building visible from a traveled roadway.
- telemetered, 24-hours/day, to the wastewater treatment plant personnel via a priority call sequence. In some cases the alarm may be transmitted to a continuously manned dispatch station, such as the local police department, which in turn will contact the response personnel.
- automatically logged by the computer, or manually recorded in a logbook by the wastewater operator. Resetting alarm horns and lights shall require an operator acknowledgement to ensure that the problem has been addressed.

All alarms and instrumentation should be tested/activated to verify operational status prior to regular operation of any facility.

### **Alarms**

Alarms for abnormal conditions for mechanical equipment, electrical systems, and treatment processes shall be provided. All PLCs with alarm singles should be provided with UPS powered backup. Alarms signals can be transmitted by wire via phone lines, or wireless by radio frequency transmission.

Electrical system alarms shall at a minimum include:

- Loss of primary power supply
- Tripped breaker
- Failure of back-up power supply (if applicable)

Alarms for major mechanical equipment typically include:

- High oil temperature
- High water temperature (i.e. emergency generator coolant)
- High/Low tank or channel liquid level
- Torque overload (i.e. clarifier drive)
- High/Low vacuum
- High/Low air pressure

Alarms for treatment processes typically include:

- High/Low pH
- High/Low DO

The electrical, mechanical, and process systems must function without major interruption to assure the continued conveyance and treatment of the wastewater. Rapid response to alarms 24-hours/day, 7-days/week is essential. As the sophistication of the process equipment increases, so should the number of alarms to increase the reliability of the systems and treatment processes.

Alarms for personnel safety typically warn of unsafe levels of toxic gases. These alarms shall include a local alarm nearby but outside the area to be monitored. The alarm must be capable of warning personnel prior to entering the monitored space as well as warning personnel within the monitored space of an abnormal condition. The alarms should also be relayed to the plant's central control panel. The alarms should be wired into the emergency electrical power circuit in the event of a primary power outage.

Where a building interior space or confined space is exposed to raw wastewater or sludge, the alarms should at a minimum include:

- Hydrogen sulfide
- Oxygen
- Combustible gases

Where a building interior space or confined space has the potential to be exposed to toxic gases the alarms should be provided for the specific gas. Chlorine gas is commonly used for disinfection in treatment plants and a chlorine gas specific alarm is required for those areas where exposure is possible. Hydrogen sulfide is also toxic and enclosed areas where raw sewage and/or sludge are present should be monitored for the presence of this gas to ensure that personnel do not enter a potentially lethal atmosphere.

Where a building interior space or confined space has the potential to be exposed to exhaust gases from fossil fired fuels a carbon monoxide alarm should be provided. Special care must be taken in siting emergency generators to prevent the intake of exhaust gases through the buildings fresh air intake.

Portable instrumentation is available for monitoring the above parameters for use in entering confined spaces, and other areas where access is infrequent.

### **Flow Metering**

Flow measurement is critical for the proper control of a wastewater treatment facility, as well as for measuring a plant's influent and effluent organic and inorganic loading for compliance reporting. Flow meters must be selected with respect to the characteristics of the liquid being measured, piping configuration, plant hydraulics, accuracy, and flow range.

Flow meters are at a minimum required to measure the total plant flow rate. For this purpose, they can be located at either the influent or effluent end of the wastewater treatment facility and cannot include internal recycle flows. Flow meters used for measuring and recording either plant influent or effluent flow shall indicate the flow rate and also record the total flow volume. The flow streams that should be metered include return and waste sludge pumped. Chemical addition is often flow paced and is dependent on an accurate flow measurement.

The typical components of a flow meter follow:

- Primary flow element,
- Transmitter,
- Local and/or remote indicator,
- Recorder, and
- Totalizer.

For sludge, wasting the total volume and not the rate of flow of the sludge pumped is important. Therefore sludge pumps can be equipped with a pump cycle counter to determine the volume of sludge wasted.

For a description of the various types of flow measurement equipment, consult “*TR-16 Guides for the Design of Wastewater Treatment Works.*”

### **Data Acquisition**

Data acquisition is necessary to monitor and evaluate the performance of the wastewater treatment facility. Data acquisition can be performed manually by logging data from indicators or automatically with systems ranging from chart recorders to SCADA systems.

The effluent discharge permit will dictate whether a regulated parameter must be monitored continuously. Flow measurement and pH are two parameters typically monitored continuously by in-situ instrumentation.

Most current major wastewater treatment system mechanical and process systems are compatible with a type of control system referred to as a Supervisory Control and Data Acquisition (SCADA) System. SCADA systems employ a Human Machine Interface (HMI). This type of an interface consists of customized software to set and adjust equipment operational parameters, alarm set points, and data acquisition. This software operates on a personal computer which can be password restricted. The computer can be networked with hard wiring from the equipment and process transmitters and may be connected on-line for remote control from either an on-site or off-site location.

A distributed control system (DCS) is a type of SCADA system where control is decentralized to remote processing units (RPU's) that are interfaced to a central control location. The advantage of a DCS over a conventional SCADA system is that control is not lost with problems with the network wiring or with the centralized computer.

For a description of the various types of control equipment consult "TR-16 Guides for the Design of Wastewater Treatment Works."

### **Lighting Control**

Proper lighting should be provided to perform the required operational and maintenance tasks. Lighting control can be automated so that the facility is only illuminated to the degree necessary to maintain safe operation. Photocells, timers, and motion detectors with a manual over-ride can be used to activate lighting in secure areas not regularly traveled.

Lighting systems shall be of the appropriate electrical service classification for the area served. Enclosed areas with exposure to raw wastewater, wastewater sludges, and corrosive or hazardous atmospheres will require that the lightning and electrical systems be of the appropriate hazard classification as defined in NFPA 820.

Energy efficient lighting systems should be used where lighting is on for long periods of time. Lighting fixture type and placement should be designed to minimize the effect on off-site properties.

Lighting systems shall be connected and activated with the emergency power generation system serving the facility.

### **Ventilation Control**

Proper ventilation is essential to maintaining a safe working environment. Confined spaces regularly entered should be equipped with a ventilation system interlocked with the lighting switch for the area.

In the event of a power failure, the power and control load demand of the ventilation equipment serving confined spaces and other potentially hazardous areas shall be transferred to the emergency generator if so equipped.

Building fresh air intakes should be located away from and upwind (based on the prevailing wind in the area) of the emergency generator exhaust stack to prevent exhaust gases from being drawn into the building. The generator exhaust stack shall terminate at a height and location per NFPA 110, MassDEP's air emission regulations, and local requirements. A generator shall not be exhausted to a roof containing a ventilation system.

The service classification and size of the ventilation equipment shall be in accordance with OSHA, the NFPA, TR-16 - Guides for the Design of Wastewater Treatment Works, ASHRAE, and Industrial Ventilation – A Manual of Recommended Practices, and any other applicable codes and industry standard guidance.

#### **M. PROPRIETARY TECHNOLOGIES**

MassDEP does not maintain an “approved” list of treatment technologies under the groundwater discharge permit program (unlike the Title 5 program). It is common for applicants to propose the use of a variety of treatment technologies which are proprietary systems. Some technologies resemble trickling filters, others are variants of membrane bioreactors, and still others may be new approaches or may be enhancements of other treatment technologies. So long as the technology is described in detail in the engineering report, and fully supported in design by a properly registered professional engineer, these technologies may be suitable for use under the groundwater permitting program. MassDEP's determination on the adequacy of any proprietary technology will be based on: (1) the information in the design report; (2) past performance in MA of the technology; and (3) any other valid performance data provided by the engineer. MassDEP also reserves the right to require piloting of the technology where performance data is limited.

The design should conform to the provisions of Section VIII of this guidance. To assure that these systems can meet their permit limits and operate for their design life, the engineer must consider a number of issues and take them into account when designing these systems:

- a. **Design flows:** Flows should be established using the methods in Section IV of this guidance, but the treatment plant design must also consider the variation in flows expected at the facility being served by the treatment plant, and include any necessary provisions for sustaining effective treatment and meeting the effluent limits in the permit.
- b. **Pollutant loading:** Representative wastewater samples should be collected where existing systems are to be upgraded or replaced. Composite sampling over several days should provide sufficient information on flow, and pollutant loading. Loadings for new facilities should be based on data collected at similar facilities, supplemented where appropriate by literature values.
- c. **Nitrification/Denitrification:** Design needs to consider aeration requirements, temperature issues, carbon source supplements, and properly sized biological

treatment units. Units exposed to temperatures which will inhibit effective biological treatment will not be approved.

- d. **Operation and Maintenance:** a detailed operation and maintenance (O&M) manual should be developed with specific requirements for all elements of the treatment system. The system manufacturer should provide direct training of operations staff on proper O&M of the proprietary system. The engineer and manufacturer's representative should be available during the startup phase and when compliance issues arise to advise the permittee and operations staff.

## **N. SCHOOLS AND OTHER SEASONAL FACILITIES**

Designing a wastewater treatment facility (WWTF) to serve seasonal operations such as a public school facility or a campground present a number of special challenges for the designer. Most school WWTP's operate under discharge permits requiring a high degree of treatment, usually including both conventional secondary treatment plus one or two forms of nutrient (nitrogen and phosphorus) removal as well. Many of today's treatment systems use biological processes employing microorganisms to achieve this. Biological processes operate best in a narrow range of temperature, pH and oxygen, and require a relatively steady supply of organic matter as a food source.

Most public schools operate in a narrow time period, usually 8 hours/day, 5 days/week, 40 weeks a year. Schools can be closed for extended periods of time, creating a widely fluctuating range of conditions under which the biological systems must operate. These fluctuating conditions must be accounted for in the WWTF design.

The steps involved in designing a wastewater treatment plant to serve a public school facility are as follows:

1. The first step in the design is to determine the wastewater characteristics. To do this the designer must identify the "universe" of different activities (both curricular and non-curricular) that may occur at this facility. For example, will the school have a pool or gymnasium with showers? Will there be full food preparation at this facility or will prepared meals be delivered? Will the school have evening or weekend activities, or summer classes? Will the facility be utilized for non-curricular activities such as public meetings, election polling center, or for events involving food preparation?

Once the full universe of activities is determined the individual wastewater characteristics for each type of activity is first determined and then combined using a mass balance approach to determine the actual range of flows and pollutant loads (from initial start-up conditions to ultimate build-out) which the treatment system will experience. The design must reflect realistic per capita flows and pollutant loadings. This requires obtaining wastewater measurements from an existing school facility with a similar range of activities. School wastewater is typically much higher in nitrogen and lower in C-BOD than typical sanitary sewage. School waste also may be subject to toxic compounds

introduced as cleaning solutions and floor strippers containing high concentrations of quaternary ammonia, which often adversely affect treatment operations, and should be avoided whenever possible. Designs based only Title 5 design flows and literature values for typical sanitary wastewater strength fail to reflect the actual flow and load ranges public schools actually generate. Furthermore, such designs fail to reflect the fact that new schools tend to open at less than full build-out occupancy

2. Following the submission and acceptance of the hydrogeological study, the effluent limits that will be required at this facility will be known. In Massachusetts most school WWTF's operating under a groundwater discharge permit must meet a BOD/TSS of 30 mg/l, a nitrate-N and total N of 10 mg/l, pH of 6.5 to 8.5, and an oil/grease limit of 15 mg/l. This means the treatment process must include denitrification as well as conventional secondary treatment. Some permits also contain phosphorus limits and disinfection requirements as well.
3. The designer must now determine whether the school treatment system is to be operated continuously all year, or to be periodically shut down for summer vacation and possibly other extended breaks. If the school WWTF is to operate continuously, the biological treatment system shall be designed to operate over a significantly wide loading range. If the system is to be periodically shut down, the design must allow for rapid start-up as well as the actual loading range that will be experienced. In either situation, ease of process operation must be a principal design consideration. As an added measure, prior to the discharge of wastes containing high concentrations of ammonia, such as when the floors are cleaned, the facility operator should be notified.
4. The designer must then select the various biological treatment processes best suited to achieve permit limits over the entire flow and loading ranges that will be experienced. In selecting these biological processes the designer should consider all of the following factors:
  - a. Process reliability in meeting permit limits.
  - b. Flexibility (the range of conditions over which the process can effectively operate).
  - c. Overall ease of operation.
  - d. Capital and O&M costs

Some conventional technologies, such as fixed film contactors and microfilters, have proven compliance records, and if properly designed, can have both the flexibility and ease of operation needed for school WWTFs. This is not to say that other systems may not be as attractive. Those processes employing a pre-anoxic stage may offer the added advantage of reduced chemical costs for both nitrification and denitrification. In selecting these processes, the designer is advised to compare actual performance records and cost data.

5. Once a reliable treatment process is selected a detailed unit-by-unit design is performed using preceding sections of these design guidelines. Each process unit design must be based on process criteria, to include hydraulic detention time, BOD loading rates, Mean Cell Residence Time (MCRT), hydraulic overflow rates, etc. The WWTF must be designed so as to operate effectively over the entire range of flow and pollutant loadings the school may generate, from the first day of operation to ultimate build-out conditions. It may be advantageous to employ multiple process trains, with each train designed to operate in a different flow/loading range. In this way, the operator could alternate between the process trains as conditions change.

An effective design must also provide for ease in process control. This means installing sufficient sampling locations in the process train to allow the operator to selectively evaluate each and every process unit. Flow equalization tanks must be equipped with timers rather than float switches to evenly distribute flow over the entire 24-hour period. Chemical feed systems must be regulated by flow-paced metering systems. Aeration tanks should be equipped with separate mixers so that the oxygen transfer may be adjusted without adversely effecting mixing characteristics. We strongly encourage designers to visit similar operating WWTFs and talk with operators about process considerations.

## **X. OPERATION AND MAINTENANCE PLAN**

### **General:**

The purpose of the Operation and Maintenance (O&M) manual is to provide treatment system personnel with the proper understanding of recommended operating techniques and procedures, and the references necessary to efficiently operate and maintain their facilities. The operations plan for the collection system is covered in Sections V and IX (K).

An individual O&M manual shall be prepared and stamped by a registered Professional Engineer and kept current for all small sewage treatment facilities. The O&M manual shall contain all information necessary for the plant operator to properly operate and maintain the collection, treatment and disposal systems in accordance with all applicable laws and regulations. An electronic and hard copy of the approved O&M manual shall be maintained at the treatment plant at all times.

In accordance with 314 CMR 12.04, the O&M manual shall include the following:

- a) Introduction;
- b) Permits and Standards;
- c) Description, Operation and Control of Wastewater Treatment Facilities;
- d) Description, Operation and Control of Sludge Handling Facilities;
- e) Personnel;
- f) Sampling and Laboratory Analysis;
- g) Records and Reporting;

- h) Maintenance;
- i) Emergency Operating and Response Program;
- j) Safety; and
- k) Utilities.

A final O&M manual must be submitted for approval at least thirty (30) days prior to scheduling with MassDEP the clear water hydraulic test of the facility. MassDEP must approve the final O&M prior to the facility going on-line.

The O&M manual shall be kept current at all times. A review by the owner of the O&M manual shall be made at least every two years. The following is a further narrative of the above referenced items:

### **Introduction**

The introduction shall include a general description of the nature of the establishment (e.g. office park, commercial strip mall, etc.) that is served by the wastewater treatment plant (WWTF). Included with the introduction shall be the location of the WWTF and any environmentally sensitive areas within ½ mile of the WWTF, a locus map should be provided.

### **Permits and Standards**

The Permits and Standards section shall discuss the type of permit issued and include a copy of all permits including conditions granted by MassDEP in regards to the WWTF. This section shall state where engineering plans approved by MassDEP will be located.

A detailed description of responsibilities of the owner, operator and consulting engineer necessary to meet all permit conditions shall be provided.

### **Description of Operation and Control of Wastewater Treatment Facilities**

The substance of how to operate the treatment facility lies within this section. This section is intended to provide a description of the various treatment plant components and their function. Each component should be presented in a sequential order and discussed individually. The narrative should discuss the treatment system from the point of generation (including the conveyance system) through the treatment processes to final disposal.

The method for operating each unit of the treatment system shall be discussed in this section. For example, if pretreatment tanks are proposed then how often they require sludge removal should be mentioned.

The O&M manual shall include the manufacturer's operating, maintenance and repair instructions for all process units and appurtenances associated with the WWTF such as: motors, pumps, valves, blowers, bearings, drive assemblies, control panels, electrical

systems, alarms, piping, tankage, and equipment. This information can be incorporated into the body of the Operation and Control of Wastewater Treatment Facilities section or included as appendices. This section shall go on to provide detailed instructions on treatment plant operation including chemical storage and handling, process testing, standard operational mode, optional modes available (such as seasonal operations), process controls and safeguards.

If the WWTF includes storage of chemicals that are required as part of the treatment process (e.g. methanol) the O&M must provide information such as name, address, and telephone number for each chemical supplier.

### **Description of Operation and Control of Sludge Handling Facilities**

All WWTFs generate waste solids that require handling separate from the wastewater treatment system. This section shall provide a description of the sludge handling and disposal requirements including the name and telephone number of the septage hauler, name and telephone number of the sludge disposal facility and record keeping requirements.

For any process unit that either generates or stores waste solids an expected removal frequency and means of removal shall be provided.

### **Personnel**

The owner of a WWTF must employ sufficient personnel to ensure the proper operation of the facility. To ensure proper operation each facility must have a Staffing Plan that provides a detailed description of the number and qualifications of the personnel necessary for proper and continuous operation of the collection, treatment and disposal systems shall be given. The Plan shall include the number of days per week and hours per day the facility shall be staffed, holiday and weekend staff coverage, and on-call and emergency operating personnel.

The following serves to provide guidance for establishing minimum staffing coverage needs at package type WWTFs regulated by MassDEP pursuant to 314 CMR 5.00 and 12.00. These WWTFs discharge treated effluent to the ground under the terms of a groundwater discharge permit issued by MassDEP pursuant to 314 CMR 5.00. Usually, these plants are routinely operated and maintained under a service contract between the permittee (property owner) and a licensed wastewater treatment plant operator. A copy of the WWTF staffing plan and executed service contract must be included in the approved Facility O&M manual and periodically updated as needed.

Currently, MassDEP requires that most groundwater discharge permittees provide advanced secondary treatment, to include both nitrification and de-nitrification. Most new WWTF's are automated and equipped with both PLC control unit and remote telemetry alarm systems. However, although automated, most WWTFs still require regular (usually daily) inspection by the operator to monitor and make periodic process adjustments and

undertake a routine preventative maintenance program. The actual amount of operator coverage time required varies as a function of a number of factors, including process complexity and reliability, plant age & size, and operator knowledge.

### **O&M Manual**

As noted previously, every permitted discharge must have an approved operation and maintenance (O&M) manual prepared specifically for that WWTF in accordance with 314 CMR 12.04. The O&M manual shall include the following documents related to personnel requirements:

1. An itemized preventative maintenance schedule for all process equipment that can be used to track routine O&M activities, listing each activity and the frequency at which this duty shall be performed.
2. An approved staffing plan specifying the required grade of the plant operator (and possibly assistant operator) and minimum coverage requirements (hours per day and/or hours per month) necessary to comply with work specified in the preventative maintenance schedule and to meet permit terms and conditions.
3. Copy of Approved Service Contract with licensed wastewater treatment plant operator. The contract should specify whether any routine operation and maintenance duties will be delegated to third parties.

A copy of the WWTF O&M manual shall be retained at the WWTF and updated whenever to reflect changes in operator coverage or process modifications.

### **Staffing Plan**

The staffing plan shall include the name, license number and current certified grade of the Plant Operator and that of any backup or staff operators, as well as a description of the duties and responsibilities of the staff, including those related to the collection system if applicable. It shall include the number of days per week and hours per day the facility shall be staffed, holiday and weekend staff coverage, and on-call and emergency operating personnel.

As previously noted, most small package-type WWTF's are highly automated and equipped with both PLC unit and remote telemetry alarm systems. Even so, all WWTF's will still require regular (usually daily) inspection by the designated operator to monitor processes, make periodic process adjustments and undertake a routine preventative maintenance program. Permits may specify that operator coverage may not be required on weekends or holidays at these small WWTFs unless either it is needed to respond to an alarm, or to perform some process adjustment.

The following table provides a guideline to be used in estimating the minimum staff coverage requirements for the staffing plan and service contract for small WWTFs permitted to treat less than 40,000 gpd.

Minimum Coverage at Permitted WWTFs		
Plant Grade	Treatment Process (assumes denitrification & disinfection)	Min. coverage (hrs./month) <sup>(1)</sup>
1-3	No denitrification or disinfection requirement	20 <sup>(2)</sup>
4	Rotating Biological Contactor	40
4	Membrane Biological Reactor	40
4	Sequencing Batch Reactor	40
4	FAST™ Treatment	40
4	Bioclere™ Treatment	40
4	Amphidrome™ Treatment	40
4	Ruck™ Treatment	40
	Any process with Reclaimed Water Operations	50
5 or higher		50
<i>(1) Does not include routine labor work not requiring operator certification.</i>		
<i>(2) 25 hours if disinfection is required</i>		

### **Adjustment Factors**

The coverage estimates listed above reflect minimum operator coverage (hrs. / month) typically needed for a small WWTF in good operating condition and in compliance with permit limits, with minimal operator time needed for either solids disposal or groundwater monitoring duties. The following factors would increase the minimum coverage requirements:

1. WWTFs with on-site solids disposal or open sand beds require more labor and possibly more operator coverage as well. Service contracts should allow for up to 10 to 20 percent increase in coverage.
2. Larger WWTFs with design flow between 40,000 and 100,000 gpd usually have multiple process trains requiring increased process control and maintenance. The minimum coverage estimates could be increased by up to 50 percent for these larger WWTFs, depending on process method employed.
3. WWTFs with process units more than 15 years old usually require increased preventative maintenance. This may increase labor costs but not operator coverage requirement, however. However, as plant equipment reaches 15 years and beyond, we recommend that service contracts reflect some increase operator coverage (10 to 20 percent) to account for oversight of growing maintenance and repair work.

4. WWTFs employing reuse of reclaimed water pursuant to 314 CMR 20.00 require increased operator coverage due to the higher treatment and monitoring requirements. We recommend that minimum coverage should be increased by an additional 20 percent at these facilities.

### **WWTF Service Contract**

Most permittees employ licensed contractors to operate the WWTF under a service contract. The service contract establishes the specific terms and conditions needed to (1) ensure compliance with the permit and (2) provide the required operation and maintenance duties described in the O&M manual. Some permits require daily monitoring to be performed for certain effluent parameters. The service contract should therefore specify the minimum coverage requirements (in hours) to meet this requirement, as well as the minimum hours per month needed to provide routine process control and preventative maintenance duties.

Each service contract shall identify the name, operator grade and license number of the designated plant operator (and if required, the assistant operator). In accordance with 314 CMR 12.04(3), the contract should include a written certification signed by the designated plant operator identifying all other WWTFs where he/she is currently designated as a the plant operator, and certifying that other contractual obligations will not cause him/her to fail to provide the minimum coverage required specified in the contract. Misrepresentation of current contractual obligations by an operator shall be deemed a violation of 314 CMR 12.00 and subject to enforcement by MassDEP.

### **Duties of Contract Manager/Administrator**

Some contractors employ a manager or administrator to oversee the duties of individual plant operators they employ to operate WWTFs under contract. Managers do not routinely perform the actual duties of a plant operator themselves, but may provide some level of overall supervision of a number of plant operators, and may have signatory authority for monthly operator reports generated for WWTFs under contract. As such, the manager's time may not be used to meet the minimum coverage requirements for WWTFs discussed below. However, if managers are licensed operators at the appropriate grade of a facility, they may temporarily fill in for a designated plant operator.

### **Duties of Plant Operator**

The plant operator must be certified at the grade of the facility, and must also possess professional experience and formal training in all treatment processes employed at the WWTF. The plant operator retains ultimate responsibility for proper operation of the plant, but may delegate specific duties to an assistant operator or to other subordinates.

The plant operator must reserve sufficient time in his/her daily schedule to meet the contractual coverage requirements, which usually means inspecting the WWTF at least 5

days/week. As such, the maximum number of WWTFs that any person may reasonably be designated as plant operator should not exceed 5 WWTFs. Assuming a minimum coverage of 40 hr/month per WWTF, this would commit that operator to 200 hrs/month. A plant operator may serve concurrently as an assistant operator at some plants to meet contractual coverage requirements, so long as the total number of plants where he/she is designated as either plant or assistant does not exceed 5. Furthermore, if the designated plant operator is currently employed “full time” (ie; 1500 hrs/year) elsewhere, the maximum number of WWTFs that he/she may operate shall not exceed 2.

### **Duties of Assistant Operator**

An assistant operator must be qualified to temporarily assume operational duties when the chief is not present. Assistant operators must be certified at the grade of the plant or not less than one grade lower if the plant is rated at Grade 4 or below. The assistant chief operator must also possess firsthand knowledge/experience and formal training on the specific treatment processes used.

If the assistant operator is also delegated as plant operator at another WWTF, or if that person is to be used to meet the minimum coverage requirement under a service contract, he/she may provide operator coverage at no more than five (5) WWTFs. This total coverage limit is further reduced to two (2) WWTFs if he/she is also employed full time elsewhere.

### **Summary**

The above minimum coverage estimates are intended for small WWTF’s treating less than 100,000 gpd. For WWTFs with design flow greater than 100,000 gpd, the minimum coverage requirements should be developed on a case-by-case basis using an itemized manpower spread sheet reflecting manpower estimates for each process unit, similar to that employed in the 2008 NEIWPCC Guide for Estimating Staffing.

MassDEP must approve WWTF O&M manual staffing plans and operator service contracts. Both should specify minimum operator coverage (both in terms of days per week and total hours/month) and identify the name/grade of the certified operator(s) responsible for providing that coverage.

To ensure adequate coverage, operators contracted to provide coverage requirements may not operate more than 5 WWTFs concurrently. If the operator also is employed full time (1500 hrs/year) elsewhere, he/she may be the designated chief operator at no more than 2 WWTFs.

Service contracts should include a written certification from the designated operator listing all WWTFs at which he/she is designated as chief operator. Any misrepresentation of coverage obligations shall be deemed a violation of 314 CMR 12.00.

## **Sampling and Analysis**

A listing of all sampling (operational and compliance monitoring) and analyses required together with appropriate protocols for proper sampling, storage, transportation, and analysis shall be provided, consistent with the groundwater discharge permit. In addition, a quality control/quality assurance plan shall be developed.

The sampling and analysis plan must include a description of sampling that is reflective of the conditions of the permit for: influent, effluent, and groundwater monitoring wells. The plan must include the parameter that is being tested for (e.g. pH, BOD5, etc.), its frequency of testing (e.g. daily, weekly, monthly, etc), and the method for testing (e.g. Standard Methods # xx). The method of sampling (e.g. grab or composite) shall also be stated in the sampling plan.

Process control testing and the parameter and frequency must also be incorporated. The sampling and analysis plan must include locations of where testing must be performed to ensure that process units are operating properly and efficiently.

The sampling plan for the groundwater monitoring wells must state the location of the well and its designation number.

If an analysis is done on site or transported to a certified lab then this must be so stated in the plan. Any on-site equipment such as pH meters must have documentation for the proper operation of such equipment including calibration information. If chemicals or buffer solutions are required for calibrating equipment, they must be stored and handled according to manufacturer's recommendations.

## **Records and Reporting**

A listing of all reporting requirements and location and method of record keeping shall be included. The Records and Reporting section shall reference daily log of plant operations, process changes and equipment maintenance. Copies of daily logs as well as any inspection reports shall be kept at the facility at all times.

This section shall provide a description of events that require reporting to MassDEP (e.g. anticipated non-compliance, planned alterations, etc.).

## **Maintenance (see Appendix D)**

The Maintenance section shall include a list of spare parts and supplies that shall be available to the operator for the maintenance and repair of the treatment plant and related appurtenances.

This section shall include a chart itemizing all equipment within the treatment facility and its associated maintenance action (e.g. lubricate motor bearings) and the frequency of

such action (e.g. every 6 months). The chart should include provisions for including notes or comments by the operator.

Included in this section shall be a lubrication chart, which details for all equipment routine inspections, lubrication and adjustment, which must be performed by the operator.

It should be noted that only equipment or materials associated with the treatment plant are allowed to be stored within the confines of the WWTP. The treatment plant should not be used as a storage structure for items not related to the WWTP.

A listing of the duties and responsibilities between the owner and operator, and the recommended maintenance schedule for specific pieces of equipment is contained in Appendix D.

### **Emergency Operations & Response**

An emergency operating and response program shall be discussed. It shall detail procedures to be followed in the event of the following emergency situation: power failures, storms, flooding, hydraulic overload/ruptures, fire, explosions, equipment failure, spills of hazardous materials, maintenance shutdowns, and personnel injury. A description of who should be notified, and when, for each emergency situation shall be provided along with an appropriate telephone number.

The procedures to follow shall include information as to identifying the emergency condition, investigating the severity of the emergency, actions to be taken and notification of responsible authorities, corrective actions to rectify the situation, and necessary follow-up. Follow-up procedures should include feasible measures to prevent or minimize the likelihood of a similar situation from reoccurring.

At a minimum, the following telephone numbers shall be incorporated into the Emergency Operations & Response Section: local fire department, local police department, ambulance, poison control center, Regional Office of MassDEP and local Board of Health. This section should state where the phone numbers would be posted within the treatment plant.

### **Safety**

A description of proper material handling and precautionary safeguards shall be included. This shall include a listing of an instruction for use of all necessary safety and first aid equipment. An itemized list of safety equipment shall be provided.

Training for personnel is a key component of a proper safety program. The Safety section must include what training (e.g. OSHA, first-aid, CPR) is required for all staff employed to work within the WWTP. Operators must have easy access to all necessary safety-

related equipment, such as gas detectors, fire extinguishers, air masks, and emergency shower/eyewash facilities.

All Material Safety Data Sheets (MSDS) for any chemicals stored on site must be included in the O&M as well as available within the WWTP.

### **Utilities**

A listing and directory providing names and notification requirements for water, electric, gas and telephone services shall be included in the O&M manual.

## **XI. CONTENT AND REQUIREMENTS OF THE GROUNDWATER DISCHARGE PERMIT**

Pursuant to 314 CMR 5.00, WWTFs which discharge to the ground with design flows of 10,000 gallons per day or greater must apply for and obtain a groundwater discharge permit. Although each groundwater discharge permit issued to a WWTF will contain requirements and conditions unique to that facility, there is a general format that is used for all permits. This chapter will review the various sections of the groundwater discharge permit and the basic requirements of each of those sections.

The front page of the permit will contain the permittee & facility address information, the date the permit application was made, the issuance date, the expiration date, and the effective date. Additionally, the front page will include a description of the facility served by the WWTF (e.g. 240,000 sf office building, 200 bedroom condominium, etc.) Permits become effective on the date of issuance provided no comments were received on the permit during the public comment period. If comments were received, the permit will become effective 30 days from the date of issuance.

***Section I.*** Special Conditions is the next part of the permit and is divided into three parts:

Part A contains the effluent limitations that the discharge must meet. Effluent limitations are a combination of both water quality based effluent limitations and technology based effluent limitations and will be determined on a case-by-case basis. The effluent characteristics and discharge limitations shown in the template permit are typical requirements for a sanitary waste discharge undergoing tertiary treatment with disinfection. The effluent characteristics and limitations will vary in each permit depending on the specifics of the discharge and applicable Department policies.

Part B of the Special Conditions contains the monitoring and reporting requirements for the discharge. The permittee will be responsible for monitoring the influent, the effluent and a minimum of three monitoring wells (at least one upgradient and two downgradient of the discharge) in order to demonstrate

compliance with the permit limitations and the groundwater quality standards (314 CMR 6.00). Under this section, the specific parameters that need to be monitored for at each sampling location will be specified along with the minimum frequency of monitoring and what type of sample needs to be taken, i.e. composite or grab. The last paragraph of Part B, details when the monitoring analyses must be submitted and whom the reports must be submitted to. For all permits, monitoring reports are required to be submitted to the MassDEP Regional Office, the MassDEP Boston office, and the Board of Health for the town in which the discharge is located. The “acceptable forms” for the data submittals are the Groundwater Permit Monthly Report Summary Sheet and the monitoring well report form. Upon issuance of the permit, the permittee will be sent both of these forms. The Summary Sheet is specific to the monitoring requirements of each permit.

Part C contains requirements for privately-owned wastewater treatment facilities to establish and maintain financial assurance mechanisms (FAMs), i.e. escrow accounts, to provide a means of funding immediate repair and capital improvements when necessary to attain and maintain permit limits, where private facilities serve residential uses.

Part D contains the Supplemental Conditions of the permit. These conditions pertain to the operation and maintenance of the facility and will vary for each facility. For small WWTFs, conditions may include ownership change notification, staffing plan submittals, operational notifications and financial conditions. Other conditions deemed necessary for the proper operation of the facility will be included in this section.

The next section of the permit, titled Appeal Rights, gives instructions for how to request a hearing on the issued permit. Any person aggrieved by the issuance of a permit may request a hearing within thirty days of the permit’s issuance date as directed by this section.

The last part of the permit is Section II. General Conditions. These conditions are from 314 CMR 5.00, section 5.19 in its entirety, and apply to all permits.

Finally, a **Section 61 Finding** is required for any MassDEP permit action if the project has been required to submit an Environmental Impact Report (EIR) under MEPA. The Finding will be prepared to comply with M.G.L. c.30, s.61 and 301 CMR 11.12(5) and to complete the public overview of the mitigation program for the project, and will contain a discussion of potential impacts and mitigation measures developed in response to concerns outlined in the EOEA Secretary’s Certificate for the project, and the anticipated implementation schedule for the project and mitigation measures. Typically, the project proponent prepares a draft Finding for DEP review, comment, and finalization. The completed Finding will be incorporated into the permit. Implementation of any mitigation measures will occur in accordance with the terms and conditions of the permit.

Please note that a copy of the Section 61 Finding must also be filed with the MEPA Office.

## **XII. CERTIFICATION & PERFORMANCE GUARANTEES**

Should a treatment technology for which little historical operating data is available, MassDEP may approve such technologies with an approved letter of credit, loan guaranty, or escrow account in an amount and under conditions determined by MassDEP to ensure the availability of funds for needed repairs, replacement and/or temporary hauling of sewage to an approved off-site treatment facility.

When equipment and unit processes other than those specified in this document are proposed, MassDEP may require a performance guaranty in the amount of 100 per cent of the costs associated with the removal and replacement of that piece of equipment or process with an alternate which is capable of meeting the specified performance standards. In all cases where a piece of equipment or a unit process other than those specified in this document are proposed, MassDEP shall set an appropriate performance standard for that piece of equipment or process and shall require performance monitoring by an independent consulting engineer for a period of at least one year. At the end of the monitoring period the independent consultant shall prepare a report that summarizes the performance monitoring and which:

- (1) Provides a certification to the owner that the piece of equipment or unit process has continuously met or exceeded its performance standards; or
- (2) Makes recommendations to the owner on necessary modifications and additional testing required; or
- (3) Recommends and designs an alternate system for the owner which is capable of meeting the specified performance standards.

A copy of the consultant's report shall be submitted to MassDEP and the local Board of Health. In the event that the effluent limitation specified in the facilities discharge permit cannot be obtained or maintained due to the piece of equipment or unit process being tested, steps shall be taken to immediately replace it.

**APPENDIX A**

**CERTIFICATION STATEMENT**



**Massachusetts Department of Environmental Protection**  
Bureau of Resource Protection – Groundwater Discharge and  
Reclaimed Water Permits

Transmittal Number # \_\_\_\_\_

**Certification Statement**

Facility ID/Permit # (if known) \_\_\_\_\_

**For BRP WP 11, 68, 79, 80, 81, 84, 85, 86, 87, 88, 89, and 90**

**A. Engineer Information**

**Important:**  
When filling out forms on the computer, use only the tab key to move your cursor - do not use the return key.



Engineer Name \_\_\_\_\_  
Company \_\_\_\_\_  
Street Address \_\_\_\_\_ City \_\_\_\_\_  
State \_\_\_\_\_ Zip Code \_\_\_\_\_ Telephone \_\_\_\_\_ Email Address \_\_\_\_\_

**B. Certification**

I, \_\_\_\_\_ Name \_\_\_\_\_

attest under the pains and penalties of perjury:

(i) that I am a registered professional engineer in the State of Massachusetts, with a concentration in sanitary, civil, or environmental engineering, and am employed by

Name of Company/Firm \_\_\_\_\_

(ii) that  the Engineering Report for \_\_\_\_\_ Name of Facility \_\_\_\_\_  
 the Plans and Specifications

have been prepared in accordance with modern sanitary engineering practice and all applicable federal, state, and local laws, regulations, and standards, except where otherwise approved by the Department, including, but not limited to the current editions of TR-16 (Guides For The Design Of Wastewater Treatment Works), the Massachusetts Guidelines for the Design, Construction, Operation and Maintenance of Small Wastewater Treatment Facilities with Land Disposal, and the Massachusetts State Building Code; and

that the facility, as designed, is capable of meeting the required effluent standards described in the Engineering Report included as part of this permit application.

(iii)  that the Hydrogeological Evaluation prepared for this project and approved by MassDEP on

Date \_\_\_\_\_ for \_\_\_\_\_ Name of Facility \_\_\_\_\_

is consistent with the site conditions and design parameters for this facility, including, but not limited to: design flow, site design, hydraulic loading rate, and location of public and private potable water supply wells, and potential impacts of the proposed facility to nearby sensitive receptors and/or property.

I am aware that there are significant penalties including, but not limited to possible fines and imprisonment for willfully submitting false, inaccurate, misleading or incomplete information. I am also aware that submitting false, inaccurate misleading or incomplete information could lead to modification, suspension or revocation of any permit granted pursuant to this application.

Signature \_\_\_\_\_ Massachusetts PE Number \_\_\_\_\_

Title \_\_\_\_\_ Date \_\_\_\_\_

## APPENDIX B

### INFILTRATION RATE & INFILTRATION RATE TEST

#### Infiltration Rate

The **infiltration rate** is the velocity or speed at which water enters into the soil. It is usually measured by the depth (in mm) of the water layer that can enter the soil in one hour. An infiltration rate of 15 mm/hour means that a water layer of 15 mm on the soil surface will take one hour to infiltrate.

In dry soil, water infiltrates rapidly. This is called the **initial infiltration** rate. As more water replaces the air in the pores, the water from the soil surface infiltrates more slowly and eventually reaches a steady rate. This is called the basic infiltration or saturated infiltration rate (Table B-1).

The infiltration rate depends on soil texture (the size of the soil particles), the grain size distribution and soil structure (the arrangement of the soil particles).

The most common method to measure the infiltration rate is by a field test using a cylinder or ring infiltrometer.

**Table B-1**

**BASIC INFILTRATION RATES FOR VARIOUS SOIL TYPES**

Soil Class	Soil type	Basic infiltration rate (mm/hour)	Basic infiltration rate (in/hour)
I	Sand	less than 30	0.50 to 1
I	Loamy Sand	25-30	0.45 to 0.50
II	Sandy loam	20 - 25	0.39 to 0.44
II	Loam	15 - 20	0.34 to 0.38
III	Silt Loams, less than 27% Silt	10-15	0.25 to 0.34
III	Sandy clay loam, less than 27% clay	5 - 10	0.10 to 0.24
IV	Clay	1 - 5	Less than 0.10

#### **Double Ring Infiltration Test**

##### Equipment required

Shovel/hoe


Hammer (2 kg)

Watch or clock

5 liter bucket  
Timber (75 x 75 x 400)  
Hessian (300 x 300) or jute cloth  
At least 100 liters of water  
Ring infiltrometer of 30 cm diameter and 60 cm diameter.  
(other diameter may be substituted with Department approval)  
Instead of the outer cylinder a berm could be made to prevent lateral water flow.  
Measuring rod graduated (e.g. 300 mm ruler)

**Figure B-1**

### SET-UP OF FIELD TEST



#### Method

- Step 1: Hammer the 30 cm diameter ring at least 15 cm into the soil. Use the timber to protect the ring from damage during hammering. Keep the side of the ring vertical and drive the measuring rod into the soil so that approximately 12 cm is left above the ground.
- Step 2: Hammer the 60 cm ring into the soil or construct an earth berm around the 30 cm ring to the same height as the ring and place the hessian inside the infiltrometer to protect the soil surface when pouring in the water
- Step 3: Start the test by pouring water into the ring until the depth is approximately 70-100 mm. At the same time, add water to the space between the two rings or the ring and the bund to the same depth. Do this quickly. The water in the berm or within the two rings is to prevent a lateral spread of water from the infiltrometer.
- Step 4: Record the clock time when the test begins and note the water level on the measuring rod.
- Step 5: After 1-2 minutes, record the drop in water level in the inner ring on the measuring rod and add water to bring the level back to approximately the original level at the start of the test. Record the water level. Maintain the water level outside the ring similar to that inside.

Step 6: Continue the test until the drop in water level is the same over the same time interval. Take readings frequently (e.g. every 1-2 minutes) at the beginning of the test, but extend the interval between readings as the time goes on (e.g. every 20-30 minutes).

### **Methodology for Infiltration Testing**

Prepare a table, as follows:

- Column 1 indicates the readings on the clock in hours, minutes and seconds.
- Column 2 indicates the difference in time (in minutes) between two readings.
- Column 3 indicates the cumulative time (in minutes); this is the time (in minutes) since the test started.
- Column 4 indicates the water level readings (in mm) on the measuring rod: before and after filling (see step 5).
- Column 5 indicates the infiltration (in mm) between two readings; this is the difference in the measured water levels between two readings. How the infiltration is calculated is indicated in brackets.
- Column 6 indicates the infiltration rate (in mm/minute); this is the infiltration (in mm; column 5) divided by the difference in time (in minutes, column 2).
- Column 7 indicates the infiltration rate (in mm/hour); this is the infiltration rate (in mm/minute, column 6) multiplied by 60 (60 minutes in 1 hour).
- Column 8 indicates the cumulative infiltration (in mm); this is the infiltration (in mm) since the test started. How the cumulative infiltration is calculated is indicated in brackets.

**Soil Infiltration Data Work Sheet**

Site Name: \_\_\_\_\_

Name of Collector/Analyst/Recorder: \_\_\_\_\_

Sample collection

- date: \_\_\_\_\_
- time: \_\_\_\_\_ (hours and minutes) check one: UT\_\_\_ Local \_\_\_

Distance to Soil Moisture study site marker \_\_\_\_\_ m

Sample Set number: \_\_\_\_\_ Width of your reference band: \_\_\_\_\_mm

Diameter: Inner Ring: \_\_\_\_\_ cm Outer Ring: \_\_\_\_\_ cm

Heights of reference band above ground level: Upper: \_\_\_\_\_ mm Lower: \_\_\_\_\_ mm

Saturated Soil Water Content below infiltrometer after the experiment:

A. Wet Weight: \_\_\_\_\_ g B. Dry Weight: \_\_\_\_\_ g C. Water Weight (A-B): \_\_\_\_\_ g

D. Container Weight: \_\_\_\_\_ g E. Dry Soil Weight (B-D): \_\_\_\_\_ g

F. Soil Water Content (C/E) x 100 \_\_\_\_\_

**Daily Metadata/Comments: (optional)**

**Directions:**

Take 3 sets of infiltration rate measurements within a 5 m diameter area. Use a different data work sheet for each set. Each set consists of multiple timings of the same water level drop or change until the flow rate becomes constant or 45 minutes is up. Record your data below for one set of infiltration measurements you take.

The form below is setup to help you calculate the flow rate.

For data analysis, plot the Flow Rate (F) vs. Midpoint time (D).

**Observations:**

A.	B.	C.	D.	E.	F.
Start	End	Interval	Midpoint	Water Level	Flow Rate
(min)	(sec)	(min)	(min)	Change	(mm/min)
(min)	(sec)	(B-A)	(A+C/2)	(mm)	(E/C)
1	_____	_____	_____	_____	_____
2	_____	_____	_____	_____	_____
3	_____	_____	_____	_____	_____
4	_____	_____	_____	_____	_____
5	_____	_____	_____	_____	_____
6	_____	_____	_____	_____	_____
7	_____	_____	_____	_____	_____
8	_____	_____	_____	_____	_____
9	_____	_____	_____	_____	_____

### **Field Measurement Using a Double-Ring Infiltrometer with a Sealed Inner Ring** **(ASTM D 5093 –90)**


The infiltration rate of water through soil is measured using a double-ring infiltrometer with a sealed or covered inner ring. The infiltrometer consists of an open outer and a sealed inner ring. The rings are embedded and sealed in trenches excavated in the soil. Both rings are filled with water such that the inner ring is submerged.

The rate of flow is measured by connecting a flexible bag filled with a known weight of water to a port on the inner ring. As water infiltrates into the ground from the inner ring, an equal amount of water flows into the inner ring from the flexible bag. After a known interval of time, the flexible bag is removed and weighed. The weight loss, converted to volume, is equal to the amount of water that has infiltrated into the ground. An infiltration rate is then determined from this volume of water, the area of the inner ring, and the interval of time. This process is repeated and a plot of infiltration rate versus time is constructed. The test is continued until the infiltration rate becomes steady or until it becomes equal to or less than a specified value.

### **Two-Stage Borehole Permeameter**

The rate of flow of water into soil through the bottom of a sealed, cased borehole is measured in each of two stages, normally with a standpipe in the falling head procedure. The standpipe can be refilled as necessary. In stage 1, the bottom of the borehole is flush with the bottom of the casing for maximum effect of  $K_v$ . The test is continued until the flow rate becomes quasi-steady. For Stage 2, the borehole is extended below the bottom of the casing for maximum effect of  $K_h$ . This stage of the test is also continued until the flow rate becomes quasi-steady. The direct results of the test are apparent hydraulic conductivities  $K_1$  and  $K_2$ . The actual hydraulic conductivities  $K_v$  and  $K_h$  can be calculated from these values.

## Schematic of Two-Stage Borehole Permeameter



### Field Hydraulic Conductivity Measurement By Using Guelph Permeameter (ASTM D 1556)

The Model 2800K1 Guelph Permeameter is a constant-head device that operates on the Mariotte siphon principle and provides a quick and simple method for simultaneously determining field saturated hydraulic conductivity, matrix flux potential and soil sorptivity in the field.

#### Loading Test

A loading test may be done at the design scale or a percentage of the final design size. It is performed in an open bed, trench or other method similar to the proposed final method of disposal. The test is designed to demonstrate the maximum hydraulic loading potential of the proposed site. Based upon site conditions and the proposed layout of the final discharge locations, multiple tests may be required. This is true especially for large sites where site heterogeneity exists, where several areas with differing soil conditions exist and if multiple disposal methods are proposed. The receiving area shall be constructed in a manner similar to that of the final design. A staff gage or other measuring device shall be placed in the receiving area and secured to prevent slippage and calibrated if a pressure transducer is being used. An observation well may be installed in the testing area if a bentonite seal is present to eliminate downward flow along the side of the well.

Observation wells shall be installed at intervals space out from the area being tested. Recommended spacing is 5, 25, 50, 100 and 200 feet. This may be modified given site conditions, and the anticipated discharge. Smaller flows or smaller scale tests should

concentrate observation wells closer to the test. Wells should be positioned with respect to the groundwater flow direction with the focus of the data collection being down gradient of the test.

Precipitation data should be collected either on site or if a meteorological data collection station is in close proximity this data may be used. Several days prior to and after the test water level data must be collected. Water levels after the test should be collected until stabilization is achieved.

Whether trenches, open beds or other method is proposed, the test shall involve discharge of clean water in the receiving area at a rate at a multiple (such as 5 times) of the anticipated maximum loading rate. After the receiving area is full, the flow shall be decreased incrementally and the rate and corresponding water levels recorded. The goal is to have one step where the flow equals the rate of infiltration of the saturated testing area ( $Q$ ). The final step shall be the design discharge loading rate (if less than the  $Q$ ).

The report shall contain a location map with testing site, well locations, water level elevations and discharge rate numbers. Well boring and installation data shall be provided. Metrological data shall be included along with a summary of the impact of any precipitation. If precipitation has a significant impact on the test is must be performed again.

## APPENDIX C

### REVIEW OF SEWER LINE/WATER SUPPLY PROTECTION

#### DWP Policy #: BRP/DWM/WS/P03-1

The intent of this policy is to protect existing and potential drinking water supplies from potentially negative effects of leaking sewer lines. This policy will apply to new sewer construction and replacement sewer construction statewide.

#### Gravel Packed and Tubular Wells

- Within the Zone I protective distance around gravel packed wells, all sewer lines and appurtenances are prohibited, unless they are necessary to eliminate existing and/or potential sources of pollution to the well.
  
- Within an Interim Wellhead Protection Area (IWPA) or unless otherwise documented by an appropriate study specifically defining the Zone II and approved by the Drinking Water Program, all sewer lines and appurtenances will be designed and constructed for maximum watertightness.
  - **Force Mains or Pressure Sewers:** shall be tested at 150% above maximum operating pressure or 150 p.s.i. whichever is greater. Testing shall conform to the requirements of the American Water Works Association (AWWA) standard C 600.
  - **Gravity Sewers:** shall be tested by approved methods which will achieve test results for infiltration or exfiltration of less than 100 gallons/inch diameter/mile/24 hours.
  - **Manholes:** shall be installed with watertight covers with locking or bolted and gasketed assemblies. Testing for infiltration/exfiltration shall conform to the same standard as the maximum allowed for pipes in the manhole as required for gravity sewers, indicated above.
  - Satisfactory test results for Force Mains, Manholes and Gravity Sewers shall be performed prior to the expiration of the contractor's one year guarantee period.
  - All pumping stations within this zone shall have standby power high water alarms telemetered to an appropriate location that is manned at all times. An emergency contingency plan must be developed by the pumping station owner and approved by the Department.

- A minimum of Class B bedding as defined by WPCF-MOP9 must be used for all piping.
- Service connections (laterals and house connections) shall be rigidly inspected by the appropriate municipal official. Certified inspection reports shall be submitted to the Department.

### **Bedrock Wells**

The above requirements are the same for bedrock wells, with the Department reserving the right to require more stringent controls as necessary to protect public health. Such additional controls may be necessary due to the potential for quicker flow transport through bedrock fracture systems.

### **Surface Water Supplies**

- Within the Zone A of all surface water supplies and tributaries, all sewer lines and appurtenances are prohibited except as required to cross tributaries or to eliminate existing or potential pollution to the water supply. In the latter case watertight construction methods shall be used as described above.
- Tributary stream crossings shall employ watertight construction methods of sewer lines and manholes. Watertight construction must be employed within the Zone A.
- Within 1,000 feet of surface water supplies and tributaries, all pumping stations shall have standby power and high water alarms telemetered to an appropriate location that is manned at all times. An emergency contingency plan must be developed by the owner of the wastewater treatment facility and submitted to the Department for approval.
- Beyond 1,000 feet, and within the watershed of surface water supplies, the Department may in specific circumstances, after review, require additional controls when deemed necessary for protection of public health.

### **Potential Public Water Supplies**

The above requirements also apply to potential public water supplies. A proposed drinking water source that is proceeding through the Source Approval Process and has an approved Zone II/Zone A, and/or an approved withdrawal rate associated with it, will be considered a potential public water supply.

## **Baseline Data Requirements**

Two (2) copies of an appropriately scaled map(s) shall be submitted to the Department which details the proposed sewers and/or appurtenances and also includes the following:

1. the location of all nearby existing or potential surface water supplies, tributaries thereto, and watershed boundaries;
2. the location of existing and potential public and municipal potable groundwater supply wells;

The Department reserves the right to impose more restrictive measures than those contained in this policy as deemed necessary to protect public health.

## **Definitions**

- Appurtenances - all attachments to sewer lines necessary for the transport and operation and maintenance of sewer lines, including manholes, pumping stations, siphons, etc.
- Class B Bedding – as defined in WPCF Manual of Practice No. 9.
- Interim Wellhead Protection Area (IWPA) – For public water systems using wells or wellfields that lack a DEP approved Zone II, the Department will apply an interim wellhead protection area. This interim wellhead protection area shall be a one-half mile radius measured from the well or wellfield for sources whose approved pumping rate is 100,000 gpd or greater. For wells or wellfields that pump less than 100,000 gpd, the IWPA radius is proportional to the approved pumping rate which may be calculated according to the following equation: IWPA radius in feet =  $[32 \times \text{pumping rate in gallons per minute}] + 400$ . [This equation is equivalent to the second graph in Appendix D of the 2001 Guidelines and Policies for Public Water Systems.] A default IWPA radius shall be applied to transient noncommunity (TNC) and nontransient noncommunity (NTNC) wells when there is no metered rate of withdrawal or no approved pumping rate. The default IWPA radius shall be 500 feet for TNC wells and 750 feet for NTNC wells.
- Potential public water supply – areas designated by communities for water supply purposes where land has been set aside and Department approved pump tests conducted and surface water supplies as defined below.
- Public Water Supply Systems – as defined in 310 CMR 22.02 (DEP Drinking Water Regulations).

- Surface Water Supply – Waters classified as Class A by the Department.
- Zone A – (a) the land area between the surface water source and the upper boundary of the bank; (b) the land area within a 400 foot lateral distance from the upper boundary of the bank of a Class A surface water source, as defined in 314 CMR4.05(3)(a), or edge of the watershed, whichever is less; and (c) the land area within a 200 foot lateral distance from the upper boundary of the bank of a tributary or associated surface water body, or edge of watershed, whichever is less.
- Zone I – the protective radius required around a public water supply well or wellfield. For public water system wells with approved yields of 100,000 gpd or greater, the protective radius is 400 feet. Tubular wellfields require a 250 foot protective radius. Protective radii for all other public water system wells are determined by the following equation: Zone I radius in feet =  $[150 \times \log \text{ of pumping rate in gpd}] - 350$ . [This equation is equivalent to the graph in Appendix C.] A default Zone I radius shall be applied to transient noncommunity (TNC) and nontransient noncommunity (NTNC) wells when radii cannot be calculated because there is no metered rate of withdrawal or no approved pumping rate. The default Zone I radius shall be 100 feet for TNC wells and 250 feet for NTNC wells.
- Zone II – that area of an aquifer which contributes water to a well under the most severe pumping and recharge conditions that can be realistically anticipated (180 days of pumping at the approved yield, with no recharge from precipitation). It is bounded by the groundwater divides which result from pumping the well and by the contact of the aquifer with less permeable materials such as till and bedrock. In some cases, streams and lakes may act as recharge boundaries. In all cases, Zone II shall extend upgradient to its point of intersection with prevailing hydrogeologic boundaries (a groundwater flow divide, a contact with till or bedrock, or a recharge boundary).

**APPENDIX D**  
**SUGGESTED MAINTENANCE REQUIREMENTS**

	<b>DUTIES AND RESPONSIBILITIES</b>	<b>Operator</b>	<b>Owner</b>	<b>Shared</b>
1	Responsible for day-to-day operations by certified operators			
2	Ensure permit compliance at all times			
3	Daily inspections of all mechanical equipment			
4	Perform preventative maintenance as required in permit			
5	Measure and observe chemical tanks and usage			
6	Order and purchase chemicals			
7	Maintain proper sludge and tank levels			
8	Schedule and pay for sludge and septic removal as needed			
9	Maintain O&M Manual and equipment maintenance repair logs			
10	Perform in house compliance testing			
11	Maintain proper consumable supplies (oils, grease, PPE, reagents, etc)			
12	Maintain housekeeping and housekeeping supplies			
13	Collect permit required influent, effluent and well samples			
14	Submit reports within time frames specified in permit			
15	Complete and submit annual financial report			
16	Maintain FAM's as specified in permit			
17	Generate submit and pay for permit renewals			
18	Payment of annual DEP fee			
19	Ensure accuracy of flow meter(s) (annual inspection/calibrations)			
20	Accompany regulatory agencies during inspections			
21	Maintain compliant log book			
22	Maintain and file all pertinent plant records			
23	Notify DEP of any spills, bypasses, interruption or significant maintenance events			
24	Generate and submit 15 year engineering report and financial plan			
25	Notify DEP of any proposed transfer of permit			
26	Generate and submit 2-year staffing plan			
27	Annual inspection of potable water backflow prevention device			
28	Annual inspections or re-generation of fire extinguishers			
29	Utility and telecommunication costs			
30	Building and grounds maintenance/upkeep			
31	Generator maintenance scheduling and costs			
32	Snow removal including access to groundwater monitoring wells, pump stations, etc			
33	Major equipment repairs			
34	Maintain spare parts inventory			
35	Alarm responses			
36	Pump station maintenance			
37	Grease trap care and maintenance			
38	Instrumentation maintenance			
39	Coordinate and pay for lab analysis			
40	Maintain safety equipment (eyewash, fire ext., signs, etc)			
41	Maintain and enforce equipment warranties			
42	Maintain appropriate PPE (glasses, gloves, faceshields, etc)			

<i>Equipment/Task</i>	Daily	Twice Weekly	Weekly	Monthly	45 Days	90 Days	105 Days	125 Days	6 Months	Annually
<b>Aerobic RBC</b>										
Check appearance of biomass	X									
Check belts/chains				X						
Inspect bearings				X						
Lubricate bearings				X						
Grease ends				X						
Change speed oil reducer										X
Check reducer oil level				X						
Lubricate motor bearings				X						
Change chain case oil										X
Check load cell pressure ratings										X
Inspect equipment for overall deficiencies	X									
<b>Anoxic RBC</b>										
Check for leaks at seals				X						
Check chain tension				X						
Check shaft lube				X						
Change speed oil reducer										X
Check reducer oil level				X						
Inspect equipment for overall deficiencies	X									
<b>Secondary Clarifier</b>										
Check sludge level			X							
Grease gear reducer fittings									X	
Check clarifier drive	X									
Check motor amperage									X	
Change motors' oil										X
Inspect equipment/motor for overall deficiencies	X									
Clean weir plate/stilling ring			X							
Check weir for levelness				X						
<b>Tertiary Sand Filter</b>										
Check float switches				X						
Initiate and observe backwash cycle				X						
Inspect seals on backwash pumps										X
Clean effluent troughs				X						
Chemical cleaning of media									X	
Check media depth										X
Inspect equipment for overall deficiencies	X									
<b>Denitrification Sand Filter</b>										
Check float switches				X						
Initiate and observe backwash cycle				X						
Inspect seals on backwash pumps										X
Clean effluent troughs				X						
Check media depth										X
Inspect equipment for overall deficiencies	X									
<b>Cloth Filter</b>										
Check float switches				X						
Initiate and observe backwash cycle				X						
Inspect seals on backwash pumps										X
Clean effluent troughs				X						
Chemical cleaning of media										X
Check media depth										X
Inspect equipment for overall deficiencies	X									

<i>Equipment/Task</i>	Daily	Twice Weekly	Weekly	Monthly	45 Days	90 Days	105 Days	125 Days	6 Months	Annually
<b>Bioclere</b>										
Observe biomass (color, quality and depth)				X						
Inspect overall exterior of Bioclere				X						
Observe spray pattern/nozzles				X						
Clean spray nozzles				X						
Inspect fan/lid gaskets				X						
Inspect vent for air passage						X				
Check recycle pumps				X						
Inspect dosing										X
Check dosing/recycle pumps amperage and timers									X	
Check sludge level				X						
<b>Anoxic Reactor</b>										
Observe color of biomass color and quality				X						
Check sludge level				X						
Inspect mixer				X						

<i>Equipment/Task</i>	Daily	Twice Weekly	Weekly	Monthly	45 Days	90 Days	105 Days	125 Days	6 Months	Annually
<b>SBR</b>										
Observe appearance of wastewater	X									
Remove and inspect sludge waste pumps										X
Inspect decant arm/mechanism										X
Inspect decant pumps										X
Inspect air distribution pattern	X									
Drain, clean and inspect SBR Tank										X
Calibrate pH, DO and OPR meters				X						
Inspect equipment for overall deficiencies				X						

<i>Equipment/Task</i>	Daily	Twice Weekly	Weekly	Monthly	45 Days	90 Days	105 Days	125 Days	6 Months	Annually	
<b>Anoxic Chamber(s)</b>											
Check mixer operation				X							
Check Amp draw on mixer motor									X		
Measure DO/ORP	X										
Remove and inspect RAS pump(s)										X	If applicable
Check carbon feed	X										
Drain and inspect tank										X	
<b>Aeration Chamber(s)</b>											
Check air patterns in tank	X										
Check DO	X										
Check pH	X										
Measure MLSS				X							
Drain and inspect tank										X	
Inspect Diffusers										X	
<b>Filtration Zone(s)</b>											
Check flux rates	X										
Check trans-membrane pressure	X										
Check Vac/Psi	X										
Check backwash cycle	X										If applicable
Check air patterns in tank	X										
Check float switches				X							
Check Amp draw - filter pump motor									X		
Inspect filter pumps									X		If applicable
Inspect membranes						X					
Chemically clean membrane										X	or as needed
<b>Backwash System (as applicable)</b>											If applicable
Check level switches				X							
Clean tank						X					
Add Chlorine		X									
Check backwash pressures	X										
Inspect backwash pumps										X	
Check Amp draw - backwash pump motor									X		
<b>Flow Meter</b>											
Calibrate meter										X	

<i>Equipment/Task</i>	Daily	Twice Weekly	Weekly	Monthly	45 Days	90 Days	105 Days	125 Days	6 Months	Annually
<b>Anoxic Zone</b>										
Check mixer operation				X						
Check Amp draw on mixer motor									X	
Measure DO/ORP	X									
Remove and inspect RAS pump(s)										X
Check carbon feed	X									
Drain and inspect tank										X
<b>FAST Reactor</b>										
Check air patterns in tank	X									
Check DO	X									
Check pH	X									
Check sludge depth				X (1)						
Measure MLSS				X						
Check venting				X						
Drain and inspect tank										X
Inspect Diffusers										X
<b>Settling Zone</b>										
Check sludge level			X							
Remove sludge and scum										X
Check tees/baffles				X						
Check sludge/scum depth				X (1)						
Inspect hatches/covers			X							
Check liquid level with respect to outlet invert				X						
<b>Filtration Zone(s)</b>										
<b>See Filtration Worksheet</b>										
<b>Flow Meter</b>										
Calibrate meter										X

(1) Pumping is required whenever the top of the sludge or solids layer is within 12 inches or less of the bottom of the outlet tee or the top of the scum layer is within two inches of the top of the outlet tee or the bottom of the scum layer is within two

<i>Equipment/Task</i>	Daily	Twice Weekly	Weekly	Monthly	45 Days	90 Days	105 Days	125 Days	6 Months	Annually
<b>Anoxic Tank</b>										
Check sludge/scum depth				X						
Check Stilling Well						X				
<b>Amph Reactor</b>										
Inspect float switches/timers/alarms			X							
Witness Backwash Cycle				X						
Test backwash water TSS									X	
Check aeration patterns				X						
Inspect hatches/covers				X						
Inspect liquid level in tank related to normal operation levels			X							
<b>Clearwell</b>										
Inspect float switches/timers/alarms				X						
Check recycle and backwash pumps										
Check Discharge Pumps						X				
Remove and inspect pumps										X
Inspect slide rails/chains				X						
Inspect wiring/junction boxes										X
Inspect hatches/covers				X						
Inspect and exercise valves										X
Inspect liquid level in tank related to normal operation levels			X							
<b>Denite Filter</b>										
Inspect floats			X							
Witness backwash				X						
Test backwash water TSS									X	
Inspect liquid level in tank related to normal operation levels			X							
Check aeration patterns				X						
Inspect hatches/covers				X						
<b>Final Eff Tank</b>										
Inspect Floats				X						
Check backwash pump										
Check discharge pumps										
Check sludge/scum depth										X
Remove and inspect pumps										X
Inspect slide rails/chains				X						
Inspect wiring/junction boxes										X
Inspect hatches/covers				X						
Inspect and exercise valves										X

<i>Equipment/Task</i>	Daily	Twice Weekly	Weekly	Monthly	45 Days	90 Days	105 Days	125 Days	6 Months	Annually
<b>Aeration Tank</b>										
Observe appearance of wastewater	X									
Inspect air distribution pattern	X									
Conduct Settleometer	X									
Measure/Record Dissolved Oxygen	X									
Calibrate pH and DO meters				X						
Review PLC/SCADA System										X
Drain, clean and inspect Aeration tank and diffusers										X
Inspect equipment for overall deficiencies										X
<b>Return/Waste Activated Sludge Pumps</b>										
Check pump operation	X									
Record Suction and Discharge pressure	X									
Record/Observe pump output	X									
Inspect wiring /junction boxes/amperage									X	
Inspect and exercise valves				X						
Check pump oil chambers				X						
Change Oil										X
Check Belts				X						
<b>Tasks to be completed with above schedule or manufacturer's recommended maintenance, whichever is more stringent.</b>										

<i>Equipment/Task</i>	Daily	Twice Weekly	Weekly	Monthly	45 Days	90 Days	105 Days	125 Days	6 Months	Annually
<b>Grease Traps</b>										
Remove grease						X				
Check tees/baffles						X				
Check grease depth				X						
Inspect hatches/covers				X						
Check liquid level with outlet invert				X						
Clean outlet filter				X						
<b>Screens</b>										
Visually inspect functionality/debris build up	X									
Clean screen	X									
Inspect float operation			X							
Lubricate motors/drives/chains				X						
Inspect belts/drives/cables						X				
Inspect motors (amperage)									X	
Visually inspect equipment			X			X				
Inspect fluid levels on motors				X						
<b>Pretreatment Tanks</b>										
Remove sludge and scum										X
Check tees/baffles				X						
Check sludge/scum depth				X (1)						
Inspect hatches/covers			X							
Check liquid level with respect to outlet invert				X						
Clean outlet filter				X						
<b>Primary Clarifier</b>										
Check sludge level			X							
Grease gear reducer fittings									X	
Check clarifier drive	X									
Check motor amperage									X	
Change motors' oil										X
Inspect equipment/muter for overall deficiencies	X									
Clean weir plate/stilling ring			X							
Check weir for levelness				X						
(1) Remove scum/sludge as needed per MassDEP Guidelines necessitating removal (PUT IN EXACT LANGUAGE FROM DEP)										

<i>Equipment/Task</i>	Daily	Twice Weekly	Weekly	Monthly	45 Days	90 Days	105 Days	125 Days	6 Months	Annually
<b>Flow Equalization Tank</b>										
Remove and inspect pumps										X
Check scum/sludge depth				X						
Inspect float switches/timers/alarms				X						
Inspect slide rails/chains				X						
Inspect wiring/junction boxes										X
Inspect hatches/covers				X						
Inspect and exercise valves										X
Inspect liquid level in tank related to normal operation levels			X							
Check aeration patterns				X						
<b>Tasks to be completed with above schedule or manufacturer's recommended maintenance, whichever is more stringent.</b>										

<i>Equipment/Task</i>	Daily	Twice Weekly	Weekly	Monthly	45 Days	90 Days	105 Days	125 Days	6 Months	Annually
<b>Pump Chambers</b>										
Remove and inspect pumps										X
Check scum/sludge depth				X						
Inspect float switches/timers/alarms				X						
Inspect slide rails/chains				X						
Inspect wiring/junction boxes										X
Inspect hatches/covers				X						
Inspect and exercise valves										X
Inspect liquid level in tank related to normal operation levels			X							
Check aeration patterns				X						
<b>Tasks to be completed with above schedule or manufacturer's recommended maintenance, whichever is more stringent.</b>										

<i>Equipment/Task</i>	Daily	Twice Weekly	Weekly	Monthly	45 Days	90 Days	105 Days	125 Days	6 Months	Annually
<b>Tertiary Sand Filter</b>										
Check float switches				X						
Initiate and observe backwash cycle				X						
Inspect seals on backwash pumps										X
Clean effluent troughs				X						
Chemical cleaning of media									X	
Check media depth										X
Inspect equipment for overall deficiencies	X									
<b>Denitrification Sand Filter</b>										
Check float switches				X						
Initiate and observe backwash cycle				X						
Inspect seals on backwash pumps										X
Clean effluent troughs				X						
Check media depth										X
Inspect equipment for overall deficiencies	X									
<b>Cloth Filter</b>										
Check float switches				X						
Initiate and observe backwash cycle				X						
Inspect seals on backwash pumps										X
Clean effluent troughs				X						
Chemical cleaning of media										X
Check media depth										X
Inspect equipment for overall deficiencies	X									
<b>Tasks to be completed with above schedule or manufacturer's recommended maintenance, whichever is more stringent.</b>										

<i>Equipment/Task</i>	Daily	Twice Weekly	Weekly	Monthly	45 Days	90 Days	105 Days	125 Days	6 Months
<b>Blowers</b>									
Check belts				X					
Inspect air filter				X					
Check oil level				X					
Change air filter									
Change oil									
Grease motor bearings									
Check amperage									X
<b>Tasks to be completed with above schedule or manufacturer's recommended maintenance, whichever is more stringent.</b>									

<i>Equipment/Task</i>	Daily	Twice Weekly	Weekly	Monthly	45 Days	90 Days	105 Days	125 Days	6 Months	Annually
<b>UV Disinfection</b>										
Replace bulbs										X
Clean UV sleeves				X						
Clean sensor				X						
Check UV intensity meter	X									
Inspect for leakage/damage	X									
Test UV system alarms				X						
Inspect effluent quality into UV system (turbidity)	X									
Clean effluent channel				X						
<b>Chlorine Disinfection</b>										
Check chlorine residual	X									
Check/adjust feed pump	X									
Review tablet/liquid chlorinator supply	X									
Review mixing/distribution	X									

<i>Equipment/Task</i>	Daily	Twice Weekly	Weekly	Monthly	45 Days	90 Days	105 Days	125 Days	6 Months	Annually
<b>House Keeping</b>										
Observe ventilation system			X							
Observe Humidity Control System				X						
Maintain/Inventory spare parts						X				
Replace/Maintain Lights										X
Review safety issues of facility				X						
Maintain Standby Power System									X	
Check Cathodic Protection										X
Clean facility			X							
Remove/dispose of lubricants/fluids and/or spills	X									
<b>Odor Control</b>										
Check media									X	
Check blower operation				X						
Change passive carbon vent media										X
Check demister system				X						

<i>Equipment/Task</i>	Daily	Twice Weekly	Weekly	Monthly	45 Days	90 Days	105 Days	125 Days	6 Months	Annually
<b>pH Adjustment</b>										
Check pump operation	X									X
Inspect for leaks				X						
Check chemical inventory	X									
Calibrate pH sensor				X						
Inspect for leakage/damage	X									
<b>Alkalinity Adjustment</b>										
Check pump operation	X									X
Inspect for leaks				X						
Check chemical inventory	X									
Check alkalinity	X			X						
Inspect for leakage/damage	X									
<b>Coagulant Feed</b>										
Check pump operation	X									X
Inspect for leaks				X						
Check chemical inventory	X									
Inspect for leakage/damage	X									
<b>Supplemental Carbon Feed</b>										
Check pump operation	X									X
Inspect for leaks				X						
Check chemical inventory	X									
Inspect for leakage/damage	X									
Check grounding/bonding (methanol)	X									





