

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 102 | 09-01-13 | Candidate Number | | |
| Skill Title: DAILY IN-SERVICE INSPECTION OF SCBA | | | | | |
| NFPA Objective: | 5.3.1 | Minimum to pass | 12 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-----|--|--|--|--|--|
| 1. | Checks integrity of hose connections for stress cracks, tightness, tears, wrinkles or, excessive wear. | | | | |
| 2. | Checks integrity of harness for rips, tears, cleanliness, and full extension. | | | | |
| 3. | Checks backpack and cylinder assembly for unusual wear or damage. | | | | |
| 4. | Checks integrity of facepiece for cracking and that straps are fully extended. | | | | |
| 5. | Checks facepiece lens for excessive scratches, cracks or separation from mask. | | | | |
| 6. | Checks hydrostatic test date. | | | | |
| 7. | Checks position of mainline, by-pass, don/doffing switch and positive pressure valves. (Manufacturer dependent) | | | | |
| 8. | Checks cylinder pressure and determine if full. (90% or above-2216 psi 1994/4500 psi= 4050) | | | | |
| 9. | Opens cylinder valve fully, checking for low air audible alarm. (Alarm should sound when cylinder valve is opened) | | | | |
| 10. | Integrated PASS device turns on and sounds, if equipped. | | | | |
| 11. | Compares cylinder gauge to remote pressure gauge. (Difference between cylinder and remote gauge shall not exceed 100 psi) | | | | |
| 12. | Checks operation of by-pass, purge, and mainline valves. (Manufacturer dependent) | | | | |
| 13. | Checks operation of PASS. | | | | |
| 14. | Connects facepiece to regulator and inhales to inspect operation of the regulator. | | | | |
| 15. | Closes cylinder valve and continues inhaling to check the activation of the low air alarm. | | | | |
| 16. | Deactivates PASS device, if integrated. | | | | |
| 17. | Detaches the facepiece and returns SCBA to original area ready for donning. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | |
|--|-----------|-----------------|------------------|---|
| Skill Sheet No. | FF-I- 103 | 09-01-13 | Candidate Number | |
| Skill Title: DON SCBA – OVER THE HEAD METHOD | | | | |
| NFPA Objective: | 5.3.1 | Minimum to pass | 13 | |
| PERFORMANCE: | | | P | F |

| | | | | | |
|--|-----|--|--|--|--|
| | 1. | Crouches or kneels at end of SCBA opposite cylinder valve. | | | |
| | 2. | Checks cylinder gauge and determines if full. (90% or above-2216 psi= 1994/4500 psi=4050) | | | |
| | 3. | Opens cylinder valve to its maximum. Low air alarm must sound and PASS device must turn on. | | | |
| | 4. | Compares cylinder gauge to remote pressure gauge. (Difference between cylinder and remote gauge shall not exceed 100 psi) | | | |
| | 5. | Grasps backplate/harness assembly with both hands. | | | |
| | 6. | Raises backplate/harness assembly over head. | | | |
| | 7. | Places and balances backplate/cylinder assembly on upper back. | | | |
| | 8. | Connects necessary buckles and adjusts underarm straps until snug. | | | |
| | 9. | Connects waist strap and adjusts until snug. | | | |
| | 10. | Dons facepiece. | | | |
| | 11. | Performs facepiece fit test. Adjusts straps if needed. | | | |
| | 12. | Connects facepiece to regulator. (Activate positive pressure from air supply.) | | | |
| | 13. | Properly dons protective hood, completely covering head and shoulders. | | | |
| | 14. | Dons helmet with ear covers down. | | | |
| | 15. | Connects and adjusts chinstrap under chin and not facepiece. | | | |
| | 16. | Turns on PASS device, if not integrated. | | | |
| | 17. | Dons gloves. | | | |
| | 18. | All Personal Protective Equipment is properly worn. | | | |
| | 19. | Completes within one minute. * | | | |
| | | *NOTE: Timing of this skill will begin when the examiner states “please begin” and will stop when the candidate takes his/her first positive pressure breath from a properly sealed facepiece. | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | |
|---------------------------------------|-----------|-----------------|------------------|---|
| Skill Sheet No. | FF-I- 104 | 09-01-13 | Candidate Number | |
| Skill Title: DON SCBA-OVERCOAT METHOD | | | | |
| NFPA Objective: | 5.3.1 | Minimum to pass | 14 | |
| PERFORMANCE: | | | P | F |

| | | | | | | |
|--|-----|--|--|--|--|--|
| | 1. | Crouches or kneels at end of SCBA with cylinder valve. | | | | |
| | 2. | Checks cylinder gauge and determine if full. (90% or above- 2216 psi= 1994/4500 psi-4050) | | | | |
| | 3. | Opens cylinder valve to its maximum. Low air alarm must sound and PASS device must turn on. | | | | |
| | 4. | Compares cylinder gauge to remote pressure gauge. (Difference between cylinder and remote gauge shall not exceed 100 psi) | | | | |
| | 5. | Grasps right (left) shoulder strap with right (left) hand. | | | | |
| | 6. | Raises SCBA and rest right (left) strap on right (left) shoulder. | | | | |
| | 7. | Inserts opposite arm through other strap having entire unit rest on both shoulders. | | | | |
| | 8. | Connects necessary buckles and adjusts underarm straps until snug. | | | | |
| | 9. | Connects waist strap and adjusts until snug. | | | | |
| | 10. | Dons facepiece. | | | | |
| | 11. | Performs facepiece fit test. Adjust straps if needed. | | | | |
| | 12. | Connects facepiece to regulator. (Activate positive pressure from air supply.) | | | | |
| | 13. | Properly dons protective hood, completely covering head and shoulders. | | | | |
| | 14. | Dons helmet with ear covers down. | | | | |
| | 15. | Connects and adjusts chinstrap under chin and not facepiece. | | | | |
| | 16. | Turns on PASS device, if not integrated. | | | | |
| | 17. | Dons gloves. | | | | |
| | 18. | All Personal Protective Equipment is properly worn. | | | | |
| | 19. | Completes within one minute. * | | | | |
| | | | | | | |
| | | *NOTE: Timing of this skill will begin when the examiner states "please begin" and will stop when the candidate takes his/her first positive pressure breath from a properly sealed facepiece. | | | | |

| | | |
|----------------------|------------------|--|
| | ■ | Failure of this critical portion is cause for entire skill failure |
| Examiner Name: _____ | Signature: _____ | Date: ___/___/___ |
| Please circle: | PASS | FAIL |
| | | RETAKE |

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | |
|---|-----------|-----------------|------------------|---|
| Skill Sheet No. | FF-I- 105 | 09-01-13 | Candidate Number | |
| Skill Title: SCBA CYLINDER REPLACEMENT-ONE FIREFIGHTER METHOD | | | | |
| NFPA Objective: | 5.3.1 | Minimum to pass | 12 | |
| PERFORMANCE: | | | P | F |

| | | | | | |
|-----|--|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Obtain a full air cylinder. (90% or above-2216 psi=1944/4500 psi=4050) | | | | |
| 3. | Disconnect facepiece from the regulator. | | | | |
| 4. | Close the cylinder valve on the used bottle. | | | | |
| 5. | Release pressure from high-pressure hoseline through regulator system and not by disconnecting high pressure hoseline from empty cylinder. | | | | |
| 6. | Reset PASS device. | | | | |
| 7. | Once all pressure is released, disconnect high-pressure hoseline from empty cylinder. | | | | |
| 8. | Release cylinder clamps. | | | | |
| 9. | Remove used cylinder. | | | | |
| 10. | Check replacement cylinder opening for debris. Open cylinder valve to clear debris if necessary. | | | | |
| 11. | Check high-pressure hoseline connection O-ring for integrity. | | | | |
| 12. | Install replacement cylinder into harness. | | | | |
| 13. | Connect high-pressure hoseline connection hand tight. | | | | |
| 14. | Adjust cylinder in harness and secure clamps. | | | | |
| 15. | Open cylinder valve and check regulator gauge. (Difference between cylinder and remote gauge shall not exceed 100 psi) | | | | |
| 16. | Close cylinder valve. | | | | |
| 17. | Release all pressure through regulator system. | | | | |
| 18. | Reset PASS device. | | | | |
| 19. | Place unit back in service. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|------------------------|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 106 | 09-01-13 | Candidate Number | | |
| Skill Title: DOFF SCBA | | | | | |
| NFPA Objective: | 5.3.1 | Minimum to pass | 13 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-------------------------------------|-----|---|--------------------------|--------------------------|--------------------------|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 2. | Remove gloves. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 3. | Deactivate positive pressure if so equipped and disconnect facepiece from regulator. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 4. | Release chin strap and remove helmet. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 5. | Slide protective hood, if utilized, off head and down around neck. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 6. | Release facepiece straps and remove facepiece. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 7. | Extend facepiece straps fully. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 8. | Disconnect and fully extend waist strap. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 9. | Crouch or kneel to the ground. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 10. | Lean forward and release shoulder strap buckles and fully extend straps. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 11. | Grasp shoulder strap, which has regulator attached, with the same side hand. (Manufacturer dependent) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 12. | Remove arm from opposite side shoulder strap. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 13. | Grasp regulator, if on shoulder strap, with free hand. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 14. | Remove remaining shoulder strap while still protecting regulator. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 15. | Lower unit to ground or in case. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 16. | Close cylinder valve. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 17. | Release all pressure through regulator system. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 18. | Turns off PASS device. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---------------------------------------|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 201 | 09-01-13 | Candidate Number | | |
| Skill Title: CONDUCT A PRIMARY SEARCH | | | | | |
| NFPA Objective: | 5.3.9 | Minimum to pass | 8 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|--------------------------|-----|--|--|--|--|--|
| <input type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn including SCBA and PASS device. | | | | |
| <input type="checkbox"/> | 2. | Carries a forcible entry tool. | | | | |
| <input type="checkbox"/> | 3. | Searches on hands and knees in low visibility. | | | | |
| <input type="checkbox"/> | 4. | Starts and maintains "left" or "right" search pattern. | | | | |
| <input type="checkbox"/> | 5. | Searches behind and under all objects. | | | | |
| <input type="checkbox"/> | 6. | Searches all areas such as closets, showers, etc. | | | | |
| <input type="checkbox"/> | 7. | Searches one room before moving onto the next. | | | | |
| <input type="checkbox"/> | 8. | Pauses occasionally to listen for cries for help, other rescuers, etc. | | | | |
| <input type="checkbox"/> | 9. | Moves up and down stairs, head always up. | | | | |
| <input type="checkbox"/> | 10. | Finds victim. | | | | |
| <input type="checkbox"/> | 11. | Notifies Command or Supervisor of Location, Identification, and Problem (victim rescue) | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|----------------------------------|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 203 | 09-01-13 | Candidate Number | | |
| Skill Title: BLANKET DRAG RESCUE | | | | | |
| NFPA Objective: | 5.3.9 | Minimum to pass | 7 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-----------|---|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn including SCBA. | | | | |
| 2. | Positions victim for rescue by rolling victim onto the back, if necessary. | | | | |
| 3. | Places a blanket beside victim with edge toward victim and gathers blanket close to victim's side. | | | | |
| 4. | Rolls victim toward rescuer and gathers blanket under victim. | | | | |
| 5. | Rolls victim back onto blanket and straightens blanket. | | | | |
| 6. | Wraps victim in blanket | | | | |
| 7. | Rescuer repositions at the victims' head. | | | | |
| 8. | Grasps the blanket on each side of the victim's head and raises victim's head and shoulders off of floor. | | | | |
| 9. | Drags victim to safety using the blanket drag. | | | | |



Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 204 | 09-01-13 | Candidate Number | | |
| Skill Title: EXTREMITIES CARRY RESCUE-RESCUER ONE | | | | | |
| NFPA Objective: | 5.3.9 | Minimum to pass | | 5 | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-----------|--|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn including SCBA. | | | | |
| 2. | Rescuer stands at the victim's head. | | | | |
| 3. | With assistance from rescuer two, positions victim into a sitting position | | | | |
| 4. | Kneels and slips arms underneath the victim's arms and grasps the victim's wrists. | | | | |
| 5. | Stands using leg, not back muscles. | | | | |
| 6. | Carries the victim to safety using the extremities carry. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 205 | 09-01-13 | Candidate Number | | |
| Skill Title: EXTREMITIES CARRY RESCUE-RESCUER TWO | | | | | |
| NFPA Objective: | 5.3.9 | Minimum to pass | 5 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-----------|---|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn including SCBA. | | | | |
| 2. | Rescuer stands at the victim's feet. | | | | |
| 3. | Grasps victims arms and assists rescuer one in moving victim to a sitting position | | | | |
| 4. | Facing away from the victim, kneels with feet together between the victim's legs and grasps the victim under the knees. | | | | |
| 5. | Stands using leg, not back muscles. | | | | |
| 6. | Carries the victim to safety using the extremities carry. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 206 | 09-01-13 | Candidate Number | | |
| Skill Title: THROUGH THE LOCK ENTRY PROCEDURES WITH THE K-TOOL | | | | | |
| NFPA Objective: | 5.3.4 | Minimum to pass | 8 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|--------------------------|-----|---|--------------------------|--------------------------|--------------------------|
| <input type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 2. | Tries to open the door to determine if actually locked. (try before you pry) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 3. | Identifies lock type. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 4. | Selects the correct tool(s) for through the lock entry. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 5. | Assures faceshield is lowered into position. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 6. | Places K-tool into position behind the ring and face of the cylinder. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 7. | Inserts halligan bar onto the K tool and forces the K tool onto the cylinder. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 8. | Pries the cylinder from the door. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 9. | Inserts key tool(s) into the cylinder hole. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 10. | Moves locking bolt to open position. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 11. | Opens the door using the K-tool through the lock method. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | |
|-----------------|-----------|----------|------------------|--|
| Skill Sheet No. | FF-I- 301 | 09-01-13 | Candidate Number | |
|-----------------|-----------|----------|------------------|--|

Skill Title: **FIGURE EIGHT**

| | | | |
|-----------------|--------|-----------------|---|
| NFPA Objective: | 5.3.20 | Minimum to pass | 5 |
|-----------------|--------|-----------------|---|

| | | |
|--------------|---|---|
| PERFORMANCE: | P | F |
|--------------|---|---|

| | | | | | | |
|--|----|---|--|--|--|--|
| | 1. | Makes a loop in the working end of the rope. | | | | |
| | 2. | Passes the working end completely around the standing part. | | | | |
| | 3. | Inserts the working end back through the loop. | | | | |
| | 4. | Dresses the knot by pulling the working end and the standing part at the same time. | | | | |
| | 5. | Completes the correct figure eight (stopper knot) and displays to the examiner. | | | | |
| | 6. | Completes within 1 minute. | | | | |
| | | | | | | |
| | | | | | | |
| | | Note: Gloves are not required while tying knots. | | | | |

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | |
|-----------------|-----------|----------|------------------|--|
| Skill Sheet No. | FF-I- 302 | 09-01-13 | Candidate Number | |
|-----------------|-----------|----------|------------------|--|

Skill Title: **FIGURE EIGHT ON A BIGHT**

| | | | |
|-----------------|--------|-----------------|---|
| NFPA Objective: | 5.3.20 | Minimum to pass | 6 |
|-----------------|--------|-----------------|---|

| | | |
|--------------|---|---|
| PERFORMANCE: | P | F |
|--------------|---|---|

| | | | | | | |
|--|----|---|--|--|--|--|
| | 1. | Forms a bight in the working end of the rope. | | | | |
| | 2. | Pass it over the standing part to form a loop. | | | | |
| | 3. | Pass the bight under the standing part and then over the loop and down through it; this forms the figure eight. | | | | |
| | 4. | Extend the bight through the knot to whatever size working loop is needed. | | | | |
| | 5. | Dresses the knot. | | | | |
| | 6. | Uses an overhand safety knot on the working end to secure the knot. | | | | |
| | 7. | Completes the correct figure eight on a bight and displays to the examiner. | | | | |
| | 8. | Completes within one minute | | | | |
| | | | | | | |
| | | | | | | |
| | | Note: Gloves are not required while tying knots. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | |
|-----------------|-----------|----------|------------------|--|
| Skill Sheet No. | FF-I- 303 | 09-01-13 | Candidate Number | |
|-----------------|-----------|----------|------------------|--|

Skill Title: SHEET BEND OR BECKET BEND

| | | | |
|-----------------|--------|-----------------|---|
| NFPA Objective: | 5.3.20 | Minimum to pass | 5 |
|-----------------|--------|-----------------|---|

| | | |
|--------------|---|---|
| PERFORMANCE: | P | F |
|--------------|---|---|

| | | | | | | |
|--|----|--|--|--|--|--|
| | 1. | Forms a bight in the end of the larger diameter rope to be tied. | | | | |
| | 2. | Brings the running part of the smaller diameter rope through the middle and around both parts of the larger diameter rope bight. | | | | |
| | 3. | Tucks the smaller diameter rope under its own standing part and over the larger diameter rope standing part. | | | | |
| | 4. | Dresses the knot by pulling the appropriate ends at the same time. | | | | |
| | 5. | Completes the correct sheet bend or becket bend and displays to the examiner. | | | | |
| | 6. | Completes within one minute | | | | |
| | | | | | | |
| | | | | | | |
| | | Note: Gloves are not required while tying knots. | | | | |

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | |
|-----------------|-----------|----------|------------------|--|
| Skill Sheet No. | FF-I- 304 | 09-01-13 | Candidate Number | |
|-----------------|-----------|----------|------------------|--|

Skill Title: OVERHAND SAFETY KNOT

| | | | |
|-----------------|--------|-----------------|---|
| NFPA Objective: | 5.3.20 | Minimum to pass | 4 |
|-----------------|--------|-----------------|---|

| | | |
|--------------|---|---|
| PERFORMANCE: | P | F |
|--------------|---|---|

| | | | | | | |
|--|----|---|--|--|--|--|
| | 1. | Brings the working end by the standing part, forming a loop. | | | | |
| | 2. | Continues working end back around the standing part, then directs the working end through the loop. | | | | |
| | 3. | Dresses the knot by pulling the appropriate ends at the same time. | | | | |
| | 4. | Completes the correct overhand safety knot and displays to the examiner. | | | | |
| | 5. | Completes within 1 minute. | | | | |
| | | | | | | |
| | | | | | | |
| | | Note: Gloves are not required while tying knots. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 305 | 09-01-13 | Candidate Number | | |
| Skill Title: HOIST A LADDER USING A BOWLINE | | | | | |
| NFPA Objective: | 5.3.20 | Minimum to pass | 10 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|-------------------------------------|-----|---|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. | Measures sufficient rope to form the size of the knot as required by the ladder to hoist. | | | | |
| <input type="checkbox"/> | 3. | Ties a bowline. | | | | |
| <input type="checkbox"/> | 4. | Ties an overhand safety knot in the working end of the rope | | | | |
| <input checked="" type="checkbox"/> | 5. | Displays correctly completed bowline and safety knot to the examiner. | | | | |
| <input type="checkbox"/> | 6. | Brings loop up between rungs and back to the tip. | | | | |
| <input type="checkbox"/> | 7. | Pulls the standing part, tightening the loops around the beams. | | | | |
| <input checked="" type="checkbox"/> | 8. | Applies bowline to ladder properly for hoisting. | | | | |
| <input type="checkbox"/> | 9. | Completes to this point within 2 minutes. | | | | |
| <input type="checkbox"/> | 10. | Dons gloves if removed to tie knot. | | | | |
| <input type="checkbox"/> | 11. | Hoists the ladder at least fifteen (15) feet. | | | | |
| <input type="checkbox"/> | 12. | Lowers the ladder to the ground. | | | | |
| <input type="checkbox"/> | 13. | Unties the knot and returns the rope and ladder to its original area. | | | | |
| | | | | | | |
| | | | | | | |
| | | Note: Gloves are not required while tying knots. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | |
|-----------------|-----------|----------|------------------|--|
| Skill Sheet No. | FF-I- 306 | 09-01-13 | Candidate Number | |
|-----------------|-----------|----------|------------------|--|

Skill Title: **HOIST A PIKE POLE**

| | | | |
|-----------------|--------|-----------------|---|
| NFPA Objective: | 5.3.20 | Minimum to pass | 7 |
|-----------------|--------|-----------------|---|

| | | |
|--------------|---|---|
| PERFORMANCE: | P | F |
|--------------|---|---|

| | | | | | | |
|----------|-----|---|--|--|--|--|
| ■ | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| | 2. | Approximately twelve (12) inches from the end of the pike pole handle applies a clove hitch. | | | | |
| | 3. | Ties an overhand safety knot. | | | | |
| | 4. | Ties two additional half hitches around the pike pole with one in the middle of the handle and one on the head just below the pike. | | | | |
| ■ | 5. | Completes the correct knots and displays to the examiner. | | | | |
| | 6. | Completes to this point within 2 minutes. | | | | |
| | 7. | Dons gloves if removed to tie knot. | | | | |
| ■ | 8. | Hoists the pike pole, pike up, at least fifteen (15) feet. | | | | |
| | 9. | Lowers the pike pole to the ground. | | | | |
| | 10. | Unties the knots and returns the rope and the pike pole to its original area. | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | Note: Gloves are not required while tying knots. | | | | |

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | |
|-----------------|-----------|----------|------------------|--|
| Skill Sheet No. | FF-I- 307 | 09-01-13 | Candidate Number | |
|-----------------|-----------|----------|------------------|--|

Skill Title: **HOIST A CHARGED HOSELINE**

| | | | |
|-----------------|--------|-----------------|---|
| NFPA Objective: | 5.3.20 | Minimum to pass | 7 |
|-----------------|--------|-----------------|---|

| | | |
|--------------|---|---|
| PERFORMANCE: | P | F |
|--------------|---|---|

| | | | | | |
|------------|--|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Approximately twelve (12) inches below the nozzle and its coupling ties a clove hitch. | | | | |
| 3. | Ties an overhand safety knot over the clove hitch. | | | | |
| 4. | Ties a half hitch through the nozzle handle and around the nozzle itself in a manner that allows the rope to hold the nozzle shut while it is being hoisted. | | | | |
| 5. | Displays correctly completed clove hitch and safety knot to the examiner. | | | | |
| 6. | Completes to this point within 2 minutes. | | | | |
| 7. | Dons gloves if removed to tie knot. | | | | |
| 8. | Hoists the charged hoseline at least fifteen (15) feet. | | | | |
| 9. | Lowers the charged hoseline to the ground. | | | | |
| 10. | Unties the knots and returns the rope and the hoseline to its original area. | | | | |
| | | | | | |
| | | | | | |
| | Note: Gloves are not required while tying knots. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 309 | 09-01-13 | Candidate Number | | |
| Skill Title: SECURE THE TIP OF A LADDER | | | | | |
| NFPA Objective: | 5.3.20 | Minimum to pass | 4 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|--|-----------|--|--|--|--|--|
| | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| | 2. | From the inside of the building, ties a clove hitch with an overhand safety knot on a ladder rung which is on the same plane as the window sill. | | | | |
| | 3. | Places a pike pole across the base of the window sill. | | | | |
| | 4. | Ties another clove hitch with an overhand safety knot to the pike pole making the rope tight between the ladder and the pike pole. | | | | |
| | 5. | Displays correctly completed clove hitch and safety knot to the examiner. | | | | |
| | 6. | Completes within 2 minutes. | | | | |
| | | | | | | |
| | | | | | | |
| | | Note: Gloves are not required while tying knots. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|----------------------------|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 311 | 09-01-13 | Candidate Number | | |
| Skill Title: TIE A BOWLINE | | | | | |
| NFPA Objective: | 5.3.20 | Minimum to pass | 6 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-------------------------------------|----|---|-------------------------------------|-------------------------------------|--------------------------|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 2. | Selects enough rope to form the desired size knot | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 3. | Form an overhand loop in the standing part and pass the working end upward through the loop | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 4. | Pass the working end over the top of the loop, and around the back of the standing part | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 5. | Bring the working end back down through the loop, forming an inside bowline | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 6. | Applies an over hand safety knot with the working end | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 7. | Completes the correct bowline and displays to the examiner | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 8. | Completes within one minute | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | | | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | | Note: Gloves are not required while tying knots. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|----------------------------|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 401 | 09-01-13 | Candidate Number | | |
| Skill Title: STRAIGHT ROLL | | | | | |
| NFPA Objective: | 5.5.2 | Minimum to pass | 7 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|-------------------------------------|----|--|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. | Lays out hose on a flat surface. | | | | |
| <input type="checkbox"/> | 3. | Removes twists and lays hose flat in a straight line. | | | | |
| <input checked="" type="checkbox"/> | 4. | If hose contains water, female coupling shall be on the downhill side. | | | | |
| <input type="checkbox"/> | 5. | Positions self at male coupling. | | | | |
| <input type="checkbox"/> | 6. | Male coupling is rolled onto hose toward female end. | | | | |
| <input type="checkbox"/> | 7. | Upon reaching female end the roll is laid on ground. | | | | |
| <input type="checkbox"/> | 8. | Any protruding coils are gently tamped with foot. | | | | |
| <input checked="" type="checkbox"/> | 9. | Completes the straight roll. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|------------------------------|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 402 | 09-01-13 | Candidate Number | | |
| Skill Title: TWIN DONUT ROLL | | | | | |
| NFPA Objective: | 5.5.2 | Minimum to pass | 6 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|-------------------------------------|----|--|--------------------------|--------------------------|--------------------------|--------------------------|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 2. | Lays out hose on a flat surface. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 3. | If hose contains water, couplings shall be on the downhill side. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 4. | Lays hose halves parallel to each other, flat and untwisted. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 5. | Folds the loop onto both hose sections. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 6. | Rolls both lines simultaneously toward coupling ends. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 7. | Upon completion of the roll secures the roll with a rope or strap. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 8. | Completes twin donut roll. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

| | |
|-------------------------------------|--|
| <input checked="" type="checkbox"/> | Failure of this critical portion is cause for entire skill failure |
| Examiner Name: _____ | Signature: _____ Date: ___/___/___ |
| Please circle: | <input type="radio"/> PASS <input type="radio"/> FAIL <input type="radio"/> RETAKE |

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 403 | 09-01-13 | Candidate Number | | |
| Skill Title: SELF-LOCKING TWIN DONUT ROLL | | | | | |
| NFPA Objective: | 5.5.2 | Minimum to pass | 9 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-------------------------------------|-----|--|-------------------------------------|-------------------------------------|--------------------------|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 2. | Lays out hose on a flat surface. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 3. | If hose contains water, couplings shall be on the downhill side. | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 4. | Lays hose halves parallel to each other, flat and untwisted. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 5. | Crosses one side of the hose over the other about three (3) feet from fold, keeping hose flat. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 6. | Positions self at fold facing couplings. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 7. | Brings the backside of the loop forward and places it on top where the hose crosses. | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 8. | Starting at cross, rolls both lines simultaneously toward couplings. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 9. | Pulls one side of the loop through the roll to form one large and one small loop. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 10. | Places long loop through the short loop just behind the couplings. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 11. | Tightens roll snugly forming the shoulder sling. | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 12. | Completes the self-locking twin donut roll. | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | |
|-----------------|-----------|----------|------------------|--|
| Skill Sheet No. | FF-I- 407 | 09-01-13 | Candidate Number | |
|-----------------|-----------|----------|------------------|--|

Skill Title: **HOSELINE EXTENSION**

| | | | |
|-----------------|--------|-----------------|---|
| NFPA Objective: | 5.3.10 | Minimum to pass | 7 |
|-----------------|--------|-----------------|---|

| | | |
|--------------|---|---|
| PERFORMANCE: | P | F |
|--------------|---|---|

| | | | | | |
|------------|---|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Carries hose sections to the nozzle end of the hoseline. | | | | |
| 3. | Applies a hose clamp approximately 5 feet from the nozzle. | | | | |
| 4. | Opens nozzle to relieve pressure. | | | | |
| 5. | Removes the nozzle utilizing either the foot-tilt or the over-hip method. | | | | |
| 6. | Connects the additional sections of hose hand tight. | | | | |
| 7. | Reconnects the nozzle to the extended hoseline hand tight. | | | | |
| 8. | Checks that the nozzle is closed. | | | | |
| 9. | Slowly releases the hose clamp. | | | | |
| 10. | Straightens the hoseline to remove kinks. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 408 | 09-01-13 | Candidate Number | | |
| Skill Title: REPLACE A SECTION IN A CHARGED LINE | | | | | |
| NFPA Objective: | 5.3.10 | Minimum to pass | 6 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-----------|--|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Applies a hose clamp on the supply side approximately 5 feet from the coupling of the hose to be replaced. | | | | |
| 3. | Carries two new sections of hose to the site of replacement. | | | | |
| 4. | Uncouples the damaged section of hose utilizing either the foot-tilt or the over-hip method. | | | | |
| 5. | Removes damaged sections. | | | | |
| 6. | Replaces damaged section with both replacement hoses until hand-tight. | | | | |
| 7. | Slowly releases the hose clamp. | | | | |
| 8. | Straightens the hoseline to remove kinks. | | | | |



Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 409 | 09-01-13 | Candidate Number | | |
| Skill Title: NOZZLE OPERATION AND STREAM ADJUSTMENT | | | | | |
| NFPA Objective: | 5.3.10 | Minimum to pass | 8 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|-------------------------------------|-----|---|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. | Holds the nozzle with one hand and grasps the hose with the other hand. | | | | |
| <input type="checkbox"/> | 3. | Straightens the hoseline behind the nozzle a distance of at least ten (10) feet. | | | | |
| <input type="checkbox"/> | 4. | Faces the direction of stream projection. | | | | |
| <input type="checkbox"/> | 5. | Anchors the hose to the ground with a foot and cradles it against the front of the body or hip. | | | | |
| <input checked="" type="checkbox"/> | 6. | Upon direction from the examiner, the candidate slowly opens the nozzle. | | | | |
| <input type="checkbox"/> | 7. | Sets the nozzle pattern on straight stream upon direction from the examiner. | | | | |
| <input type="checkbox"/> | 8. | Sets the nozzle pattern for a narrow angle fog (long-reach) pattern upon direction from the examiner. | | | | |
| <input type="checkbox"/> | 9. | Sets the nozzle pattern for a wide angle for (short-reach) pattern upon direction from the examiner. | | | | |
| <input checked="" type="checkbox"/> | 10. | Slowly closes the nozzle upon direction from the examiner. | | | | |
| <input checked="" type="checkbox"/> | 11. | Completes nozzle operation without losing control of nozzle. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | |
|--|-----------|-----------------|------------------|---|
| Skill Sheet No. | FF-I- 410 | 09-01-13 | Candidate Number | |
| Skill Title: UNCHARGED HOSELINE ADVANCEMENT UP A LADDER-NOZZLE | | | | |
| NFPA Objective: | 5.3.10 | Minimum to pass | 4 | |
| PERFORMANCE: | | | P | F |

| | | | | | |
|-----------|--|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Carries the nozzle on the back with the hose going over the shoulder towards the front then under the arm to the rear. | | | | |
| 3. | Advances the hoseline by climbing the ladder keeping the hanging loop of hose outside the ladder beam. | | | | |
| 4. | Advances to the first fly section and awaits the backup firefighter | | | | |
| 5. | Advances the hoseline to a point as directed by the examiner. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 411 | 09-01-13 | Candidate Number | | |
| Skill Title: UNCHARGED HOSELINE ADVANCEMENT UP A LADDER-BACKUP | | | | | |
| NFPA Objective: | 5.3.10 | Minimum to pass | 5 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-------------------------------------|----|--|-------------------------------------|-------------------------------------|-------------------------------------|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| <input type="checkbox"/> | 2. | Takes the hose approximately 20-25 feet behind the nozzle. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 3. | Places a loop of hose over the shoulder keeping the hose on the same side as the nozzle fighter. | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| <input type="checkbox"/> | 4. | Moves up to approximately ten (10) feet behind the nozzle firefighter. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 5. | Advances the hoseline by climbing the ladder keeping the hanging loop of hose outside the ladder beam. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 6. | Advances the hoseline to a point as directed by the examiner. | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | |
|---|-----------|-----------------|------------------|----------|
| Skill Sheet No. | FF-I- 412 | 09-01-13 | Candidate Number | |
| Skill Title: OPERATE A CHARGED LINE FROM A LADDER | | | | |
| NFPA Objective: | 5.3.10 | Minimum to pass | | 4 |
| PERFORMANCE: | | | | P F |

| | | | | | |
|-------------------------------------|----|---|--------------------------|--------------------------|--------------------------|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 2. | Places the nozzle between two of the ladder rungs. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 3. | Secures a leg lock to the ladder. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 4. | Secures the hoseline to the ladder rung using a hose strap, rope etc. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 5. | Opens and closes the nozzle slowly as directed by the examiner. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |



Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 413 | 09-01-13 | Candidate Number | | |
| Skill Title: CONNECT AND ADVANCE A HOSE LINE FROM A STANDPIPE – NOZZLE POSITION/CREW LEADER | | | | | |
| NFPA Objective: | 5.3.10 | Minimum to pass | 9 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|------------|--|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Carries hose into the structure to the standpipe, via the stairwell, to one (1) level below the fire floor. | | | | |
| 3. | Lays hose in stairwell on landing. | | | | |
| 4. | Advances the fire department hoseline from the standpipe to the landing of the fire floor. If possible, lays excess hose UP stairwell towards floor above. | | | | |
| 5. | Assures nozzle is closed. | | | | |
| 6. | Orders backup man to charge hoseline. | | | | |
| 7. | Removes kinks from charged hoseline in vicinity of the nozzle. | | | | |
| 8. | Slowly opens the nozzle, bleeds air and flows water to assure proper flow. | | | | |
| 9. | Slowly closes the nozzle. | | | | |
| 10. | Assures backup man is on same side of the hoseline and ready to enter. | | | | |
| 11. | Checks door for heat with back of an ungloved hand, low to high | | | | |
| 12. | Opens door slowly and enters fire floor. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 414 | 09-01-13 | Candidate Number | | |
| Skill Title: CONNECT AND ADVANCE A HOSE LINE FROM A STANDPIPE – BACKUP POSITION | | | | | |
| NFPA Objective: | 5.3.10 | Minimum to pass | 8 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|------------|--|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Assists carrying hose into the structure to the standpipe, via the stairwell, to one (1) level below the fire floor. | | | | |
| 3. | Lays hose in stairwell. | | | | |
| 4. | Detaches building hoseline or removes protective cap (screw cap or breakaway) from standpipe. | | | | |
| 5. | Inspects standpipe outlet for debris, damaged threads, etc. | | | | |
| 6. | Connects necessary adapters to allow fire department hoseline attachment. | | | | |
| 7. | Connects fire department hoseline to standpipe hand-tight. | | | | |
| 8. | Upon orders from the nozzleman, slowly charges the fire department hoseline with the standpipe valve. | | | | |
| 9. | Advances to fire floor, removing kinks from charged hoseline. | | | | |
| 10. | Backs up nozzleman on same side of the hoseline | | | | |
| 11. | Assists the nozzleman with advancing hoseline onto fire floor | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-1- 415 | 09-01-13 | Candidate Number | | |
| Skill Title: OPERATION OF FOG AND SOLID MASTER STREAM NOZZLES | | | | | |
| NFPA Objective: | 5.3.8 | Minimum to pass | 10 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|-------------------------------------|-----|--|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. | Carries master stream device to set-up area. | | | | |
| <input type="checkbox"/> | 3. | Positions device on solid, level surface. | | | | |
| <input checked="" type="checkbox"/> | 4. | Aims female swivels opposite stream direction (determined by examiner) and utilizes the swivel locking device, if present. | | | | |
| <input checked="" type="checkbox"/> | 5. | Extends hoselines around the front of the device from opposite sides forming two large loops to reduce nozzle reaction (10 foot diameter minimum.) | | | | |
| <input type="checkbox"/> | 6. | Attaches hoseline to device. | | | | |
| <input type="checkbox"/> | 7. | Attaches tip to deliver appropriate stream as directed by examiner (solid, fog, straight) | | | | |
| <input type="checkbox"/> | 8. | Signals for water; flows stream. | | | | |
| <input type="checkbox"/> | 9. | Removes kinks in hoselines as necessary. | | | | |
| <input checked="" type="checkbox"/> | 10. | Upon direction from examiner, signals to stop water. | | | | |
| <input type="checkbox"/> | 11. | Changes tip to deliver appropriate stream as directed by examiner (solid, fog, straight) | | | | |
| <input type="checkbox"/> | 12. | Signals for water. Flows stream. | | | | |
| <input checked="" type="checkbox"/> | 13. | Upon direction from examiner, signals to stop water. | | | | |
| <input checked="" type="checkbox"/> | 14. | Breaks down and returns all equipment to original location | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 416 | 09-01-13 | Candidate Number | | |
| Skill Title: CONNECT HOSE LINES TO A FIRE DEPARTMENT CONNECTION | | | | | |
| NFPA Objective: | 5.3.10 | Minimum to pass | | 5 | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|-------------------------------------|----|---|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. | Stretches hose lines to fire department sprinkler connection. | | | | |
| <input type="checkbox"/> | 3. | Assures male couplings are toward connections. | | | | |
| <input type="checkbox"/> | 4. | Removes protective caps (screw plug or breakaway) from connection. | | | | |
| <input type="checkbox"/> | 5. | Inspects connection for debris, damaged threads, or missing gaskets. Replace gaskets, if necessary. | | | | |
| <input checked="" type="checkbox"/> | 6. | Connects hoselines to fire department connection. | | | | |
| <input checked="" type="checkbox"/> | 7. | Removes kinks from charged hoseline. | | | | |



Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 501 | 09-01-13 | Candidate Number | | |
| Skill Title: HYDRANT TO PUMPER CONNECTION-ONE SOFT INTAKE LINE | | | | | |
| NFPA Objective: | 5.3.15 | Minimum to pass | 9 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|-------------------------------------|-----|--|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. | Spots apparatus at the hydrant for the connection. | | | | |
| <input type="checkbox"/> | 3. | Removes the front intake cap. | | | | |
| <input type="checkbox"/> | 4. | Attaches the appropriate female end of the soft suction hose to the front intake. | | | | |
| <input type="checkbox"/> | 5. | Removes the appropriate hydrant discharge cap and places the hydrant wrench on the hydrant operating nut. | | | | |
| <input type="checkbox"/> | 6. | Inspects hydrant threads for damage and integrity. Inspects inside outlet for debris. | | | | |
| <input type="checkbox"/> | 7. | Attaches the appropriate female end of the soft suction hose to the hydrant. (Pumper may be moved to allow this connection to occur.) | | | | |
| <input checked="" type="checkbox"/> | 8. | Opens front intake valve before opening hydrant. | | | | |
| <input type="checkbox"/> | 9. | Slowly opens the hydrant fully. | | | | |
| <input type="checkbox"/> | 10. | Reduces any leakage by tightening connections and assures soft suction hose has no kinks. | | | | |
| <input type="checkbox"/> | 11. | Adds a chafing block at the point where hose touches the ground, if necessary. | | | | |
| <input checked="" type="checkbox"/> | 12. | Completes the connection as directed by the examiner. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | |
|---|-----------|-----------------|------------------|---|
| Skill Sheet No. | FF-I- 502 | 09-01-13 | Candidate Number | |
| Skill Title: HYDRANT TO PUMPER CONNECTION-TWO SOFT INTAKE LINES | | | | |
| NFPA Objective: | 5.3.15 | Minimum to pass | 9 | |
| PERFORMANCE: | | | P | F |

| | | | | | | |
|-------------------------------------|-----|--|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. | Removes the hydrant caps and places the hydrant wrench on the hydrant operating nut. | | | | |
| <input type="checkbox"/> | 3. | Inspects hydrant threads for damage and integrity. Inspects inside outlets for debris. | | | | |
| <input type="checkbox"/> | 4. | Attaches two closed gates to the hydrant discharge ports. | | | | |
| <input type="checkbox"/> | 5. | Connects the first hoseline to one of the hydrant gates. | | | | |
| <input type="checkbox"/> | 6. | Connects opposite end of the first hoseline to the pumper intake siamese. | | | | |
| <input checked="" type="checkbox"/> | 7. | Fully opens hydrant, then the hydrant gate slowly, then pumper intake. | | | | |
| <input type="checkbox"/> | 8. | Connects the second hoseline to the other hydrant gate. | | | | |
| <input type="checkbox"/> | 9. | Connects opposite end of the second hoseline to the pumper intake siamese. | | | | |
| <input checked="" type="checkbox"/> | 10. | Fully opens the second hydrant and pumper intake gates from the hydrant into the pumper, slowly. | | | | |
| <input type="checkbox"/> | 11. | Reduces any leakage by tightening connections and assures hoselines have no kinks. | | | | |
| <input checked="" type="checkbox"/> | 12. | Completes the assembly as directed by the examiner. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 503 | 09-01-13 | Candidate Number | | |
| Skill Title: ASSEMBLE DRAFTING EQUIPMENT | | | | | |
| NFPA Objective: | 5.3.15 | Minimum to pass | 8 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|-------------------------------------|-----|---|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. | Removes pumper intake cap. | | | | |
| <input checked="" type="checkbox"/> | 3. | Attaches two sections of hard suction together, taking care not to get dirt in the couplings | | | | |
| <input checked="" type="checkbox"/> | 4. | Attaches strainer to hard suction hose male coupling. | | | | |
| <input type="checkbox"/> | 5. | Utilizes rubber mallet, as necessary, to provide an airtight connection | | | | |
| <input type="checkbox"/> | 6. | Attaches rope to strainer. | | | | |
| <input type="checkbox"/> | 7. | Lowers hose and strainer into static source (portable tank.) | | | | |
| <input type="checkbox"/> | 8. | Attaches female coupling of hard suction hose to pumper intake. | | | | |
| <input type="checkbox"/> | 9. | Secures strainer rope to pumper or other stationary object. | | | | |
| <input checked="" type="checkbox"/> | 10. | Assures strainer and strainer-to-hose coupling is under water. | | | | |
| <input checked="" type="checkbox"/> | 11. | Completes the assembly as directed by the examiner. | | | | |
| <input type="checkbox"/> | | | | | | |
| <input type="checkbox"/> | | | | | | |
| <input type="checkbox"/> | | <i>Tightness of connections is proven by the Examiners ability/inability to achieve a prime. If prime is not achieved candidate will be informed of such and asked to perform any actions, if possible, to rectify the situation.</i> | | | | |



Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 504 | 09-01-13 | Candidate Number | | |
| Skill Title: HAND LAY HOSE FROM PUMPER TO WATER SOURCE-FIREFIGHTER ONE | | | | | |
| NFPA Objective: | 5.3.15 | Minimum to pass | 7 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|------------|---|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Removes hydrant wrench from pumper. | | | | |
| 3. | Removes the gates and appropriate amount of supply hose from the hose bed. Transfers to a flat shoulder load. | | | | |
| 4. | Waits for second firefighter to remove additional hose from bed. | | | | |
| 5. | Advances with second firefighter toward water source. | | | | |
| 6. | Once the second firefighter has unloaded his shoulder load, first firefighter starts allowing his hose to lay out on ground. | | | | |
| 7. | Continues to advance toward water source. | | | | |
| 8. | If source is not reached after both firefighters have laid their shoulder loads, they must return to pumper and pull off sufficient hose to reach source. | | | | |
| 9. | Places hydrant wrench on hydrant operating stem. | | | | |
| 10. | Attaches a hydrant gate to each 2½ port. Attaches hose into one gate. | | | | |
| 11. | Completes evolution as directed by the examiner. | | | | |
| | | | | | |
| | Candidate cannot return to apparatus solely to retrieve hydrant wrench | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 505 | 09-01-13 | Candidate Number | | |
| Skill Title: HAND HOSE LAY FROM PUMPER TO WATER SOURCE – FIREFIGHTER TWO | | | | | |
| NFPA Objective: | 5.3.15 | Minimum to pass | 6 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|-------------------------------------|----|---|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. | Waits for first firefighter remove hose, gates, and hydrant wrench from hose bed. | | | | |
| <input type="checkbox"/> | 3. | Removes appropriate amount of supply hose and transfers to a flat shoulder carry. | | | | |
| <input type="checkbox"/> | 3. | Advances with first firefighter toward water source. | | | | |
| <input type="checkbox"/> | 4. | Allows hose to lay out on ground as advancement continues. | | | | |
| <input type="checkbox"/> | 5. | If source is not reached after both firefighters have laid their shoulder loads, they must return to pumper and pull off sufficient hose to reach source. | | | | |
| <input type="checkbox"/> | 6. | Assists first firefighter in attaching hydrant gates and/or hose as needed. | | | | |
| <input checked="" type="checkbox"/> | 7. | Completes evolution as directed by the examiner. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 601 | 09-01-13 | Candidate Number | | |
| Skill Title: ONE FIREFIGHTER SHOULDER LADDER CARRY FROM THE GROUND | | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 8 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|------------|--|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Faces the tip of the ladder near the center of ladder. | | | | |
| 3. | Crouches/kneels beside the ladder on knee closest to ladder. | | | | |
| 4. | Grasps rung nearest the ladder's balance point, with the hand closest to the ladder. | | | | |
| 5. | Stands and pivots into the ladder inserting the other arm through the rungs. | | | | |
| 6. | Faces ladder butt and places the upper beam onto the shoulder. | | | | |
| 7. | Steadies ladder with both hands. | | | | |
| 8. | Tilts butt end to the ground as it is carried. | | | | |
| 9. | Uses leg, not back muscles, throughout the entire skill. | | | | |
| 10. | Carries the ladder to the destination as directed by the examiner and places onto the ground on the bed section. | | | | |
| 11. | Carries the ladder using the low shoulder carry as directed. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 602 | 09-01-13 | Candidate Number | | |
| Skill Title: ONE FIREFIGHTER FLAT RAISE OF AN EXTENSION LADDER FROM THE GROUND | | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 11 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|------------|---|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Checks the terrain and overhead obstructions before stepping forward or bringing the ladder to the vertical position. | | | | |
| 3. | Positions the ladder butt for the raise with the butt spurs against the wall of the building. | | | | |
| 4. | Raises the ladder, hand over hand, toward the ladder butt until ladder is vertical against the building. | | | | |
| 5. | Rolls the ladder to position the fly section of the ladder toward the building, if necessary. | | | | |
| 6. | Positions the tip of the ladder away from the building to a proper location for extending the fly. | | | | |
| 7. | Steadies the ladder with the instep, knee, and leg. | | | | |
| 8. | Grasps the halyard and extends the fly hand over hand to a height as directed by the examiner. | | | | |
| 9. | Locks the fly into place with the pawls. | | | | |
| 10. | Places ladder against the building and rolls ladder over so fly section is out. | | | | |
| 11. | Grasps a lower rung to carefully move the butt away from the building to the desired position. | | | | |
| 12. | Checks for proper placement, climbing angle, and makes necessary adjustments. | | | | |
| 13. | Secures the halyard. | | | | |
| 14. | Uses leg, not back, muscles throughout the entire skill. | | | | |
| 15. | Performs the flat raise as directed. | | | | |



Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 603 | 09-01-13 | Candidate Number | | |
| Skill Title: TWO FIREFIGHTER SHOULDER CARRY FROM THE GROUND-BUTT | | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 11 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|------------|--|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Position is on the same side of the ladder relative to the tip firefighter. | | | | |
| 3. | Crouches/kneels next to the ladder facing the tip on the knee closest to ladder. | | | | |
| 4. | Grasps a rung with the hand nearest to the ladder, palms facing forward. | | | | |
| 5. | Stands ladder on the beam. | | | | |
| 6. | Provides commands to lift ladder to the shoulder. | | | | |
| 7. | Stands and pivots into the ladder toward the butt. | | | | |
| 8. | Places the free arm between the rungs. | | | | |
| 9. | Lowers the upper beam onto the shoulder. | | | | |
| 10. | Is so positioned as to be able to reach beyond the butt of the ladder. | | | | |
| 11. | Provides commands to advance to destination. | | | | |
| 12. | Controls the ladder with the inside hand. | | | | |
| 13. | Uses leg, not back, muscles throughout the entire skill. | | | | |
| 14. | Carries the ladder to the destination as directed by the examiner and places onto the ground on the bed section. | | | | |
| 15. | Carries the ladder using the low shoulder carry as directed. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 604 | 09-01-13 | Candidate Number | | |
| Skill Title: TWO FIREFIGHTER SHOULDER CARRY FROM THE GROUND-TIP | | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 10 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|------------|--|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Position is on the same side of the ladder relative to the butt firefighter. | | | | |
| 3. | Crouches/kneels next to the ladder facing the tip while on the knee closest to ladder. | | | | |
| 4. | Grasps a rung with the hand nearest to the ladder, palms facing forward. | | | | |
| 5. | Stands ladder on beam. | | | | |
| 6. | Obeys commands to lift ladder to the shoulder. | | | | |
| 7. | Stands and pivots into the ladder toward the butt. | | | | |
| 8. | Places the free arm through the rungs. | | | | |
| 9. | Lowers the upper beam onto the shoulder. | | | | |
| 10. | Obeys commands to advance to destination. | | | | |
| 11. | Controls the ladder with the free hand. | | | | |
| 12. | Uses leg, not back muscles, throughout the entire skill. | | | | |
| 13. | Carries the ladder to the destination as directed by the examiner and places onto the ground on the bed section. | | | | |
| 14. | Carries the ladder using the low shoulder carry as directed. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 605 | 09-01-13 | Candidate Number | | |
| Skill Title: TWO FIREFIGHTER FLAT RAISE OF AN EXTENSION LADDER FROM THE GROUND-BUTT | | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 10 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-------------------------------------|--|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. Checks the terrain and overhead obstructions before stepping forward or bringing the ladder to the vertical position. | | | | |
| <input type="checkbox"/> | 3. Positions the ladder butt for the raise. | | | | |
| <input type="checkbox"/> | 4. Braces the ladder butt by standing on the bottom rung, grasping an upper rung and leaning back. | | | | |
| <input type="checkbox"/> | 5. Grasps successively higher rungs as ladder comes to the vertical. | | | | |
| <input checked="" type="checkbox"/> | 6. Pivots the ladder to position the fly section of the ladder away from the building, if necessary. | | | | |
| <input type="checkbox"/> | 7. Steadies ladder in preparation for extending the fly section. | | | | |
| <input type="checkbox"/> | 8. Grasps the halyard and extends the fly, hand over hand, to a height as directed by the tip firefighter. | | | | |
| <input checked="" type="checkbox"/> | 9. Locks the fly in place with the pawls. | | | | |
| <input type="checkbox"/> | 10. Slowly lowers the ladder into the building. | | | | |
| <input checked="" type="checkbox"/> | 11. Secures the halyard <u>after</u> properly positioning the ladder resting on the structure and climbing angle adjustments are made. | | | | |
| <input type="checkbox"/> | 12. Provides commands throughout the evolution to allow for fluid motion. | | | | |
| <input checked="" type="checkbox"/> | 13. Uses leg, not back, muscles throughout the entire skill. | | | | |
| <input checked="" type="checkbox"/> | 14. Performs the flat raise of an extension ladder as directed. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | |
|--|-----------|-----------------|------------------|---|
| Skill Sheet No. | FF-I- 606 | 09-01-13 | Candidate Number | |
| Skill Title: TWO FIREFIGHTER FLAT RAISE OF AN EXTENSION LADDER FROM THE GROUND-TIP | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 9 | |
| PERFORMANCE: | | | P | F |

| | | | | | |
|-------------------------------------|-----|---|--|--|--|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | |
| <input type="checkbox"/> | 2. | Advances hand over hand along the rungs toward the butt end until ladder is in a vertical position. | | | |
| <input checked="" type="checkbox"/> | 3. | Pivots the ladder to position the fly section of the ladder away from the building, if necessary. | | | |
| <input type="checkbox"/> | 4. | Braces the ladder at the assigned beam. | | | |
| <input type="checkbox"/> | 5. | Braces the ladder, with both hands on the beams, as the fly is extended. | | | |
| <input type="checkbox"/> | 6. | Informs the butt firefighter when the desired height has been reached. | | | |
| <input checked="" type="checkbox"/> | 7. | Assures the fly is locked with the pawls. | | | |
| <input type="checkbox"/> | 8. | Slowly lowers the ladder into the building, bracing with foot on rung. | | | |
| <input type="checkbox"/> | 9. | Checks for proper placement, climbing angle, and makes the necessary adjustments. | | | |
| <input type="checkbox"/> | 10. | Obeys commands to allow for fluid motion. | | | |
| <input checked="" type="checkbox"/> | 11. | Uses leg, not back, muscles throughout the entire skill. | | | |
| <input checked="" type="checkbox"/> | 12. | Performs the flat raise of an extension ladder as directed. | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 607 | 09-01-13 | Candidate Number | | |
| Skill Title: TWO FIREFIGHTER <u>BEAM</u> RAISE OF AN EXTENSION LADDER FROM THE GROUND-BUTT | | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 10 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-----------|--|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Checks the terrain and overhead obstructions before stepping forward or bringing the ladder to the vertical position. | | | | |
| 3. | Positions the ladder beam butt on the ground for the raise. | | | | |
| 4. | Places foot on the beam at a spur. | | | | |
| 5. | Grasps the upper beam and counterbalances the weight of the ladder. | | | | |
| 6. | Pivots the ladder to position the fly section of the ladder away from the building, if necessary. | | | | |
| 7. | Faces the tip firefighter and braces the ladder. | | | | |
| 8. | Grasps the halyard and extends the fly, hand over hand, to a height as directed by the tip firefighter. | | | | |
| 9. | Locks the fly in place with the pawls. | | | | |
| 10. | Slowly lowers the ladder into the building. | | | | |
| 11. | Secures the halyard <u>after</u> properly positioning the ladder resting on the structure and climbing angle adjustments are made. | | | | |
| 12. | Provides commands to allow for fluid motion. | | | | |
| 13. | Uses leg, not back, muscles throughout the entire skill. | | | | |
| 14. | Performs the beam raise as directed | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 608 | 09-01-13 | Candidate Number | | |
| Skill Title: TWO FIREFIGHTER <u>BEAM</u> RAISE OF AN EXTENSION LADDER FROM THE GROUND-TIP | | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 9 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-------------------------------------|--|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. Lifts and rests the beam of the ladder onto the shoulder. | | | | |
| <input type="checkbox"/> | 3. Advances, hand over hand, along beam toward the butt end until ladder is in a vertical position. | | | | |
| <input checked="" type="checkbox"/> | 4. Pivots the ladder to position the fly section of the ladder away from the building, if necessary. | | | | |
| <input type="checkbox"/> | 5. Faces the butt firefighter and braces the ladder. | | | | |
| <input type="checkbox"/> | 6. Informs butt firefighter when the fly has reached the desired height as directed. | | | | |
| <input checked="" type="checkbox"/> | 7. Assures the fly is locked with the pawls. | | | | |
| <input type="checkbox"/> | 8. Slowly lowers the ladder into the building while bracing with foot on rung. | | | | |
| <input type="checkbox"/> | 9. Checks for proper placement, climbing angle, and makes the necessary adjustments. | | | | |
| <input type="checkbox"/> | 10. Obeys commands to allow for fluid motion. | | | | |
| <input checked="" type="checkbox"/> | 11. Uses leg, not back, muscles throughout the entire skill. | | | | |
| <input checked="" type="checkbox"/> | 12. Performs and completes the beam raise as directed. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 609 | 09-01-13 | Candidate Number | | |
| Skill Title: TWO FIREFIGHTER FLAT LOWERING OF AN EXTENSION LADDER TO THE GROUND-BUTT | | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 9 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|------------|---|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Checks the terrain and overhead obstructions before bringing the ladder to the vertical position. | | | | |
| 3. | Unsecures the halyard and prepares to remove ladder from building. | | | | |
| 4. | Slowly removes the ladder from the building. | | | | |
| 5. | Extends the fly enough to unlock the pawls. | | | | |
| 6. | Slowly lowers the fly section using the halyard, hand over hand, to its lowered position. | | | | |
| 7. | Locks the pawls at the appropriate rung, if possible, and secures the halyard, if necessary. | | | | |
| 8. | Braces the ladder butt by standing on the bottom rung, grasping an upper rung and leaning back. | | | | |
| 9. | Braces the ladder as it is lowered to the ground. | | | | |
| 10. | Provides commands to allow for fluid motion throughout evolution. | | | | |
| 11. | Uses leg, not back, muscles throughout the entire skill. | | | | |
| 12. | Performs the flat lowering of an extension ladder as directed. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 610 | 09-01-13 | Candidate Number | | |
| Skill Title: TWO FIREFIGHTER FLAT LOWERING OF AN EXTENSION LADDER TO THE GROUND-TIP | | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 9 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|------------|--|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Braces the ladder with one foot on the rung. | | | | |
| 3. | Slowly raises the ladder away from the building. | | | | |
| 4. | Braces the ladder. | | | | |
| 5. | Informs the butt candidate when fly section is unlocked. | | | | |
| 6. | Steadies the ladder with both hands on the beams as the fly is lowered. | | | | |
| 7. | Repositions for lowering the ladder to the ground. | | | | |
| 8. | Lowers the ladder hand over hand along the rungs toward the tip until the ladder is in the horizontal position, swinging out on command. | | | | |
| 9. | Lowers ladder to the ground, kneeling down on inside knee. | | | | |
| 10. | Obeys commands to allow for fluid motion. | | | | |
| 11. | Uses leg, not back, muscles throughout the entire skill. | | | | |
| 12. | Performs the flat lowering of an extension ladder as directed. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 611 | 09-01-13 | Candidate Number | | |
| Skill Title: TWO FIREFIGHTER <u>BEAM</u> LOWERING OF AN EXTENSION LADDER TO THE GROUND-BUTT | | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 10 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-------------------------------------|--|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. Checks the terrain and overhead obstructions before bringing the ladder to the vertical position. | | | | |
| <input type="checkbox"/> | 3. Unsecures the halyard and prepares to remove ladder from building. | | | | |
| <input type="checkbox"/> | 4. Slowly removes the ladder from the building. | | | | |
| <input type="checkbox"/> | 5. Extends the fly enough to unlock the pawls. | | | | |
| <input type="checkbox"/> | 6. Slowly lowers the fly section using the halyard, hand over hand, to its lowered position. | | | | |
| <input type="checkbox"/> | 7. Locks the pawls at the appropriate rung, if possible, and secures the halyard. (if necessary) | | | | |
| <input type="checkbox"/> | 8. Repositions for lowering. | | | | |
| <input type="checkbox"/> | 9. Places foot on the beam the ladder will be lowered on, at the spur. | | | | |
| <input type="checkbox"/> | 10. Grasps the upper beam and counterbalances the weight of the ladder. | | | | |
| <input type="checkbox"/> | 11. Steadies the ladder as it is lowered to the ground. | | | | |
| <input type="checkbox"/> | 12. Provides commands to allow for fluid motion throughout the evolution. | | | | |
| <input checked="" type="checkbox"/> | 13. Uses leg, not back, muscles throughout the entire skill. | | | | |
| <input checked="" type="checkbox"/> | 14. Performs the beam lowering of an extension ladder as directed. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 612 | 09-01-13 | Candidate Number | | |
| Skill Title: TWO FIREFIGHTER <u>BEAM</u> LOWERING OF AN EXTENSION LADDER TO THE GROUND-TIP | | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 7 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|-------------------------------------|-----|---|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. | Faces the butt firefighter and braces the ladder with one foot on the rung. | | | | |
| <input type="checkbox"/> | 3. | Steadies and slowly raises the ladder from the building. | | | | |
| <input type="checkbox"/> | 4. | Informs the butt candidate when fly section is unlocked. | | | | |
| <input type="checkbox"/> | 5. | Braces the ladder. | | | | |
| <input type="checkbox"/> | 6. | Steadies the ladder as the fly section is lowered. | | | | |
| <input type="checkbox"/> | 7. | Repositions for lowering to the ground. | | | | |
| <input type="checkbox"/> | 8. | Lowers ladder, hand over hand, along the beam toward tip until the ladder is lowered fully to the ground. | | | | |
| <input type="checkbox"/> | 9. | Obeys commands to allow for fluid motion. | | | | |
| <input checked="" type="checkbox"/> | 10. | Uses leg, not back, muscles throughout the entire skill. | | | | |
| <input checked="" type="checkbox"/> | 11. | Performs the beam lowering of an extension ladder as directed. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 613 | 09-01-13 | Candidate Number | | |
| Skill Title: THREE FIREFIGHTER FLAT SHOULDER CARRY OF AN EXTENSION LADDER FROM THE GROUND-BUTT | | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 10 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-------------------------------------|---|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. Positions on the same side as one of the tip firefighters. | | | | |
| <input type="checkbox"/> | 3. Crouches/kneels next to ladder facing the tip on the knee closest to ladder. | | | | |
| <input type="checkbox"/> | 4. Grasps the ladder with the hand closest to the ladder. | | | | |
| <input type="checkbox"/> | 5. Provides commands to lift the ladder onto the shoulder. | | | | |
| <input type="checkbox"/> | 6. Stands and pivots toward the butt. | | | | |
| <input type="checkbox"/> | 7. Places the ladder beam on the shoulder. | | | | |
| <input type="checkbox"/> | 8. Is so positioned as to be able to reach beyond the butt of the ladder. | | | | |
| <input type="checkbox"/> | 9. Provides commands to allow for fluid motion throughout evolution. | | | | |
| <input type="checkbox"/> | 10. Controls the ladder with the inside hand. | | | | |
| <input checked="" type="checkbox"/> | 11. Uses leg, not back, muscles throughout the entire skill. | | | | |
| <input checked="" type="checkbox"/> | 12. Carries the ladder to the destination as directed by the examiner. | | | | |
| <input checked="" type="checkbox"/> | 13. Places ladder on the ground, kneeling on inside knee. | | | | |
| <input checked="" type="checkbox"/> | 14. Carries the ladder using the flat shoulder carry. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 614 | 09-01-13 | Candidate Number | | |
| Skill Title: THREE FIREFIGHTER FLAT SHOULDER CARRY OF AN EXTENSION LADDER FROM THE GROUND-TIP 1 | | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 9 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|--|------------|--|--|--|--|--|
| | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| | 2. | Positions either on the same side as the butt firefighter at the tip OR on the beam opposite the butt firefighter in the center. | | | | |
| | 3. | Crouches/kneels next to ladder facing the tip on the knee closest to ladder. | | | | |
| | 4. | Grasps ladder with the hand closest to the ladder. | | | | |
| | 5. | Obeys commands to lift ladder onto the shoulder. | | | | |
| | 6. | Stands and pivots toward the butt. | | | | |
| | 7. | Places the ladder beam on the shoulder. | | | | |
| | 8. | Obeys commands to advance to destination. | | | | |
| | 9. | Controls the ladder with the inside hand. | | | | |
| | 10. | Uses leg, not back, muscles throughout the entire skill. | | | | |
| | 11. | Carries the ladder to the destination as directed by the examiner. | | | | |
| | 12. | Places ladder on the ground, kneeling on inside knee. | | | | |
| | 13. | Carries the ladder using the flat shoulder carry as directed. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 615 | 09-01-13 | Candidate Number | | |
| Skill Title: THREE FIREFIGHTER FLAT SHOULDER CARRY OF AN EXTENSION LADDER FROM THE GROUND-TIP 2 | | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 10 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|--|------------|---|--|--|--|
| | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | |
| | 2. | Positions either on the same side as the butt firefighter at the tip OR on the beam opposite the butt firefighter in the center. | | | |
| | 3. | Crouches/kneels next to ladder facing the tip, on the knee closest to ladder. | | | |
| | 4. | Grasps ladder with the hand closest to the ladder. | | | |
| | 5. | Obeys commands to lift ladder onto the shoulder. | | | |
| | 6. | Stands and pivots toward the butt. | | | |
| | 7. | Places the ladder beam on the shoulder. | | | |
| | 8. | Obeys commands to advance to destination. | | | |
| | 9. | Controls the ladder with the inside hand. | | | |
| | 10. | Uses leg, not back, muscles throughout the entire skill. | | | |
| | 11. | Carries the ladder to the destination as directed by the examiner. | | | |
| | 12. | Places ladder on the ground, kneeling on inside knee. | | | |
| | 13. | Carries the ladder using the flat shoulder carry as directed. | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 616 | 09-01-13 | Candidate Number | | |
| Skill Title: THREE FIREFIGHTER FLAT RAISE OF AN EXTENSION LADDER FROM THE GROUND-BUTT | | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 10 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|------------|--|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Checks the terrain and overhead obstructions before stepping forward or bringing the ladder to the vertical position. | | | | |
| 3. | Positions the ladder butt properly for the raise. | | | | |
| 4. | Braces the ladder by standing on the bottom rung, grasping an upper rung and leaning back. | | | | |
| 5. | Pivots the ladder to position the fly section(s) of the ladder away from the building, if necessary. | | | | |
| 6. | Steadies the ladder as it is raised to the vertical. | | | | |
| 7. | Grasps the halyard and extends the fly, hand over hand, to a height as directed by the tip firefighters. | | | | |
| 8. | Locks the fly in place with the pawls. | | | | |
| 9. | Slowly guides the ladder into the building. | | | | |
| 10. | Secures the halyard <u>after</u> properly positioning the ladder resting on the structure and climbing angle adjustments are made. | | | | |
| 11. | Provides commands to allow for fluid motion throughout the evolution. | | | | |
| 12. | Uses leg, not back, muscles throughout the entire skill. | | | | |
| 13. | Performs the flat raise as directed. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 617 | 09-01-13 | Candidate Number | | |
| Skill Title: THREE FIREFIGHTER FLAT RAISE OF AN EXTENSION LADDER FROM THE GROUND-TIP 1 | | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 11 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|-------------------------------------|-----|--|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. | Crouches/kneels next to ladder facing the tip, on the knee closest to ladder. | | | | |
| <input type="checkbox"/> | 3. | On command from butt man raises ladder and pivots under the beam. | | | | |
| <input type="checkbox"/> | 4. | Advances in unison with other tip firefighter hand over hand along beams toward the butt end until ladder is in a vertical position. | | | | |
| <input type="checkbox"/> | 5. | Verifies overhead is clear while raising the ladder. | | | | |
| <input checked="" type="checkbox"/> | 6. | Pivots the ladder to position the fly section(s) of the ladder away from the building, if necessary. | | | | |
| <input type="checkbox"/> | 7. | Braces the ladder at the assigned beam. | | | | |
| <input type="checkbox"/> | 8. | Steadies the ladder with both hands as the fly is extended. | | | | |
| <input type="checkbox"/> | 9. | Informs the butt firefighter when the desired height has been reached. | | | | |
| <input type="checkbox"/> | 10. | Assures that the fly is locked with the pawls. | | | | |
| <input type="checkbox"/> | 11. | Slowly lowers the ladder into the building while bracing with inside foot on the rung. | | | | |
| <input checked="" type="checkbox"/> | 12. | Checks for proper placement, climbing angle and makes the necessary adjustments. | | | | |
| <input type="checkbox"/> | 13. | Obeys commands to allow for fluid motion. | | | | |
| <input checked="" type="checkbox"/> | 14. | Uses leg, not back, muscles throughout the entire skill. | | | | |
| <input checked="" type="checkbox"/> | 15. | Performs the flat raise as directed. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | |
|--|-----------|-----------------|------------------|---|
| Skill Sheet No. | FF-I- 618 | 09-01-13 | Candidate Number | |
| Skill Title: THREE FIREFIGHTER FLAT RAISE OF AN EXTENSION LADDER FROM THE GROUND-TIP 2 | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 11 | |
| PERFORMANCE: | | | P | F |

| | | | | | | |
|-------------------------------------|-----|--|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. | Crouches/kneels next to ladder facing the tip, on the knee closest to ladder. | | | | |
| <input type="checkbox"/> | 3. | On command from butt man raises ladder and pivots under the beam. | | | | |
| <input type="checkbox"/> | 4. | Advances in unison with other tip firefighter hand over hand along beams toward the butt end until ladder is in a vertical position. | | | | |
| <input type="checkbox"/> | 5. | Verifies overhead is clear while raising the ladder. | | | | |
| <input checked="" type="checkbox"/> | 6. | Pivots the ladder to position the fly section(s) of the ladder away from the building, if necessary. | | | | |
| <input type="checkbox"/> | 7. | Braces the ladder at the assigned beam. | | | | |
| <input type="checkbox"/> | 8. | Braces the ladder with both hands as the fly is extended. | | | | |
| <input type="checkbox"/> | 9. | Informs the butt firefighter when the desired height has been reached. | | | | |
| <input type="checkbox"/> | 10. | Assures that the fly is locked with the pawls. | | | | |
| <input type="checkbox"/> | 11. | Slowly lowers the ladder into the building while bracing with inside foot on the rung. | | | | |
| <input checked="" type="checkbox"/> | 12. | Checks for proper placement, climbing angle and makes the necessary adjustments. | | | | |
| <input type="checkbox"/> | 13. | Obeys commands to allow for fluid motion. | | | | |
| <input checked="" type="checkbox"/> | 14. | Uses leg, not back, muscles throughout the entire skill. | | | | |
| <input checked="" type="checkbox"/> | 15. | Performs the flat raise as directed. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 619 | 09-01-13 | Candidate Number | | |
| Skill Title: THREE FIREFIGHTER FLAT LOWERING OF AN EXTENSION LADDER TO THE GROUND-BUTT | | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 9 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|----------|-----|---|----------|--|--|--|
| ■ | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| | 2. | Checks the terrain and overhead obstructions before bringing the ladder to the vertical position. | | | | |
| | 3. | Unsecures the halyard and prepares to remove ladder from building. | | | | |
| | 4. | Slowly removes the ladder from the building. | | | | |
| | 5. | Extends the fly hand over hand enough to unlock the pawls. | | | | |
| | 6. | Slowly lowers the fly section(s), hand over hand, to the fly's lowered position. | | | | |
| | 7. | Locks the pawls at the appropriate rung, if possible, and secures the halyard, if necessary. | | | | |
| | 8. | Braces the ladder by standing on the bottom rung, grasping an upper rung and leaning back. | | | | |
| | 9. | Braces the ladder as it is lowered from the vertical. | | | | |
| | 10. | Provides commands to allow for fluid motion throughout the evolution. | | | | |
| ■ | 11. | Uses leg, not back, muscles throughout the entire skill. | ■ | | | |
| | 12. | Performs the flat lowering of an extension ladder as directed. | | | | |

| | | | | |
|----------------------|--|----------------------|--------|--|
| ■ | Failure of this critical portion is cause for entire skill failure | | | |
| Examiner Name: _____ | Signature: _____ | Date: ____/____/____ | | |
| Please circle: | PASS | FAIL | RETAKE | |

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 620 | 09-01-13 | Candidate Number | | |
| Skill Title: THREE FIREFIGHTER FLAT LOWERING OF AN EXTENSION LADDER TO THE GROUND-TIP 1 | | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 7 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|-------------------------------------|-----|---|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. | Braces the ladder at the assigned beam with inside foot on the rung. | | | | |
| <input type="checkbox"/> | 3. | Slowly removes the ladder from the building. | | | | |
| <input type="checkbox"/> | 4. | Braces the ladder with both hands as the fly is lowered. | | | | |
| <input type="checkbox"/> | 5. | Repositions for lowering the ladder to the ground. | | | | |
| <input type="checkbox"/> | 6. | Lowers the ladder in unison with the other tip firefighter, hand over hand, along the beams toward the tip until the ladder is in the horizontal position, swinging out on command. . | | | | |
| <input type="checkbox"/> | 7. | Lowers ladder to the ground, kneeling down on inside knee. | | | | |
| <input type="checkbox"/> | 8. | Obeys commands to allow for fluid motion. | | | | |
| <input checked="" type="checkbox"/> | 9. | Uses leg, not back, muscles throughout the entire skill. | | | | |
| <input checked="" type="checkbox"/> | 10. | Performs the flat lowering of an extension ladder as directed. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 621 | 09-01-13 | Candidate Number | | |
| Skill Title: THREE FIREFIGHTER FLAT LOWERING OF AN EXTENSION LADDER TO THE GROUND-TIP 2 | | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 7 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|------------|---|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Braces the ladder at the assigned beam with inside foot on the rung. | | | | |
| 3. | Slowly removes the ladder from the building. | | | | |
| 4. | Braces the ladder with both hands as the fly is lowered. | | | | |
| 5. | Repositions for lowering the ladder to the ground. | | | | |
| 6. | Lowers the ladder in unison with the other tip firefighter, hand over hand, along the beams toward the tip until the ladder is in the horizontal position, swinging out on command. . | | | | |
| 7. | Lowers ladder to the ground, kneeling down on inside knee. | | | | |
| 8. | Obeys commands to allow for fluid motion. | | | | |
| 9. | Uses leg, not back, muscles throughout the entire skill. | | | | |
| 10. | Performs the flat lowering of an extension ladder as directed. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 622 | 09-01-13 | Candidate Number | | |
| Skill Title: DEPLOYMENT OF A ROOF LADDER-RAISED TO THE LADDER | | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 9 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|------------|---|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Carries the roof ladder to the ground ladder to be ascended. | | | | |
| 3. | Places the roof ladder on the ground and opens the hooks. | | | | |
| 4. | Raises the roof ladder, resting it against the ground ladder, hooks facing outward. | | | | |
| 5. | Climbs the ground ladder positioning the shoulder about two (2) rungs above the midpoint of the roof ladder. | | | | |
| 6. | Reaches through the rungs of the roof ladder and places it onto the shoulder. | | | | |
| 7. | Climbs to the top of the ground ladder with the roof ladder on shoulder. | | | | |
| 8. | Secures with a leg lock as directed by the examiner. | | | | |
| 9. | Lowers the roof ladder from the shoulder onto the roof and, using the hand-over-hand method, pushes the roof ladder, hooks down, toward the peak. | | | | |
| 10. | When the hooks of the roof ladders fall over the peak, tugs roof ladder and ascertains that the hooks are firmly secured over the peak. | | | | |
| 11. | Uses leg, not back, muscles throughout the entire evolution. | | | | |
| 12. | Deploys the roof ladder properly and safely as directed. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | |
|---|-----------|-----------------|------------------|---|
| Skill Sheet No. | FF-I- 623 | 09-01-13 | Candidate Number | |
| Skill Title: CLIMB A LADDER WITH A TOOL AND SECURE A LEG LOCK | | | | |
| NFPA Objective: | 5.3.6 | Minimum to pass | 12 | |
| PERFORMANCE: | | | P | F |

| | | | | | | |
|-------------------------------------|-----|--|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. | Climbs the ladder to the top while carrying a forcible entry/ventilation tool after the climbing angle has been checked. | | | | |
| <input type="checkbox"/> | 3. | Checks that ladder pawls are locked and notifies the examiner of their status. | | | | |
| <input type="checkbox"/> | 4. | Keeps eyes forward with an occasional glance at the tip of the ladder. | | | | |
| <input checked="" type="checkbox"/> | 5. | Slides the tool along the side of the ladder beam and the free hand under the other ladder beam maintaining constant contact. | | | | |
| <input type="checkbox"/> | 6. | After reaching the tip, the firefighter descends the number of rungs as directed by the examiner. | | | | |
| <input type="checkbox"/> | 7. | Climbs one rung higher than working height. | | | | |
| <input checked="" type="checkbox"/> | 8. | Extends leg <u>opposite</u> the working side through rung. Bend knee. Bring foot through ladder just below rung supporting the knee. | | | | |
| <input type="checkbox"/> | 9. | Hooks foot over either a rung or top of beam. | | | | |
| <input type="checkbox"/> | 10. | Rests on thigh and steps down one rung. | | | | |
| <input checked="" type="checkbox"/> | 11. | Secures a leg lock as directed by the examiner. | | | | |
| <input type="checkbox"/> | 12. | Simulates performing work off the side of the ladder. | | | | |
| <input type="checkbox"/> | 13. | Releases the leg lock. | | | | |
| <input type="checkbox"/> | 14. | Descends the ladder to the ground. | | | | |
| <input checked="" type="checkbox"/> | 15. | Holds onto the tool at all times. | | | | |
| <input checked="" type="checkbox"/> | 16. | Completes the evolution as directed. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 624 | 09-01-13 | Candidate Number | | |
| Skill Title: ASSIST A CONSCIOUS VICTIM DOWN A LADDER | | | | | |
| NFPA Objective: | 5.3.9 | Minimum to pass | 5 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-----------|--|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Receives the victim, feet first, from the building opening. | | | | |
| 3. | Positions the victim for carrying. | | | | |
| 4. | Descends first keeping both arms around the victim under the armpits with hands on the rungs in front of the victim for support. | | | | |
| 5. | Keeps at least one hand on the ladder at all times. | | | | |
| 6. | Fully descends the ladder with the victim to the ground. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 625 | 09-01-13 | Candidate Number | | |
| Skill Title: ASSIST AN UNCONSCIOUS VICTIM DOWN A LADDER | | | | | |
| NFPA Objective: | 5.3.9 | Minimum to pass | 6 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|-------------------------------------|----|---|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. | Receives the victim from the building opening, feet first and are toward the firefighter. | | | | |
| <input type="checkbox"/> | 3. | Places the victim's legs and arms outside the beams of the ladder. | | | | |
| <input type="checkbox"/> | 4. | Fully supports the victim's body. | | | | |
| <input type="checkbox"/> | 5. | Keeps both arms around the victim. | | | | |
| <input checked="" type="checkbox"/> | 6. | Keeps hands on the rungs in front (back) of the victim. | | | | |
| <input type="checkbox"/> | 7. | Lowers victim one rung at a time. | | | | |
| <input checked="" type="checkbox"/> | 8. | Fully descends the ladder with the victim to the ground. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | |
|--|-----------|-----------------|------------------|---|
| Skill Sheet No. | FF-I- 701 | 09-01-13 | Candidate Number | |
| Skill Title: SALVAGE COVER ROLL FOR A ONE-FIREFIGHTER SPREAD | | | | |
| NFPA Objective: | 5.3.14 | Minimum to pass | 12 | |
| PERFORMANCE: | | | P | F |

| | | | | | | |
|----------|-----|--|----------|----------|----------|----------|
| ■ | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| | 2. | Lays salvage cover flat on a clean surface with finished side up. | | | | |
| | 3. | Takes a position at the end of the length of the cover, kneeling, and facing other firefighter. | | | | |
| | 4. | Grasps the edge of the cover with the outside hand midway between the center of the cover and the edge to be folded. | | | | |
| | 5. | Places free hand on cover midway between outside hand and center. | | | | |
| | 6. | Folds cover by bringing fold over pivot hand to center of cover to create an inside and an outside fold. | | | | |
| | 7. | Positions for next fold by placing outside hand at corner of cover and free hand as a pivot over outside fold. | | | | |
| | 8. | Grasps the outside corner with outside hand and using inside hand as a pivot, brings outside corner to the center. | | | | |
| | 9. | Moves to other half of cover and completes steps 3 through 8 to fold. | | | | |
| | 10. | Straightens folds, if necessary. | | | | |
| | 11. | Folds both ends of cover approximately 12 inches toward the center. | | | | |
| | 12. | Repositions at one end with other firefighter. | | | | |
| | 13. | Rolls cover toward opposite end. | | | | |
| | 14. | Compresses cover tightly tucking wrinkles forming ahead of cover and keeping edges aligned. | | | | |
| | 15. | Secures roll with supplied equipment. | | | | |
| ■ | 16. | Completes the salvage cover roll. | ■ | ■ | ■ | ■ |

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 702 | 09-01-13 | Candidate Number | | |
| Skill Title: SALVAGE COVER FOLD FOR A ONE-FIREFIGHTER SPREAD | | | | | |
| NFPA Objective: | 5.3.14 | Minimum to pass | 12 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|------------|--|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Lays salvage cover flat on a clean surface with finished side up. | | | | |
| 3. | Takes a position at the end of the length of the cover, kneeling, and facing other firefighter. | | | | |
| 4. | Grasps the edge of the cover with the outside hand midway between the center of cover and edge to be folded. | | | | |
| 5. | Places free hand on cover midway between outside hand and center. | | | | |
| 6. | Folds cover by bringing fold over pivot hand to center of cover to create an inside and an outside fold. | | | | |
| 7. | Positions for next fold by placing outside hand at corner of cover and free hand as a pivot over outside fold. | | | | |
| 8. | Grasps the outside corner with outside hand and using inside hand as a pivot, brings outside corner to the center. | | | | |
| 9. | Moves to other half of cover and completes steps 3 through 8. | | | | |
| 10. | Repositions, standing alongside other firefighter at the same end, facing the cover. | | | | |
| 11. | Picks up cover with one hand on the outside fold and one hand on the inside fold. | | | | |
| 12. | Folds cover to a point just short of the center (approximately 4 inches.) | | | | |
| 13. | Using one hand as a pivot, brings the folded end over the top of the first fold. | | | | |
| 14. | Folds cover again using techniques from steps 10 and 13. | | | | |
| 15. | Aligns one set of folds on top of the other set using space between the two stacks as a hinge. | | | | |
| 16. | Completes the salvage cover fold. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | |
|---|-----------|-----------------|------------------|---|
| Skill Sheet No. | FF-I- 703 | 09-01-13 | Candidate Number | |
| Skill Title: ONE FIREFIGHTER SPREAD OF A ROLLED SALVAGE COVER | | | | |
| NFPA Objective: | 5.3.14 | Minimum to pass | 9 | |
| PERFORMANCE: | | | P | F |

| | | | | | | |
|-------------------------------------|-----|---|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. | Starts unrolling cover just enough to cover end of objects while keeping remainder of roll tight. | | | | |
| <input type="checkbox"/> | 3. | Positions cover on the top near edge of the objects to be covered. | | | | |
| <input type="checkbox"/> | 4. | Unrolls cover across objects toward opposite end. | | | | |
| <input type="checkbox"/> | 5. | Allows cover to fall into place covering opposite end of objects. | | | | |
| <input type="checkbox"/> | 6. | Repositions at one end and faces unrolled cover. | | | | |
| <input type="checkbox"/> | 7. | Grasps the cover with each hand at the open edges. | | | | |
| <input checked="" type="checkbox"/> | 8. | Opens cover by snapping both hands up and out covering objects. | | | | |
| <input type="checkbox"/> | 9. | Repositions at opposite end. | | | | |
| <input checked="" type="checkbox"/> | 10. | Grasps cover and covers objects using same technique. | | | | |
| <input type="checkbox"/> | 11. | Tucks edges under and in to keep water out. | | | | |
| <input checked="" type="checkbox"/> | 12. | Completes the rolled salvage cover spread. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | |
|---|-----------|-----------------|------------------|---|
| Skill Sheet No. | FF-I- 704 | 09-01-13 | Candidate Number | |
| Skill Title: ONE FIREFIGHTER SPREAD OF A FOLDED SALVAGE COVER | | | | |
| NFPA Objective: | 5.3.14 | Minimum to pass | 10 | |
| PERFORMANCE: | | | P | F |

| | | | | | |
|-------------------------------------|-----|--|-------------------------------------|-------------------------------------|--------------------------|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 2. | Takes a position at one side of the objects to be covered. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 3. | Places cover on objects near the center. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 4. | Separates the stacked folds by unfolding the top folds at the hinge and laying folds flat. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 5. | Unfolds one-half of the cover toward one end, covering objects. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 6. | Repositions, and unfolds remaining half toward opposite end. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 7. | Allows cover to fall into place covering both ends fully. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 8. | Repositions at one end and faces unrolled cover. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 9. | Grasps the cover with each hand at the open edges. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 10. | Opens cover by snapping both hands up and out, covering objects. | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 11. | Repositions at opposite end. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 12. | Grasps cover and covers objects using same technique. | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 13. | Tucks edges under and in to keep water out. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 14. | Completes the folded salvage cover spread. | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 705 | 09-01-13 | Candidate Number | | |
| Skill Title: CONSTRUCTION OF A WATER CHUTE | | | | | |
| NFPA Objective: | 5.3.14 | Minimum to pass | 6 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-----------|---|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Positions salvage cover at desired location, finished side down, flat and open | | | | |
| 3. | Places pike poles on opposite edges with pikes extending off end of cover. | | | | |
| 4. | Rolls both edges equally over pike poles until there is a three foot width between the rolls. | | | | |
| 5. | Flips cover over keeping folds in place. | | | | |
| 6. | Elevates one end by hooking pike poles over ladder or object. | | | | |
| 7. | Extends chute out a door or window. | | | | |
| 8. | Completes and indicates that the water chute is complete. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 707 | 09-01-13 | Candidate Number | | |
| Skill Title: SHUTTING OFF ELECTRICAL SERVICE TO A BUILDING | | | | | |
| NFPA Objective: | 5.3.18 | Minimum to pass | 4 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|-------------------------------------|----|--|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| <input type="checkbox"/> | 2. | Searches area/building for electrical service box or panel. | | | | |
| <input checked="" type="checkbox"/> | 3. | Shuts off main breakers or pulls knife switch arm to shut off power using a concentrated motion for a clean break. | | | | |
| <input type="checkbox"/> | 4. | Looks away while manipulating breakers/switches. | | | | |
| <input type="checkbox"/> | 5. | Applies lock out/tag out equipment (if available). | | | | |
| <input checked="" type="checkbox"/> | 6. | Confirms to examiner that electrical service has been shut off. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | |
|-----------------|-----------|----------|------------------|--|
| Skill Sheet No. | FF-I- 708 | 09-01-13 | Candidate Number | |
|-----------------|-----------|----------|------------------|--|

Skill Title: SHUTTING OFF NATURAL GAS SERVICE

| | | | |
|-----------------|--------|-----------------|---|
| NFPA Objective: | 5.3.18 | Minimum to pass | 4 |
|-----------------|--------|-----------------|---|

| | | |
|--------------|---|---|
| PERFORMANCE: | P | F |
|--------------|---|---|

| | | | | | | |
|-------------------------------------|----|--|-------------------------------------|--------------------------|--------------------------|--------------------------|
| <input checked="" type="checkbox"/> | 1. | All Personal Protective Equipment (PPE) is properly worn. | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 2. | Searches area/building for natural gas meter. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 3. | Using a proper wrench, turns petcock to the "CLOSED" position. | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 4. | Turns any remaining visible valves to the "CLOSED" position. | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input type="checkbox"/> | 5. | Applies lock out/tag out equipment (if available). | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| <input checked="" type="checkbox"/> | 6. | Confirms to examiner that natural gas has been shut off. | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council

Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 709 | 09-01-13 | Candidate Number | | |
| Skill Title: SHUTTING OFF LPG OR CNG SERVICE | | | | | |
| NFPA Objective: | 5.3.18 | Minimum to pass | | 4 | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-----------|--|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Searches area/building for LPG or CNG cylinder or tank. | | | | |
| 3. | Locates shut-off on cylinder or tank. | | | | |
| 4. | Closes shut-off valve clockwise fully or in the direction of the arrow on the valve. | | | | |
| 5. | Confirms to examiner the LPG or CNG service has been shut off. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 710 | 09-01-13 | Candidate Number | | |
| Skill Title: SHUTTING OFF WATER SERVICE | | | | | |
| NFPA Objective: | 5.3.18 | Minimum to pass | 3 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-----------|--|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Searches area/building for main water feeder. | | | | |
| 3. | Closes feeder-main valve fully. | | | | |
| 4. | Confirms to examiner that water service has been shut off. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-I- 711 | 09-01-13 | Candidate Number | | |
| Skill Title: USE OF A SPRINKLER WEDGE OR STOPPER | | | | | |
| NFPA Objective: | 5.3.18 | Minimum to pass | 4 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|----------|----|--|----------|----------|----------|----------|
| ■ | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| | 2. | Places ladder and safely climbs ladder to within reach of sprinkler head. | | | | |
| | 3. | Inserts a wedge (flat sides up & down) or inserts sprinkler tongs between head arms. | | | | |
| | 4. | Drives wedge into sprinkler or opens and locks tongs. | | | | |
| ■ | 5. | Stops flow of water from head. | ■ | ■ | ■ | ■ |

| | | | |
|----------------------|--|-----------------------|--------|
| ■ | Failure of this critical portion is cause for entire skill failure | | |
| Examiner Name: _____ | Signature: _____ | Date: ___ / ___ / ___ | |
| Please circle: | PASS | FAIL | RETAKE |

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-1- 712 | 09-01-13 | Candidate Number | | |
| Skill Title: OPEN AND CLOSE A SPRINKLER SYSTEM MAIN DRAIN | | | | | |
| NFPA Objective: | 5.3.18 | Minimum to pass | 4 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-----------|--|--|--|--|--|
| 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| 2. | Assures water supply valves are closed. | | | | |
| 3. | Opens main drain valve by slowly turning counter clockwise. | | | | |
| 4. | Opens main drain valve fully. | | | | |
| 5. | Once flow has stopped, close main drain valve by turning clockwise until fully closed. | | | | |



Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___ / ___ / ___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-II-203 | 09-01-13 | Candidate Number | | |
| Skill Title: DISPLACE A VEHICLE DOOR USING HYDRAULIC TOOLS | | | | | |
| NFPA Objective: | 6.4.1 | Minimum to pass | 10 | | |
| PERFORMANCE: | | | | P | F |

| | | | | |
|-------------------------------------|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. Wears full protective clothing with eye protection in position. | | | |
| <input type="checkbox"/> | 2. Assures vehicle is stable and battery disconnected. | | | |
| <input type="checkbox"/> | 3. Assesses passive restraint system for deployment. | | | |
| <input checked="" type="checkbox"/> | 4. Assures patient is properly covered/protected. | | | |
| <input type="checkbox"/> | 5. Assures door is not locked and cannot be opened as designed. | | | |
| <input type="checkbox"/> | 6. Assures unnecessary personnel are clear of door area. | | | |
| <input checked="" type="checkbox"/> | 7. Assures all glass in door is safely removed. | | | |
| <input type="checkbox"/> | 8. Provides access for hydraulic spreader at either the hinge or latch side of door. | | | |
| <input type="checkbox"/> | 9. Displaces first attachment side. (hinge or latch) | | | |
| <input type="checkbox"/> | 10. Displaces second attachment side. (hinge or latch) | | | |
| <input checked="" type="checkbox"/> | 11. Does not jeopardize the patient throughout the evolution. | | | |
| <input type="checkbox"/> | 12. Uses leg, not back muscles when lifting equipment. | | | |
| <input type="checkbox"/> | 13. Displaces the vehicle door. | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|------------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-II- 204 | 09-01-13 | Candidate Number | | |
| Skill Title: DISPLACE A VEHICLE WINDSHIELD USING AN AXE RESCUER ONE | | | | | |
| NFPA Objective: | 6.4.1 | Minimum to pass | 9 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-------------------------------------|---|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. Wears full protective clothing with eye protection in position. | | | | |
| <input type="checkbox"/> | 2. Assures vehicle is stable and battery disconnected. | | | | |
| <input checked="" type="checkbox"/> | 3. Assures patient is properly covered/protected. | | | | |
| <input type="checkbox"/> | 4. Takes a position opposite the other rescuer on the other side of the vehicle. | | | | |
| <input type="checkbox"/> | 5. Starts at the top of the windshield and cuts across top, down the side to the bottom edge of the windshield. | | | | |
| <input type="checkbox"/> | 6. Uses short strokes keeping one hand near the axe head for control. | | | | |
| <input type="checkbox"/> | 7. Passes the axe, handle first to the opposite rescuer. | | | | |
| <input type="checkbox"/> | 8. Supports the windshield as the other rescuer completes cutting other side. | | | | |
| <input type="checkbox"/> | 9. Working with other rescuer folds windshield down onto hood | | | | |
| <input type="checkbox"/> | 10. Places windshield either under the vehicle or in other safe location out of the immediate area. | | | | |
| <input checked="" type="checkbox"/> | 11. Does not jeopardize the patient throughout the evolution. | | | | |
| <input checked="" type="checkbox"/> | 12. Displaces the vehicle windshield. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-II-205 | 09-01-13 | Candidate Number | | |
| Skill Title: DISPLACE A VEHICLE WINDSHIELD USING AN AXE RESCUER TWO | | | | | |
| NFPA Objective: | 6.4.1 | Minimum to pass | 7 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-------------------------------------|--|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. Wears full protective clothing with eye protection in place. | | | | |
| <input type="checkbox"/> | 2. Assures vehicle is stable and battery disconnected. | | | | |
| <input checked="" type="checkbox"/> | 3. Assure patient is properly covered/protected. | | | | |
| <input type="checkbox"/> | 4. Takes a position opposite the other rescuer on the other side of the vehicle. | | | | |
| <input type="checkbox"/> | 5. Receives axe from opposite rescuer and continues cutting at the top of the windshield and down the side to the bottom edge. | | | | |
| <input type="checkbox"/> | 6. Uses short strokes keeping one hand near the axe head for control. | | | | |
| <input type="checkbox"/> | 7. Working with other rescuer folds windshield down onto hood. | | | | |
| <input type="checkbox"/> | 8. Places windshield either under the vehicle or in other safe location out of the immediate area. | | | | |
| <input checked="" type="checkbox"/> | 9. Does not jeopardize the patient throughout the evolution. | | | | |
| <input checked="" type="checkbox"/> | 10. Displaces the vehicle windshield. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|---|-----------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-II-206 | 09-01-13 | Candidate Number | | |
| Skill Title: DISPLACE A VEHICLE STEERING COLUMN AND DASHBOARD USING HYDRAULIC TOOLS | | | | | |
| NFPA Objective: | 6.4.1 | Minimum to pass | 9 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | |
|-------------------------------------|---|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. Wears full protective clothing with eye protection in place. | | | | |
| <input type="checkbox"/> | 2. Assures vehicle is stable and battery disconnected. | | | | |
| <input type="checkbox"/> | 3. Assesses passive restraint system for deployment. | | | | |
| <input checked="" type="checkbox"/> | 4. Assures patient is properly covered/protected. | | | | |
| <input type="checkbox"/> | 5. Assures both front doors and windshield have been removed. | | | | |
| <input type="checkbox"/> | 6. Makes relief cuts at the bottom of the "A" post as close to the rocker panels as necessary. | | | | |
| <input type="checkbox"/> | 7. Cuts top of "A" post. | | | | |
| <input type="checkbox"/> | 8. Properly utilizes cutters, rams and/or spreaders to displace the steering column and dashboard simultaneously. | | | | |
| <input checked="" type="checkbox"/> | 9. Utilizes cribbing, where necessary, to support and secure displaced parts. | | | | |
| <input type="checkbox"/> | 10. Uses leg, not back muscles when lifting equipment. | | | | |
| <input type="checkbox"/> | 11. Does not jeopardize the patient throughout the evolution. | | | | |
| <input type="checkbox"/> | 12. Displaces the vehicle steering column and dashboard. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|------------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-II- 401 | 09-01-13 | Candidate Number | | |
| Skill Title: SERVICE TESTING FIRE HOSE | | | | | |
| NFPA Objective: | 6.5.5 | Minimum to pass | 13 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|----------|-----|---|--|--|--|--|
| ■ | 1. | All Personal Protective Equipment (PPE) is properly worn. | | | | |
| | 2. | Checks gaskets and connects hose lengths together. (no more than 300') hose should be laid out straight. | | | | |
| ■ | 3. | Connects and tightens an open test gate valve to the discharge port. | | | | |
| ■ | 4. | Utilizes a rope, rope tool, or hose strap to anchor hose to pumper at test gate valve connection. | | | | |
| | 5. | Attaches a shutoff nozzle to the open end of test length. | | | | |
| | 6. | Fills hoseline with water and increases pressure to 50 PSI. | | | | |
| | 7. | Permits air to discharge fully from the line by opening the nozzle. | | | | |
| | 8. | Makes a chalk or pencil mark on hose jacket against each coupling. | | | | |
| ■ | 9. | Checks that no couplings are leaking. Tightens any couplings, if necessary. | | | | |
| ■ | 10. | Closes test valve and increases pump pressure to the required test pressure. | | | | |
| | 11. | Maintains pressure for five minutes. | | | | |
| | 12. | While at the test pressure the candidate shall walk along the test hose inspecting it for leaks. At no time shall the candidate be any closer than 15 feet to the hose, and he/she shall be on the left side of the hose while looking toward the nozzle end from the pump end. | | | | |
| | 13. | Slowly reduces pump pressure after five minutes, closes discharge valve, assures the pump is disengaged. | | | | |
| | 14. | Opens nozzles to bleed off pressure. | | | | |
| | 15. | Breaks connections and drains water away from the test area. | | | | |
| | 16. | Observes marks placed on hose at the couplings. | | | | |
| ■ | 17. | Determines whether each length can remain in service or be tagged and placed out of service. | | | | |
| ■ | 18. | Completes evolution safely | | | | |

■ Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE

Massachusetts Fire Training Council Firefighter Practical Certification Examination

| | | | | | |
|--|------------|-----------------|------------------|---|---|
| Skill Sheet No. | FF-II- 501 | 09-01-13 | Candidate Number | | |
| Skill Title: PRESENTATION OF PUBLIC FIRE EDUCATION MESSAGE | | | | | |
| NFPA Objective: | 6.5.2 | Minimum to pass | 5 | | |
| PERFORMANCE: | | | | P | F |

| | | | | | | |
|-------------------------------------|----|--|--|--|--|--|
| <input checked="" type="checkbox"/> | 1. | Explains the purpose of Stop, Drop, and Roll. | | | | |
| <input type="checkbox"/> | 2. | Instructs student to STOP and stay in place | | | | |
| <input type="checkbox"/> | 3. | Instructs student to DROP to the ground/floor and cover face with hands. | | | | |
| <input type="checkbox"/> | 4. | Instructs student to ROLL to extinguish flames by tucking in elbows and keeping legs together. | | | | |
| <input checked="" type="checkbox"/> | 5. | Demonstrates STOP, DROP, AND ROLL procedure to student. | | | | |
| <input type="checkbox"/> | 6. | Instructs student to demonstrate. | | | | |
| <input type="checkbox"/> | 7. | Evaluate student's performance. | | | | |

Failure of this critical portion is cause for entire skill failure

Examiner Name: _____ Signature: _____ Date: ___/___/___

Please circle: PASS FAIL RETAKE