

## **780 CMR 10.00 MEANS OF EGRESS**

### **780 CMR 1018.0 NUMBER OF EXITS AND CONTINUITY**

**1018.1 Minimum Number of Exits.** *For A-2 nightclubs (A-2nc) also see 780 CMR 1024.* All rooms and spaces within each story shall be provided with and have access to the minimum number of approved independent exits as required by Table 1018.1 based on the occupant load, except as modified in 780 CMR 1014.1 or 1018.2. For the purposes of 780 CMR 10.00, occupied roofs shall be provided with exits as required for stories. The required number of exits from any story, basement or individual space shall be maintained until arrival at grade or the public way.

**Exception: Individual rooms or spaces at the level of exit discharge that are not required to have two exits by the provisions of Section 1014.1 shall be permitted to have a single exit directly to the exterior provided the interior and exterior common path of travel do not exceed the limitations of Section 1013.3 for the occupancy of the space.**